REPORT DOCUMENTATION PAGE	Form Approved OMB No. 0704-0188						
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for information Operations and Reports, 1215 Jefferson Davis Highway. Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.							
1. AGENCY USE ONLY (Leave blank)       2. REPORT DATE       3. REPORT TYPE         November 1989       Final Report	AND DATES COVERED Ort						
4. TITLE AND SUBTITLE CABLE STAYED BRIDGE STATIC TESTSAN EXPERIMENTAL STUD for the CAPTAIN WILLIAM MOORE CREEK BRIDGE	Y 5. FUNDING NUMBERS						
G. AUTHOR(S) J. Leroy Hulsey David K. Delaney Richard W. Briggs							
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)	8. PERFORMING ORGANIZATION REPORT NUMBER						
INSTITUTE OF NORTHERN ENGINEERING 539 Duckering Building Fairbanks, AK 99775-0660	INE88.47						
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) State of Alaska	10. SPONSORING / MONITORING AGENCY REPORT NUMBER						
Department of Transportation and Public Facilities Statewide Research M/S 2554 2301 Peger Road Fairbanks, Alaska 99709-5316	<b>88NX174</b> FHWA-AK-RD-90-08						
11. SUPPLEMENTARY NOTES							
Conducted in cooperation with the U.S. Department of Tr Federal Highway Administration.	cansportation,						
12a. DISTRIBUTION / AVAILABILITY STATEMENT	126. DISTRIBUTION CODE						
13. ABSTRACT (Maximum 200 words) A 300-ft fracture-critical bridgelocated on the highway between Skagway, Alaska and Carcross, Canadasupports automobiles, campers, buses, and ore trucks during summer months. During the winter months, the bridge is subjected to predominantly ore truck traffic. At the time of the study, the loaded ore trucks weighed approximately 160,000 lbs.							
The bridge is a two-lane structure with a laminated timber deck supported by transverse floor beams spanning two stiffened ASTM A588 steel box girders. The box girders have 30-, 123-, 127-, and 20-foot span lengths.							
The bridge was instrumented to evaluate the static live-load performance when subjected to a loaded ore truck. Instrumentation included strain gages on the box girders, pylons, and an upstation column support. In addition, environmental sensors were installed to monitor solar radiation, wind speed, air temperature, and temperature distribution through a box girder. Tests were conducted to monitor static response for two types of loads at predetermined positions. The two loads were preweighed ore trucks and a Snooper truck which was used as a control vehicle.							
Experimental strain data, girder deflections, and environmental data were recorded and reported.							
14. SUBJECT TERMS Keywords: Instrumentation, bridges, loads, temperatures, temperature distribu load tests, testing	15. NUMBER OF PAGES 112 16. PRICE CODE						
17. SECURITY CLASSIFICATION 18. SECURITY CLASSIFICATION 19. SECURITY CLASSIF OF REPORT OF THIS PAGE OF ABSTRACT	ICATION 20. LIMITATION OF ABSTRACT						

		_			_
NSN	754	0-0	1-28	0-5	500

UNCLASSIFIED

UNCLASSIFIED

1

UNCLASSIFIED

### CABLE STAYED BRIDGE STATIC TESTS--AN EXPERIMENTAL STUDY for the CAPTAIN WILLIAM MOORE CREEK BRIDGE

Final Report

J. Leroy Hulsey Associate Professor of Civil Engineering David K. Delaney Graduate Assistant, Dept. of Civil Eng. UNIVERSITY OF ALASKA FAIRBANKS INSTITUTE OF NORTHERN ENGINEERING

and

Richard W. Briggs, Electronic Technician ALASKA DEPARTMENT OF TRANSPORTATION

November 1989

Prepared for

State of Alaska Department of Transportation and Public Facilities Statewide Research M/S 2554 2301 Peger Road Fairbanks, Alaska 99709-5316

In cooperation with

U.S. Department of Transportation Federal Highway Admission

The contents of this report reflect the views of the authors, who are responsible for the facts and accuracy of the data presented herein. The contents do not necessarily reflect the official views of the Alaska Department of Transportation and Public Facilities or the Federal Highway Administration. This report does not constitute a standard, specification, or regulation.

Publication Cost \$17.00

#### ACKNOWLEDGMENTS

The authors would like to thank the Alaska Department of Transportation and the Federal Highway Administration for providing the research funds to investigate the static behavior of the Captain William Moore Creek Bridge near Skagway Alaska.

The authors would also like to thank Mr. Rufus B. Bunch, a graduate student who helped prepare the instrumentation, conducted laboratory calibration studies, and assisted with the installation and data collection for the one-week period during field testing.

Thanks are due to Mr. Jim Miracle from Tok DOT Maintenance who drove the snooper truck and assisted with gage preparation, installation and traffic control. Mr. Keith Knorr from Skagway DOT Maintenance also provided assistance with the gage preparation, installation and traffic control.

Mr. George Imbsen and Mr. Mike Rieves both from DOT Bridge Design are to be thanked for their assistance with traffic control during the instrumentation installation and field data monitoring. Without efforts from each of the above personnel, this project would not have been possible.

### ABSTRACT

The Captain William Moore Creek Bridge is an unusual 300 ft cable-stayed bridge located on the highway between Skagway, Alaska and Carcross, Canada. The bridge has a laminated timber deck supported by transverse floor beams spanning two stiffened ASTM A588 steel box girders. The box girders have span lengths of 30-123-127-20 ft.

This bridge was originally designed in 1974 to carry AASHTO HS20-44 highway loads and was strengthened in 1986 to carry B-Train trucks hauling ore weighing approximately 160,000 lbs.

The Captain William Moore Creek Bridge is a unique design that is fracture critical. It is subjected to a mix of automobiles, campers, and nonstandard ore trucks during the summer months. During the winter months, the bridge is subjected predominantly to nonstandard ore truck traffic and temperature extremes typical of an Alaskan winter. This combination of conditions provides a strong argument for studying the bridge's behavior. Thus, a two-part study was implemented to examine the static response when subjected to B-Train truck loads.

In the summer of 1988, this bridge was instrumented with strain gages on the box girders, pylons, and an upstation column abutment support. In addition, environmental sensors were installed to monitor solar radiation, wind speed, air temperature, and the temperature distribution through a box girder.

The bridge was subjected to a static snooper truck (used as the control load) and static B-Train loads. Experimental strain data, deflections, and environmental data were recorded. The investigation was conducted in the following manner:

<u>Part 1</u> involved instrumentation, experimentation, and presentation of results for controlled statically loaded field tests. This report is devoted to this part of the study.

ii

Part 2 consisted of performing a two-dimensional finite element analysis of the bridge for the loads studied in Part 1. The results were compared with the experimental data. This information is presented in a separate report.

# TABLE OF CONTENTS

ACKNO ABSTR	WLEDGE ACT .	MENTS .	•••	•	•••	•	•••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	.i ii
LIST	OF FIG	URES .	•••	•	• •	•	•••	٠	٠	٠	•	٠	٠	•	•	٠	•	•	•	•	٠	•	٠	Vi
LIST	OF TAB	LES	•••	•	•••	•	•••	•	•	•	•	•	•	•	•	•	•	٠	•	•	•	•	•	vii
1.	INTRO	DUCTION	• • •	•	• •	•	•••	•	•	•	•	•	•	•	•	•		•	•	•	•	•	•	1
	1.1 1.2 1.3	Develop Experim Captain	ment d ental Willi	of ( Stu iam	Cabl udie Moc	e-S es t ore	Sta Sy Cr	ye Otl eel	d I hei k I	Br rs Bri	i dg i dg	jes je	S.	• •	• •	• •	• •	•	• •	•	• •	•	• •	1 2 5
2.	EXECU	TIVE SUM	MARY.		•	••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	9
	2.1 2.2	Maximum Girder	Strai Deflec	ns. tio	ons	•••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	`10 10
3.	INSTR	UMENTATI	. NC	•••	•	•••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	12
	3.1 3.2 3.3 3.4 3.5 3.6	Project General Instrum Laborato Field In Field Pi	Objec Infor entati ory Pr nstall rogram	tiv mat on/ epa ati an	e. Mon rat on d C	ito ion 	bri bri	ng nd ati	Ec Ca	; i i i i i	ipm br	ien at	io	• • n •	• • • •	• • • •	• • • •	• • • •	• • • •	• • • •	• • • •	• • • •	• • • •	12 12 13 20 25 26
4.	FIELD	STUDY.	• • •	• •	٠	•••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	29
	4.1 4.2 4.3	Test Pro Snooper B-Train	ocedur Truck Tests	e Te	sts	• • • •	• •	• •	• •	• •	•	• •	• •	• •	•	•	• •	•	•	•	•	•	•	29 33 36
5.	EXPER	[MENTAL F	RESULT	s.	•	••	٠	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	39
	5.1 5.2	Snooper B-Train	Truck Loads	L0	ads	•••	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	39 40

6.	SUMMARY	. 43
	6.1 Snooper truck	. 43 . 43
7.	CONCLUSION	. 49
8.	REFERENCES	. 51
APPENI	IDIX A: FIELD DATA REDUCTION INFORMATION	A
	A.1General Comments	A-1 A-1 A-8 A-9 A-9 A-10 A-10
APPENI	IDIX B: SNOOPER TRUCK FIELD DATA	В
	Test No. SLDOSO2 Test No. SRUOSO3 Test No. SCDOSO4 Test No. SCDOSO5	B-2 B-30 B-57 B-84
APPENI	IDIX C: B-TRAIN FIELD DATA	с
	Test No. SLDOBO6 Test No. SLDOBO8 Test No. SCDOBI0 Test No. SRDOB11	C-2 C-7 C-11 C-16

# LIST OF FIGURES

		Page
Figure 1.1	Captain William Moore Creek Bridge Geometry	6
Figure 3.1	Strain Gage Locations and Numbering Scheme	14
Figure 3.2	Strain Gage Wiring Diagram	17
Figure 3.3	Power Supply for the Strain Gages and LVDT	19
Figure 3.4	Data Acquisition System	21
Figure 3.5	Operator Interface for Data Collection	22
Figure 4.1	Bridge Frame and Critical Load Position	30
Figure 4.2	Bridge Frame and Floor Beam Position	32
Figure 4.3	Snooper Truck	34
Figure 4.4	Ore Truck Configuration (B-Train)	37

# LIST OF TABLES

Table 2.1	William Moore Creek Bridge Maximum Strains and Stresses	10
Table 4.1	Snooper Truck Test Series	36
Table 4.2	B-Train Tests	38
Table 5.1	Maximum Strains and Stresses for Snooper Truck Loads	40
Table 5.2	Maximum Strains and Stresses for B-Trains	41
Table 6.1	Maximum Strains Produced by Snooper Trucks	43
Table 6.2	Maximum Strains Produced by B-Trains	44
Table 6.3	Strain Extremes for Symmetric Snooper Truck Loads	45
Table 6.4	Strain Extremes for Asymmetric Snooper Truck Loads	46
Table 6.5	Strain Extremes for Symmetric B-Train Truck Loads	47
Table 6.6	Strain Extremes for Asymmetric B-Train Truck Loads	48
A.1	Laboratory Measured Cable (2-wire) Resistances	A-4

### 1. INTRODUCTION

### 1.1 Development of Cable-Stayed Bridges

The basic elements of cable-stayed bridges have been used as structural components for centuries. The idea of supporting beams by inclined ropes or chains connected to a mast or a tower goes back to the times of the early Egyptians who applied the concept to their sailing ships. Tropical regions of the world applied the concept to primitive types of foot bridges using vines attached to trees on either bank to support a walk of vines and bamboo sticks(6).

The development of the cable-stayed system progressed very slowly at first. Although many applications have been recorded through history, the system initially met with little success. This was because early designers did not understand the type of materials needed for inclined bars and chains and lacked knowledge of the statics of the cable-stayed bridge. Thus, several of the first cable-stayed bridges collapsed. This led to a partial abandonment of that type of bridge.

During the post-war years in Western Europe, materials were in short supply and a need to obtain optimum material performance sparked a renewed interest in the cable-stayed system. However, it wasn't until the past twenty years that the concept received wide and successful application, due to the introduction of high-strength steels and orthotropic type decks, the development of welding techniques, and progress in structural analysis. Existing structural facilities have provided useful data in understanding the performance of cable-stayed systems. Through the above process, state-of-the-art advancements have nurtured the use of cable-stayed systems. Some of the advancements to date include:

 New or improved structural analysis methods and application of electronic computers for complex statically indeterminate structures,

- 2) Introduction and use of orthotropic steel decks,
- 3) Experience with previously built bridges containing basic elements of cable-stayed bridges,
- Application of high-strength steels combined with advances in fabrication and erection,
- 5) Evaluation of the behavior of cable-stayed bridges through the use of model-to-prototype studies (6), and
- 6) With this report, the successful instrumentation and experimental testing of an existing cable-stayed bridge.

### 1.2 Experimental Studies by Others

Cable-stayed bridges use high-strength cables to support girders from above instead of bearings and piers from below. The opportunity for long free spans is an obvious advantage of this type of bridge. But the complex combination of cables and beams generally leads to a nonlinear, highly indeterminate structure which is not well defined. Therefore experimental studies have been conducted by other researchers in an attempt to understand this complex behavior.

## Model Studies

Kayser and Binbkhorst used a model to verify erection stresses calculated by the finite element method for the main girder and diaphragm for a nine-span 1055 m bridge (2). The bridge has a 36.4 m roadway width between parapets and is located on Highway 75 over the Waal river near Ewjik in the Netherlands. A tapered box-shaped steel tower located at each end of the 270 m main span was used to stay this and adjacent spans with high-strength cables in a fan shape.

A simplified 1:50 scale model of the main girder and diaphragm was used to simulate erection loads when the bridge was extended 30 m beyond the pier. Three load cases were examined. These were pure moment, moment and shear, and torsion. Strain gages on the transverse cross-sections of the model box were used to determine strains in three directions in the transverse cross-section. The model was studied experimentally and used to confirm the results obtained from the finite element program "KOKER".

The construction sequence for the fan type double plane multi-cable Meiko-Nishi Bridge in Japan was investigated through the use of model studies in the laboratory (3). Models included a 1:55 scale model of an A-shaped tower and a 1:2.5 partial model of six main girder panels and anchorages. The models were tested as follows:

- a) The model A-shaped tower was tested in a wind tunnel. This test was supplemented by field data taken during one phase of the construction when the towers were left in a free standing state for several months. Wind-induced ambient vibrations were examined during this period.
- b) The partial model of six main girder panels was load tested for cable anchorage. This test was conducted to verify how force due to cable tension is transmitted to the girder and what the anchorage behavior exhibited in the elasto-plastic range.

Troitsky and Lazar (7) investigated experimental laboratory techniques with small-scale structural models as possible tools for the analysis and design of cable-stayed bridges. Two models (A and B) were used in the study. The prototype had six lanes of traffic supported by two box girders. The structure was a double-tower single-plane cable-stayed bridge with cables in a harp configuration.

Strain gages were mounted on cables and girder. Dial gages were placed at cable-to-girder intersection points to measure deflections; gages were also arranged to measure rotation and vertical displacements of the girder to allow computation of bending moments, and of axial and shear forces from joint displacements.

Model A was used to develop influence lines and Model B was used to predict nonlinear behavior. The nonlinear behavior was examined by loading the model with 20% of total load and then total load. The results from the second test were divided by the results from the first to obtain non-linear factors which can be applied to influence diaphragms to determine non-linear behavior of a structure.

## Full Scale Static Tests

Previous static tests of cable-stayed bridges were not evident from a computer search of the literature. Thus, the work presented in this report should provide the basis for future studies.

### Full Scale Dynamic Tests

The Tjorn Bridge in Sweden was subjected to dynamic tests one week prior to opening the bridge to traffic (4). This structure is a cable-stayed steel girder bridge with a free span of approximately 366 m.

Vertical acceleration measurements were made at 14 points located inside the main box girder at the outer stiffeners of the bottom flange. Piezoelectric accelerometers were used to measure accelerations.

Three types of tests were performed. These were:

- A dynamic load was produced by driving a 20 ton lorry over a 200 mm high wooden obstacle placed on the bridge deck. Vertical acceleration measurements were recorded over an eight minute period beginning just before the truck began moving.
- b) A free decay test was conducted in which the bridge was preloaded vertically and symmetrically by two wires connected to a free floating barge at the bottom. Hydraulic jacks attached to the wires were installed at the bridge deck and used to preload the wires. Once the wires were preloaded, they were released by

simultaneous explosions which produced free vibrations of the bridge.

c) Forced vibration tests were conducted by using a 2000 ton exciter mounted on the bridge deck.

# 1.3 Captain William Moore Creek Bridge

The Captain William Moore Creek Bridge is located on the highway between Skagway, Alaska and Carcross, Canada. This unusual cable-stayed bridge consists of a 7-inch laminated timber plank deck supported by transverse floor beams spanning between two stiffened ASTM A588 steel box-shaped girders. The girders are supported by column arrangements on their ends and are stayed at approximately mid-span by cable pairs in a doubleplane arrangement. The bridge has an overall length of 300 ft. which is divided over four span lengths of 30-123-127-20 ft. (see Fig. 1.1.)

The two main box-shaped girders were fabricated from ASTM A588 steel plates welded at the corners in 60 ft. lengths. These sections were spliced together at the ends with bolted inside and outside plates. The original overall dimensions of the girders were 2 ft. 6-5/8 in. by 5 ft. 1 in. Each girder is stayed at approximately mid-span by two 3-inch diameter inclined cables constructed of galvanized structural strands which extend through the girders and are anchored to the underside of the bottom flange. The stays are supported above the deck by an inclined H-shaped tower which has two transverse beams near its top. The tower is supported by the canyon's rock wall at the base, extends up to and supports the girders, and continues up approximately 106 ft. with a tapered box-shaped cross section. The ASTM A588 steel tower is inclined forward over the canyon at approximately 15 degrees to the vertical. The back stays all terminate at tripod supports which are mounted downstation of the structure and affixed to the hillside by prestressed rock anchors. The structure was originally designed for AASHTO HS20-44 highway loads in 1974. In 1986, the bridge was strengthened to carry ore trucks weighing approximately



160,000 lb. traveling from the Yukon Territory in Canada to Skagway.

# Instrumentation

It was the objective of this study to instrument and test the William Moore Creek Bridge for statically applied ore truck loads. The instrumentation consisted of,

- a) Strain gages on the girders, at the base of the pylons, and on the upstation abutment column;
- b) A transducer on one cable to test the feasibility of monitoring cable strain;
- c) Thermistors to monitor the temperature distribution through a bridge girder; and
- d) Meteorological devices to monitor the air temperature, solar radiation, and wind speed.

Because of a limited budget, rosettes were not installed on the bridge structure. Thus, strain gages were installed along the principal axis of the members.

Beams and axial members are generally considered plane stress members. Assuming this is valid, the relation between stress and strain for a linear elastic isotropic material is given by (1,5)

$$\sigma_{XX} = \frac{E}{(1-\mu^2)} (\epsilon_{XX} + \mu \epsilon_{yy})$$
(1a)

$$\sigma_{yy} = \frac{E}{(1-\mu^2)} (\mu \epsilon_{xx} + \epsilon_{yy})$$
(1b)

$$\sigma_{ZZ} = 0 \tag{1c}$$

$$\sigma_{ZX} = \sigma_{YZ} = 0 \tag{1d}$$

$$\sigma_{XY} = \frac{E}{2(1+\mu)} \in_{XY}$$
(1e)

All tests conducted in this study provided experimental strains in the x-direction only. Strains in the y and z directions were not measured and Poisson's ratio was not determined. However, if it is assumed that the member thickness is small (ie., that plane stress is valid) and restraints are insignificant in the direction transverse to the gage, the strain in the y-direction can be approximated by

$$\epsilon_{yy} \simeq -\mu \epsilon_{XX} \tag{2}$$

Based on the above assumption, and substituting Eq. 2 into Eq. 1a, the engineer is able to approximate the stress in the x-direction by the following relationship

$$\sigma_{XX} \simeq E \in_{XX}$$
(3)

#### 2. EXECUTIVE SUMMARY

The William Moore Creek Bridge was originally designed in 1974 to carry conventional AASHTO HS20-44 design loads. In 1986 it was strengthened to carry loaded ore trucks moving from the Yukon territory to Skagway, Alaska.

The behavior of the bridge under the influence of these unusual loads was questioned. Therefore, it was the objective of this study to experimentally evaluate the performance of the structure for the heavy ore truck (B-Train) loads.

Thus, an experimental investigation was conducted to evaluate the structural performance of the 300 ft. cable-stayed bridge under static loading conditions. The study consisted of five parts: instrumentation calibration in the laboratory, field instrumentation installation, field testing, data evaluation, and presentation of results.

A two-dimensional, finite-element, analytical comparison of the field results was also conducted and is presented in a separate report. This was Part 2 of the study.

Two types of test loads were applied to the bridge. These were a preweighed Snooper Truck, used as a control vehicle, and 160,000 lb. (approx.) loaded ore trucks. The axle weight distribution for each ore truck was obtained from a weight ticket. Each static test was carried out by positioning the truck's front axle on the bridge deck at a preselected location determined to produce the maximum stress in the box girder/girders.

After a truck was in place, strains, girder temperatures, cable deformation, ambient air temperature, wind speed, and horizontal solar radiation were recorded. When possible, top-of-girder elevations were also recorded for both the unloaded and loaded conditions.

A partial list of results are summarized herein for the reader's convenience. It should be noted that special emphasis was given to the heavy ore truck (B-Train) load conditions and only the stress, strain and displacement results are presented in this section.

### 2.1 Maximum Strains

Strains were recorded on the inside surface of the top and bottom plates of the box girders, on the exterior face of the pylon bases just above the stiffeners, and at the upstation left column support. The study showed that static truck loads were approximately distributed to the girders through floor beams as simply supported members. The maximum strains recorded are presented in Table 2.1, see below.

Item	Location	Strains (Micro-strain)	Stresses (a) (ksi)
(Snooper Truck)			
Left girder	98 ft.	87.7	2.54
Right girder	98 ft.	96.7	2.80
Left Col.	upstation	10.0	0.29
Left pylon	base	41.8	1.21
Right pylon	base	26.9	0.78
(B-Trains)			
Left girder	98 ft.	223.6	6.48
Right girder	98 ft.	207.3	6.01
Left col.	upstation	26.9	0.78
Left pylon	base	133.6	3.87
Right pylon	base	102.9	2.98

Table 2.1 William Moore Creek Bridge Maximum Strains and Stresses

(a) Stresses calculated by  $\sigma = E \in$ 

## 2.2 Girder Deflections

On each day of testing prior to any tests and without traffic, top-ofgirder elevations were recorded for both box girders. During testing and when possible, top-of-girder elevations were recorded for the test load cases. Girder deflections were calculated by determining the elevation differences between the loaded and unloaded state. It was found that the Snooper truck produced a maximum deflection of 0.84 in. and B-Trains produced a maximum deflection of 2.76 in.

Axle weights of the B-Trains did not vary significantly from truck to truck, and for like loading conditions, the experimental data showed excellent repeatability, thus validating the instrumentation technique and testing procedure.

### 3. INSTRUMENTATION

### 3.1. Project Objective

The objective of this project was to investigate, through experimentation, the behavior and load distribution of the Captain William Moore Creek Bridge.

In order to accomplish this objective, two types of loads were investigated: a Snooper truck (control load) placed at specified positions on the bridge, and loaded ore trucks (B-Trains) placed at positions previously determined to be critical to the performance of the box girders. Weight tickets were obtained for each test involving an ore truck.

# 3.2 General Information

Strain gages were installed at critical locations established through a pre-instrumentation analysis performed by the principal investigator and the Alaska DOT&PF Bridge Design Section. An LVDT extensiometer was also installed on the downstation forestay cable, on the left side of the bridge, to examine the feasibility of monitoring cable strains. Thermistors were installed on the exterior face of the right girder at a single station to measure the temperature distribution through the girder.

A summary of the instruments used in this study is provided below:

- a) 25 full-bridge strain gages,
- b) seven thermistors mounted on the side of the box girder at a single station to record girder temperature profile,
- c) an extensiometer using an LVDT to monitor cable strains,

- d) a transit and level to measure girder elevations for deflection monitoring,
- e) a velocity probe to insure that structural vibration was insignificant and that static condition was available for the test, and
- f) meteorological instruments consisting of a pyronometer for horizontal solar radiation, a temperature sensor for ambient air temperature, and an anemometer for wind speed measurements.

Fig. 3.1 illustrates the gage number scheme used, the gages' locations, and installed cable-number-to-gage-number correlation. Wind speed, air temperature, and horizontal solar radiation were also monitored during the testing period. A DOT van was used as a portable laboratory. All data acquisition equipment was located in the van. Twenty-six fiveconductor Belden cables were used to connect the instruments to the monitoring equipment. Appendix A of this report provides the equations, sample calculations, calibration information, and appropriate data used to compile field data.

A Wild T-16 Theodolite transit and a Zeiss Ni2 automatic level were used to determine top girder elevations prior to application of the truck loads and after load applications for selected tests. The elevation difference between the loaded and unloaded states enabled these researchers to determine the box girder deflections. The elevations of the deflected top of girder were determined at five specific points for both the right and left girders using a separate surveying instrument for each side. Looking upstation, the transit was used on the left side of the bridge and the level on the right side.

### 3.3 Instruments/Monitoring Equipment

It is the purpose of this section of the report to provide the reader with a detailed understanding of the instrumentation, calibration, and procedures that were utilized in this study.



(

Figure 3.1 Strain Gage Locations and Numbering Scheme

#### Strain Instrumentation

The strain gages used to instrument the William Moore Creek Bridge were weldable, bonded-foil sensors manufactured by HITEC Products, Inc. The gage circuit is a 350-ohm, full bridge with the active arm attached to a rectangle of stainless steel shim stock, enabling the gage to be directly welded to the bridge steel. Three compensating gages are encapsulated in a proprietary compound and are located within 3 cm of the active gage to reduce noise pick-up and properly compensate for temperature effects on the circuit (Fig. 3.2).

A clamp-on extensiometer was built to assess the feasibility of monitoring static and dynamic strains on the forestay cables. A Linear Variable Displacement Transducer (LVDT) was threaded into a clamp assembly with a ten-inch gage length. The clamp was fitted with a dial indicator with a .0001 inch resolution to check LVDT operation in the field. Thumbscrews were used to facilitate installation and removal of the device.

Power for the strain gages and LVDT (5 volts and bipolar 15 volts) was provided by a custom-built power supply that contained a monolithic linear regulator for the strain gages and a TDK DC to DC converter for the LVDT. The power supply was fitted with barrier strips to serve as terminations for the 26 cables requiring power. A 12-volt storage battery provided input power with no ripple or noise to degrade accuracy.

#### Meteorological Instrumentation

Environmental data was logged by sensors on the down-station side of the bridge. Air temperature, girder temperature profile, wind speed, and the internal temperature of the two data loggers were recorded at the beginning of each test series. Incoming solar radiation was recorded during every scan because of its changeable nature. The following summary provides a brief description of the environmental sensors:

<u>Air Temperature.</u> The ambient air temperature at the bridge site was measured at the down station end using a Type T thermocouple, with special limits of error wire.

<u>Girder Temperature.</u> It has been previously determined by researchers that environmental effects can be significant. Thus, in order to quantify the strains due to the statically applied truck loads, it was necessary to identify girder temperature variation through the crosssection. Therefore eight YSI 3000 ohm thermistors were mounted on magnetic fixtures and placed on the exterior side of the right box girder near the pylon. (The girder is on the right, relative to someone looking upstation.)

<u>Wind Speed.-</u> Cable-stayed bridges are typically flexible and respond more to nominal wind speeds than conventional short span bridges. Thus, the magnitude of the wind speed was monitored at the left downstation end of the bridge with a Met One three-cup anemometer.

<u>Instrument Temperature.</u> Instrument accuracy is affected by surrounding temperatures. In a laboratory where temperatures can be held constant, the instrument temperature may not be a significant factor influencing experimental accuracy. However, for field instrumentation where temperature varies as a function of time it is important to identify this parameter. Thus, instrument temperatures were monitored by the use of a solid state transducer mounted on the data logger circuit board.

<u>Incoming Solar.</u> The influence of solar radiation on the bridge structure was monitored during the test series. A Star pyranometer was mounted horizontally at the right downstation end to record global direct and diffuse radiation with a 0.3 to 3 micron response.

# Monitoring Equipment

The data-acquisition system was assembled using two Hewlett-Packard 3421A data loggers controlled by an HP-71 handheld computer. Peripheral



Fig. 3.2 Strain Gage Wiring Diagram

devices included a printer for hard copy and a 3.5" disk drive for the program and data storage. This system was designed to use a 12-volt DC battery for power, thereby eliminating the need for a portable generator. This feature has field recording advantages over other dataacquisition systems that rely on AC electricity. These advantages include: a) portable generators are not needed in the field; and b) sources of electric and acoustic noise are eliminated. Figs. 3.3 and 3.4 show the power supply and the data-acquisition system, respectively, were used for this project.

The HP3421A can scan up to 30 differential channels, measuring DC and AC volts, resistance, temperature and frequency. One HP3421A (Instrument 1) was wired to read the power supply, strain gage outputs, LVDT, pyranometer, anemometer and air temperature. The other HP3421A (Instrument 2) read the eight thermistors for the girder temperature profile. Since the accuracy of the data logger is dependent on temperature, the internal reference temperatures were logged at the beginning of each test series.

The HP-71 is a calculator-sized, battery-operated, BASIC language computer. With the help of a data-acquisition ROM, a menu-driven program was written to automate the collection, linearization, printing and storage of data. The use of a computer to control the instrumentation greatly increased the speed and accuracy in collecting data. No manual adjustments were necessary and the hard copy output enabled the researchers to see test results in the field (Fig. 3.4).

Data storage and hard copy were provided by a HP9114A disk drive and a HP2225B ink jet printer, respectively. Both units are powered by rechargeable batteries and can receive a trickle charge from the data logger. A 3.5-inch 640k disk stored all data points except temperatures in raw form (i.e. voltages) to facilitate data manipulation at the office. During setup of the instrumentation, the printer provided a graphics presentation of strain vs. time for static and dynamic



recordings. This feature was extremely valuable in troubleshooting. Appendices B and C of this report provide reformatted copies of the field data as it was printed out on site.

Truck static loads were obtained by moving the truck to the appropriate load position. Before the test was carried out, structural vibrations were allowed to dampen. This was accomplished by using a Bently-Nevada velocity seismoprobe with a visual needle read-out between data scans to insure that vibrations of the bridge structure reached a minimum. Since even a small amount of wind could cause perceptible movements, it was decided that a deck velocity of .1 inches per second would represent the maximum acceptable noise level. Thus, strain gage readings were postponed until this value was reached.

# 3.4 Laboratory Preparation and Calibration

Belden 8723 cable was chosen both for its electrical characteristics and because the weldable strain gage manufacturer used it for lead wire. The 22 gage, individually shielded, two-pair cable is suited for both static and dynamic measurements due to its low unit capacitance and low dielectric absorption.

#### Strain Gages

After the gage positions were located on the bridge plan, extension cables were cut to length, numbered with waterproof tape, and soldered to Lemo waterproof connectors. Under controlled temperature conditions in the laboratory, the loop resistance of each pair of wires was measured and recorded to account for desensitization effect. As strain gages are resistive devices, lead wire desensitization becomes significant when the magnitude of the lead wire resistance exceeds 0.1% of the nominal gage resistance. Some of the longer cables (450') had resistances over 13 ohms (3-4%). All calibration measurements were conducted in a scientific manner. Thus, the same monitoring equipment used in the laboratory (such as the data logger) was used in the field.



#### EQUIPMENT LIST FOR COMPUTER/D.A. SYSTEM

HP-718

Math ROM D.A. ROM HPIL ROM & Interface 2 ea. 4 KB Memory Modulas

2 ea. HP3421A Data Loggers

HP-9114A Disk Drive

HP-2225B Thinkjet Printer

Backup Printer & Mass Memory

HP-2225B Thinkjet Printer HP-82163 Cassette Drive

Figure 3.4 Data Acquisition System



Fig. 3.5 Operator Interface for Data Collection.

Once all the connectors were installed on the cables and sensors, the waterproof connectors were tested in a 24 hour soak to confirm o-ring integrity after assembly.

### Extensiometer

The forestay cable extensiometer was not calibrated prior to its usage in the field. When clamped to a cable, the linearized LVDT output was found to agree closely with the .0001" resolution dial indicator. Readings taken during testing seemed somewhat low, but it was not until the analytical model was being developed that the field data from the extensiometer came into question. The data collected from the extensiometer indicated cable strains an order of magnitude lower than expected.

After returning from the field and at the time the extensiometer data were evaluated, a complete laboratory calibration of the extensiometer was conducted. First the LVDT was removed from the clamp assembly and installed in a calibration fixture built by the LVDT manufacturer. Four twenty-point calibration runs were completed. These runs were:

- 1) Compression to tension at full scale;
- 2) Tension to compression at full scale;
- 3) Compression to tension at  $1\50$  full scale; and
- 4) Tension to compression at  $1 \ge 0$  full scale.

Each data point was the average of thirty readings taken over a 45 second time span. The results of a linear curve fit showed that the LVDT data was within factory specifications.

The next step in the laboratory calibration procedure involved simulation of a tensioned cable. Thus, the extensiometer apparatus (fixture, LVDT) was mounted to a 3 ft. section of pipe and installed in the University of Alaska Civil Engineering MTS load frame under laboratory conditions. The extensiometer was then connected to a power supply and data logger to monitor pipe displacement over a ten-inch gage length. The MTS load frame consisted of a 50,000 lb. load cell, a servo-hydraulic control system and a set of grips. This 3-foot section of pipe was installed in the grips to simulate the forestay cable and the extensiometer attached. An MTS calibrated clip-on extensiometer was fastened to the pipe to accurately record the tensile strain.

Eight load-unload calibration tests were made with a maximum load of 13,610 lb at 460 micro-strains. The results of these tests showed that the slope of the calibration curve changed depending on whether the sample was being loaded or unloaded. Although the average slope of all eight tests was approximately 10% of true strain, it was determined that the calibrated percent error was too great, and the field data would not be accurate enough to be relied upon. Therefore, the field data recorded for the cable elongations over a ten-inch gage length (strains) were not used to model the forestay behavior.

# Thermistors

The girder temperature profile was measured by thermistors mounted in two hardwood fixtures magnetically clamped to the exterior side of the steel box girder. The YSI 44030 thermistors were chosen for high resolution with the monitoring equipment, +/- .1°C interchangeability, and availability.

During assembly, possible thermal and mechanical stresses were reduced by first soldering the relatively heavy 8723 cable to a miniature printed circuit board. Next, the thermistor's leads were mechanically fastened to the circuit board and a heat sink was clamped just below the thermistor body. The free end of the cable was temporarily connected to the data logger to monitor resistance and insure that the maximum working temperature of the thermistor was not exceeded during soldering. After soldering, the assembly was coated with Dow 3140 RTV, a noncorrosive silicone rubber. A second coat was applied 24 hours later. When the cure was complete, heat shrink tubing was installed over the thermistor while observing its temperature rise. At this point, two coats of Scotchguard(TM) were added to finish the encapsulation.

Before final assembly of the magnetic fixtures, the eight thermistors were checked in an ice bath for accuracy. All were within the manufacturer's specifications. The thermistors with leads attached were divided into two groups and each group was soldered to an extension cable. It was at this point that thermistor number eight was inadvertently shorted out. This was not discovered until field testing was underway. Data records show a temperature of over 200°C on thermistor eight because of this short.

# 3.5 Field Installation

#### Strain Gages

The weldable gages were installed during the first three days of field work. Gages for the two main girders were mounted inside the structure as requested by ADOT Bridge Design so that the appearance of the bridge would not be degraded and the gages would not be damaged by winter snow removal efforts. At each location along the inside of the box girders where gages were to be installed, one gage was mounted on the ceiling and one was mounted on the floor. Lack of ventilation had produced a significant amount of rust in the box. Thus, large amounts of rust and scale had to be removed by electric grinders to prepare the surface for welding.

Once a smooth surface was obtained, a carpenter's square was used to scribe a reference line on the steel to insure proper alignment. The mounting area was cleaned and the gage assembly tacked in place by stainless steel tabs on the transition module. The gage was then placed in position, tacked and pattern welded in a manner that minimizes residual strain. Silicone RTV sealant was applied over the active part of the gage to inhibit corrosion and provide some mechanical protection. Floor gages were given additional protection with a short piece of galvanized "C" channel. Extension cables were then connected to the gages and these cables were passed through the box girder and brought out at the downstation end near the data logger location.

### **Remaining Instrumentation**

The extensiometer was installed with integral thumbscrew clamps to facilitate removal at the close of each day. The two thermistor assemblies were placed on the right girder by the pylon. A ten-foot length of perforated steel tubing (PST) was nailed to the left guard rail approximately 50 feet south of the end of the bridge. A 3-cup anemometer was mounted to the top of this tubing. The air temperature thermocouple and pyranometer were located on the right side approximately 150 feet south of the end of the bridge.

All instrumentation cables were terminated with connectors to facilitate removal.

# 3.6 Field Program and Calibration

A BASIC program was written to automate the measurement, linearization, hard copy and storage of raw data from the various transducers. The program was written in two parts: a mainline program with a linear flow and five subprograms to perform specific tasks.

The mainline program set up the HPIL interface, allocated memory for variables and constants, and provided a user interface with two menus. Before the bridge was loaded, the operator of the data-acquisition system obtained initial readings of the sensors and printed the results and stored the data on disk. This was accomplished by pushing four user-defined keys, which logged temperatures, power supply voltage, 25 strain gage voltages, the LVDT voltage, and the voltages for the meteorological sensors. At this point the bridge was available for loading.

### Static Tests

After a truck was positioned, i.e. when the bridge was loaded and the vibration was damped out, voltage data for each sensor was logged by pressing a single key. Results were available on the spot with one page of raw and linearized data. When the bridge was unloaded again, another keystroke would close the data file and put the system to sleep to conserve power.

### Dynamic Tests

Although the stated objectives of the project did not call for a study of the bridge dynamics, the researchers conducted three tests with moving trucks: one for the Snooper, and two for B-Trains. These limited tests were performed to gain some insight into the cable dynamics of the bridge.

The data acquisition used for this study had a limited memory and sampling rate. Thus, only the voltages for the extensiometer were monitored during these three tests. However, because of questions relating to the accuracy of the extensiometer as stated above, these tests were inconclusive. The LVDT was used as the signal source in these tests.

The BASIC program dynamic routine was written to select an input channel (LVDT), dimension an array for 256 samples and configure the data logger for a maximum reading rate of 15 samples per second. The data was stored on disk in raw form for later analysis.

Prior to actual testing, system and calibration checks were carried out. The extensiometer was monitored with the data logger and the linearized data compared well with the dial indicator mounted adjacent to the LVDT. Because the resolution and accuracy of the LVDT was two orders of magnitude better than the mechanical dial, calibration was postponed until return to the laboratory.
### General Comments

Using unbalanced bridge measurement techniques and compensating for leadwire and temperature effects in software kept the strain gage readings from requiring manual calibration. Power supply drift was in the millivolt range and was accounted for by reading the 5 volt nominal supply every time the gages were scanned. The bridge circuit is essentially a linear device at low strain values(<1000) and the combination of ratiometric techniques and specified low drift of the data logger results in stable, repeatable measurements. Strain resolution was .4 micro-strains and system accuracy was limited by the gage factor of the strain gages,  $+\-1\%$ . Repeated tests were made under no-load conditions and the residual noise was on the order of one or two micro-strains.

# 4. FIELD STUDY

### 4.1 Test Procedure

## General Information

The William Moore Creek Bridge superstructure consists of a timber deck supported by floor beams connected to two longitudinal box girders. The box girders are supported by end bents, a pylon, cables, and a brace near the up station end. Prior to designing the instrumentation program, an analysis was conducted to determine maximum girder strain locations and front axle positions for both the Snooper truck and Btrains.

The extent of structural symmetry and the manner in which loads are distributed to girders were studied by putting control loads (Snooper truck) at different places on the bridge deck and recording the resulting experimental data. Based on the analysis, predetermined load positions were laid out on the deck of the bridge with fluorescent paint prior to testing. Fig. 4.1 shows the locations of these positions.

Each test was designed to provide static results for a known truck load at a given position on the bridge. This was accomplished by referencing the type of truck, position across the deck, location of the front axle along the girder, and direction of movement.

The structure was loaded either in a lane or on the bridge center line. The terms left and right were used to reference the truck position across the roadway. Hereafter in this report, all references to left and right mean when looking upstation.

# Equipment Initialization and Calibration

At the beginning of a day's test, with no traffic on the bridge, elevations of the top of the girders were established using a Theodolite on the left side of the bridge and a Zeiss level on the right side. The



Fig. 4.1 Bridge Frame and Critical Load Positions.

end of each girder was supported at the upstation abutment and this was used to establish the height of the survey instrument.

Girder elevation measurements with no traffic on the bridge provided zero live load baseline elevations for the two girders. At the end of the day's test, the height of instrument was again measured and when time permitted, top of girder elevations were measured with no traffic on the structure. This procedure provided for vertical elevation control.

Before each test series and while no traffic was on the bridge, an initial no-load voltage reading was taken for each strain gage and the LVDT. This procedure was used for the purpose of establishing a zero reading for each instrument prior to testing. These initial readings reduce residual strain in the gages remaining from the previous test, traffic, environmental change, and other possible causes of zero drift experienced by gages between tests. The air temperature, wind speed, girder temperatures, instrument temperatures, and horizontal solar radiation readings were also taken immediately before positioning the truck on the bridge.

# **General Test Procedure**

Once the instruments were initialized for the no traffic condition, a truck was positioned with the front axle centered over the appropriate floor beam. The load was referenced to the floor beam position number. For example, load position #0 corresponded to locating the front axle over the first floor beam (floor beam #0) at the downstation end of the bridge. Floor beams were numbered sequentially upstation to position #24 (the last beam) at the up station end of the bridge (Fig. 4.2).

Each test series was given a file name and the file name described the type of test, lane position, direction of the truck, and type of truck used for the test. The details of the file name description may be found in Appendices B AND C.



BRIDGE DECK PLAN VIEW



BRIDGE FRAME PLAN VIEW

Fig. 4.2 Bridge Frame and Floor Beam Positions

A typical static test series involved the following procedure. Depending on the type of test, a truck was moved either to the center of the left lane, center of the right lane, bridge center line, or the visible traffic wheel path of the left lane. With the truck positioned, and after vibration had dampened, the time and voltages for each strain gage, LVDT, thermistor, and horizontal solar radiation were recorded.

When possible, girder deflections were obtained by recording top of girder elevations at positions #4, 9, and 14 while the truck was parked with the front axle over the appropriate floor beam. Later in the office, the deflected top-of-girder elevations were compared with previously determined no-load elevations to evaluate the actual girder deflection.

# 4.2 Snooper Truck Tests

A Snooper truck type highway load was used for the control tests. The snooper truck was a standard flat-bed truck with a man basket connected to a maneuverable, folding hydraulic boom mounted on the bed. Fig. 4.3 shows the Snooper truck dimensions and axle loads used to load the bridge. The truck was selected to assist with instrumentation installation.

# Test Series #1

The first series of control tests were performed with the truck in the center of the left lane and this test series was given the filename SLDOSO1. The first test began with the truck facing downstation and the front axle centered over the last floor beam (position #24) at the upstation end. Electronic sensor data were recorded for this static load and the truck was then moved down station to the next floor beam (position #23) and the procedure was repeated. A total of 25 static tests were recorded in this manner. No girder elevations were measured for this test series.



SIDE VIEW



TOP VIEW



Fig. 4.3. Snooper Truck.

Because personnel safety was of paramount importance to these researchers, handheld transceivers (CB radios) were used to maintain traffic control and communicate during testing. Once this test series was completed, the data were examined for integrity. An examination of the data showed that the radios had introduced electronic data spikes and the amount of data recorded was inconsistent with the file names. Therefore, the testing procedure was modified to establish radio silence during electronic recording. Due to record-keeping difficulties and the electronic spikes in the data, this series of tests was not considered valid.

# Subsequent Series of Tests

In the second series of tests (SLDOSO2), the Snooper truck again started in the left lane facing downstation at the upstation end and progressed downstation. The third series of tests (SLRUSO3) started in the center of the right lane at the downstation end, position #0, and progressed backwards upstation. Both of these series of tests were for all 25 positions but no deflection measurements were taken.

Two more series of tests were made with the Snooper truck. The first, test series 4 (SCDOSO4), began with the truck centered on the center line of the bridge facing downstation with the front axle centered on the last upstation floor beam (position #24). The truck was then moved downstation. In this series, all 25 load positions were tested. Deflection measurements were taken only with the truck at positions #14, 9, and 4. The second, test series 5 (field test SCDOSO5) was conducted with the Snooper truck positioned in the center of the right lane, facing downstation, with the front axle at position #4. The truck was then moved backward to positions #9 and #14, moved off the bridge over to the center of the left lane, and proceeded downstation. Data was recorded for this case when the truck was positioned at #14, 9, and 4. Deflection measurements were made for all truck positions of the latter test series.

### Test Summary

Counting the first test series, data were recorded for a total of 106 load positions on the first day of testing. There were 53 load positions with the truck in the left lane, 28 with the truck in the right lane, and 25 with the truck on the centerline. Girder elevations were recorded for 9 of the 106 load positions. Table 4.1 summarizes these static load tests.

Test #	Front Axle Pos.	Truck Locations	Movement	Measured Deflection Locations
SLD0S01	24-0	Center of 1t lane	downstation	none
SLD0S02	24-0	Center of 1t lane	downstation	none
SLRUS03	0-24	Center of rt lane	upstation	none
SCDOS04	24-0	Center of Bridge	downstation	14.9.4
SCD0S05	4.9.14	Center of rt lane	upstation	4,9,14
SCDOS05	14,9,4	Center of 1t lane	downstation	14,9,4

Table 4.1	Snooper	Truck	Test	Seri	es		
	(Left &	Right	refer	' to	looking	upstation	)

# 4.3 B-Train Tests

On the following day, testing resumed using ore trucks (B-Trains). The B-Trains were semi tractors towing two lowboy trailers containing a single dual axle and two sets of tandems. The B-Trains carried four pots mounted on the lowboy trailers. These trucks carried ore from the Yukon Territory in Canada to Skagway, Alaska. The average gross weight of these trains was approximately 160,000 lbs. Fig. 4.4 is a schematic of the B-Train showing the axle configuration and dimensions. Axle weights for the B-Trains used in the tests were obtained from a nearby weigh station in the Yukon Territory.

The same truck-positioning nomenclature and pattern used for the Snooper was utilized for the B-Train tests with the exception that these trucks were only placed at positions #4, 9, and 14. These positions were previously established with finite element analysis by both the principal investigator and the Alaska Department of Transportation





TOP VIEW



Fig. 4.4 Ore Truck Configuration (B-Train)

Division of Bridge Design as inducing the maximum strains in the box girders.

The first two B-Train tests were conducted with the truck in the left lane and positioned in the observable wheel path. For these tests the truck's transverse location with respect to the left guardrail was recorded for each position. The tests began with the front axle situated at position #14, facing downstation. No deflection measurements were made for the first of these two tests (field test #SLDOB06), but deflection measurements were taken during the second test for all three static locations (field test #SLDOB08).

The final two tests were for the B-Train centered on the center line of the bridge (field test #SCDOB10), and the B-Train in the center of the right lane (field test #SRDOB11). In these tests, the truck was again facing downstation, and the first test began with the front axle at position #14. Deflection data was recorded for only the first of these two tests.

A total of 12 B-Train load positions were tested. Six of these tests were with the truck in the observable wheel path of the left lane, three were with the truck in the right lane, and three loadings were with the truck on the center line of the bridge. Appendices B and C of this report provide the field test results for the Snooper truck and the B-Train tests respectively. Table 4.2 summarizes the static load tests that were carried out for the B-Trains.

Test #	Front Axle Pos.	Truck Locations	Movement	Measured Deflection Locations
SLDOB06	4,9,14	Left lane wheel path	downstation	none
SLDOB08	4,9,14	Left lane wheel path	downstation	14,9,4
SCDOB10	4,9,14	Center of Bridge	downstation	14,9,4
SRD0B11	14,9,4	Center of Rt lane	downstation	none

Table 4.2 B-Train Tests (Left & Right refer to looking upstation)

# 5. EXPERIMENTAL RESULTS

The William Moore Creek Bridge field study was conducted for two types of trucks: a Snooper truck, which simulated a conventional AASHTO H2O-44 highway load, and loaded B-Trains. The experimental results are presented below for consideration.

# 5.1 Snooper Truck Loads

During the third week of August in 1988, the William Moore Creek Bridge near Skagway, Alaska was instrumented and field tested. Part of the tests consisted of subjecting the bridge to static loads using a Snooper truck. These tests incorporated 106 load conditions. There were 53 cases with the truck in the left lane, 28 with the truck in the right lane and 25 with the truck on the bridge centerline. The first 25 tests in the left lane were not valid. All tests are described as if the reader were looking upstation toward Whitehorse.

The test load conditions were located at predetermined positions on the bridge deck to evaluate the performance of the structure. The truck used in these studies had a front axle weight of 8.18 kips and duals with axle weights of 15.78 kips giving a total truck weight of 39.74 kips.

# Strains and Stresses

The strains in the girders, pylon bases, and the upstation column were examined for each test case and the maximum strains for each summarized and located. The results of this study enabled the researchers to identify the experimental maximum strains recorded for these tests. Based on this procedure, the maximum strain results for these tests are presented below in Table 5.1.

Truck Location	Item (a)	Strain (micro-in/in)	Stress(b) (ksi)
-Left lane			
	Girder (98')	87.7	2.54
	Left column upstation end	10.0	0.29
	Pylon base (left pylon)	41.8	1.21
-Center line			
	Girder (33.25′)	51.7	1.50
	Left column upstation end	6.0	0.17
	Pylon base (right pylon)	31.6	0.92
-Right lane			
<b>.</b>	Girder (98')	96.7	2.80
	Left column upstation end	6.6	0.19
	Pylon base (right pylon)	26.9	0.78
a) Distances ald	ong bridge incline from downsta	tion end	

Table 5.1 Maximum Strains and Stresses for Snooper Truck Loads

b) Stresses were calculated by  $\sigma = E \in$ 

# Girder Deflections

The maximum deflection measured at the top of the girder was 0.84 in. for eccentric loading conditions and 0.48 in. for symmetric loading conditions.

# **Other Findings**

The experimental results clearly showed that the bridge acted symmetrically with respect to its longitudinal center line. The Summary section of this report includes further discussion on this phenomenon.

#### 5.2 **B-Train Loads**

It was the objective of this study to obtain experimental results (member strains and girder deflections) for static loads imposed by the loaded B-Train trucks moving from Whitehorse in the Yukon Territory to Skagway, Alaska. Because of time limitations, only four loaded ore trucks were tested in this study. These trucks were located at 12 positions and data were recorded for these positions. Prior to

recording data, a weight ticket for each truck was obtained from the driver and this weight was recorded. The results of these tests are summarized in the next subsection.

# Strains and Stresses

Like the Snooper truck tests, strains were recorded for both girders, both pylon bases, and the axial strain in the upstation left column at the bridge abutment. The strain results are shown in Table 5.2.

Truck Location	Truck wt. (kips)	Item (a)	Strain (micro-in/in)	Stress(b) (ksi)
-Left lane	155.07	Girder (98') Left column Pylon base (left)	223.65 26.03 133.57	6.48 0.75 3.87
-Center line	157.379	Girder (33.25') Left column Pylon base (right	168.95 21.72 ) 98.85	4.90 0.63 2.87
-Right lane	157.556	Girder (98') Left column Pylon base (right	207.26 17.05 ) 102.92	6.01 1.49 2.98

Table 5.2 Maximum Strains and Stresses for B-Trains

a) Distances along bridge incline from downstation end

b) Stresses were calculated by  $\sigma = E \in$ 

# **Girder Deflections**

The difference between the girder elevations when subjected to the B-Train static loads and the unloaded girder elevations was calculated. The maximum deflection at the top of girder was found to be 2.76 in. for eccentric loads (truck in the driving lane) and 2.16 in. for symmetric loading (truck on the bridge center line).

# **Other Findings**

For like loading conditions, excellent repeatability in recorded values was observed, thus endorsing the instrumentation technique and testing procedure.

B-Train axle weights did not vary significantly from truck to truck.

#### 6. SUMMARY

It is the purpose of this chapter to summarize the experimental results of the field static load tests for the William Moore Creek Bridge. Two types of trucks were used to load the bridge: a Snooper truck with a weight of 39.74 kips and loaded B-Train ore trucks weighing between 155 and 158 kips.

# 6.1 Snooper Truck

The maximum strains measured in the field due to Snooper truck static loads are presented in Table 6.1.

<u>,</u>		Strain(micro-in/in)			
Load Condition	Type of Member	Tension	Compression		
Symmetrical:	Along the girders Pylon base Upstation column (left side)	53.1 15.0 5.1	51.6 31.6 6.0		
Asymmetrical:	Along the girders Pylon base Upstation column (left side)	93.4 41.7 4.3	96.6 24.3 10.0		

Table 6.1 Maximum Strains Produced by the Snooper Truck

# 6.2 B-Trains

The maximum strains measured in the field for the B-Train load tests are presented in Table 6.2.

		Strain(micro-in/in)			
Load Condition	Type of Member	Tension	Compression		
Symmetrical:	Along the girders	162.9	168.9		
	Pylon base	39.5	98.9		
	Upstation column (left side)	21.7			
Asymmetrical:	Along the girders	205.0	223.6		
-	Pylon base	53.7	133.6		
	Upstation column (left side)	26.0			

#### Table 6.2 Maximum Strains Produced by B-Trains

Over the two-day testing period a total of 118 loading conditions were examined. Tests consisted of eccentric loadings (truck being placed in the left and right lanes), and symmetric loadings (truck placed on the bridge center line). The structure reacted according to the loading circumstance. Based on the test results, it was concluded that the structure experienced a symmetrical behavior for the symmetric loadings applied.

Under symmetrical loads, the strains measured in both girders at gages located directly opposite each other were approximately the same in magnitude and sign (tension or compression). It was further concluded that asymmetric loads induced larger strains in the girder nearest the load, and lower strains in the girder farthest from the load than was measured in either girder under a symmetric loading condition. This observation was made for both asymmetric loading circumstances (truck placed in the right or left lane).

The magnitude and sign of the strains measured in the girder nearest to or farthest from the load, for the eccentric loading conditions, were approximately the same. Tables 6.3 through 6.6 present the maximum measured strains for each gage over the testing period for both the Snooper and B-train tests, under either a symmetric or asymmetric loading condition.

		Top of	Girder	Bottom of Girder				
	Left	eft Girder Right Girder Left Girder		Girder	Right Girder			
Location (ft)	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp
33.25	51.6	3.8	51.1	3.6	0.3	46.9	0.3	48.9
98.00	18.1	46.2	19.6	44.1	50.7	19.0	53.1	20.3
146.00	12.6	18.9	16.7	18.6	10.4	11.7	8.4	13.1
206.00	15.7	46.1	13.0	51.6	42.7	10.2	38.3	11.2
278.00	35.2	1.7	36,2	3.2	2.2	44.0	1.1	45.4

Table 6.3 Strain Extremes for Symmetric Snooper Truck Loads (All Strains in Micro-Strain)

Note: 1) Blank entries imply girder did not go into compression/ tension at the gage location for the test series.

2) Gage locations are measured from downstation end of bridge, see Ch 4.

		Top of	Girder		Bot. of Girder			
0	Left	Girder	Right	Girder	Left	Girder	Right Girder	
Location (ft)	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.
33.25	60.3	10.3	58.0	8.3	2.3	63.1	1.9	58.1
98.00	6.5	87.4	6.7	96.6	83.2	23.5	93.4	20.0
146.00	6.4	42.3	4.0	48.9	27.8	16.3	32.6	11.6
206.00	5.2	71.0	6.1	78.9	60.8	10.4	57.8	7.2
278.00	45.9	3.4	48.1	6.4	0.1	62.0	0.3	65.8

Table 6.4 Strain Extremes for Asymmetric Snooper Truck Loads (All Strains in Micro-Strain)

Note: 1) Blank entries imply girder did not go into compression/tension at the gage location for the test series.
2) Gage locations are measured from downstation end of bridge, see Ch 4.

T	Top of Girder Bot. of Girder					r			
6.000	Left	Left Girder Right Girder Left G		Left Girder Right Girder		Girder	Right Girder		
Location (ft)	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	
33.25	153.5		152.2			157.2		158.0	
98.00		168.9		164.3	145.6	66.8	162.9	74.3	
146.00		68.9		72.1	33.6	30.8	33.4	30.9	
206.00	13.7	144.0	15.4	165.4	115.8	17.2	111.1	15.4	
278.00	116.6		126.9			158.1	<u></u>	171.4	

Table 6.5	Strain Extremes	for Symmetric	B-Train	Truck Loads
	(All Strains in	Micro-Strain)		

Note: 1) Blank entries imply girder did not go into compression/tension at the gage location for the test series.
2) Gage locations are measured from downstation end of bridge, see Ch 4.

		Top of	Girder	B	ottom of	Girder		
	Left	Left Girder   Right Girder   Left Girder		Right	Right Girder			
Location (ft)	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.	Max. Tens.	Max. Comp.
33.25	204.2	4.4	191.4	4.4		208.4		197.5
98.00		223.6		207.3	195.5	81.6	205.0	85.4
146.00		93.7		93.2	50.7	38.4	47.3	34.6
206.00	17.4	189.0	19.7	204.0	150.7	21.8	137.9	18.5
278.00	157.3		159.5	<b>_</b>		210.7		215.2

.

Table 6.6 Strain Extremes for Asymmetric B-Train Truck Loads (All Strains in Micro-Strain)

Note: 1) Blank entries imply girder did not go into compression/tension at the gage location for the test series.
2) Gage locations are measured from downstation end of bridge,

See Ch 4.

### 7. CONCLUSIONS

An investigation of the Captain William Moore Creek Bridge was conducted to examine the load distribution and structural behavior under static load conditions. Two types of loads were experimentally tested: a Snooper truck which was used as a control load, and 160,000 lb. ore trucks (B-Trains). These test vehicles were statically positioned on the bridge at locations previously determined to be critical to the performance of the bridge girders.

The bridge was instrumented with strain gages, thermistors, an anemometer, a LVDT, and a horizontal all-wave radiometer. The strain gages were installed at locations determined critical by a preinstrumentation mathematical analysis, thermistors were installed at a single location on one girder to monitor the temperature profile of the girder, and the LVDT was installed on one of the forestay cables to determine the feasibility of measuring cable strains. Wind speed, horizontal solar radiation, and ambient air temperature were also recorded during the testing period. Deflection measurements of the tops of both girders were made for selected tests using surveying instruments.

Five test series were conducted using the Snooper truck. The first test was with the truck in the left lane facing down station. Procedural flaws occurred during this test and therefore it was not considered valid. The remaining four tests were executed properly and used to study bridge behavior.

Four series of static tests were performed for B-Trains. Each of these test series involved three load positions (4,9,14). The truck was placed in the observable wheel path of the left lane, centered on the bridge center line, and in the center of the right lane. Deflection measurements were taken for the B-Train centered on the center line and in the observable wheel path of the left lane.

The maximum state of stress was 6.48 ksi due to the B-train load tested. The stress occurred in the left girder at 98 ft from the downstation end. The maximum measured girder deflection due to the B-train load was 2.76 inches. The maximum stress due to the Snooper truck load was 2.80 ksi. This stress occurred in the right girder 98 ft from the downstation end. The maximum measured girder deflection due to the Snooper truck load was 1.84 inches.

### 8. **REFERENCES**

- 1) Dally, J.W., Riley, W.F., "Experimental Stress Analysis", 2nd Edition, McGraw-Hill, Inc., New York, 1978.
- 2) Kayser, T.H., Binkorst, J., "Computer Calculations of a Complex Steel Bridge Verified by Model Investigations (Applied at the Steel Bridge Spanning the River Waal Near Ewijk)", Ministry of Transport, Netherlands, Rijkswaterstaat The Hague, Netherlands, No. 23, 1975.
- 3) Koizumi, M., et. al, "Construction of Meiko-Nishi Bridge", Nippon Kokan Technical Report, Report No. 45, Dec. 1985, pp. 22-12.
- Ohleson, Sven, "Dynamic Properties of the Tjorn Bridge Experimental Program", Chalmers University of Technology, Sweden Institute of Transportation, Onsternik, Staal-och Traebvggnad, Report No. 81:3, Nov., 1981, 36 pages.
- 5) Roark,R.J., "Formulas for Stress and Strain", Fourth Edition, McGraw-Hill, Inc., New York, 1965.
- Troitsky, M.S., "Cable-Stayed Bridges, An Approach To Modern Bridge Design", Van Nostrand Reinhold Company, New York, 1988.
- 7) Troitsky, M.S., Lazar, B.E., "Model Analysis and Design of Cable-Stayed Bridges", Inst of Civil Engineers, Proceedings, London, England, Proc. Vol 48, Paper 17375, March, 1971, pp. 439-464.

APPENDIX A

# FIELD DATA REDUCTION INFORMATION

### A.1 General Comments

This section is intended to provide the reader with an understanding of the data recorded and how the data were processed to obtain engineering units. This is accomplished by providing the equations used for the reduction of raw data recorded in the field. This appendix includes sample calculations for each parameter measured. Specific data records are available for review in Appendix B.

# A.2 Conversion of Strain Gage Voltages to Strain

The experimental results from the static load tests for the William Moore Creek Bridge were obtained using a five volt DC power supply and data logger. Strain gage response to a given load was recorded in volts on a floppy disk (see Appendix B). Air temperature and girder temperatures measured with thermistors were recorded in degrees centigrade.

All strain gages used at the bridge were environmentally sealed weldable strain gages supplied by HITEC Products, Inc. (8), with a nominal resistance of 350 ohms. Each strain gage installation circuit incorporated three completion resistors in a transition module and an active gage (resistor) at the mounting. The Wheatstone Bridge circuit, power supply and monitoring equipment are shown in Figure A.1. An accurate conversion between voltage and strain must account for input voltage, gage resistance, cable resistance, etc.

### **Gage Factor**

A given strain gage has a relationship between strain and resistance at a given temperature which is called the gage factor. The HITEC gages supplied had a gage factor of 2.05 at a calibration temperature of 24°C. The manufacturing data showed that the resistance changed .7% per 100°C. Thus, the gage factor for the weldable gages is given by

$$GF = 2.05 \left[1 + \frac{.007(T_m - 24)}{100}\right]$$
(A.1)

in which  $T_m$  is the temperature in degrees centigrade of the member in contact with the strain gage. At the bridge site, thermistors were used to monitor the temperature profile at the exterior surface of the right box girder near the downstation end. The average of these temperatures was used for the member temperature in Eq. A.1.

# **Circuit Resistance**

The resistance of the Wheatstone Bridge circuit is affected by wire size used for cables, cable length, air temperature and strain gage resistance. The cables used were Belden 8273 5 conductor 22 gage individually shielded supplied by Belden Wire and Cable (1). The sensors were connected to the cables with Lemo connectors: Part #FE 2.305 NYLU/4.2 male plugs, and Part #RCE 2.305 NYLU/4.2 female receptacle provided by Lemo USA, Inc. (4). In order to properly account for the effects of various cable lengths and changes in the environment, the following laboratory calibration procedure was used.

- Each 5 conductor Belden cable was cut for length, marked with a code member which identified the cable placement location, and fitted with a connector;
- After the above procedure was completed, the wire resistance of each cable was measured at a temperature of 18°C and recorded, see Table A.1.

The total resistance of the appropriate cable connecting a gage is given by

$$R_1 = R_{cal} [1 + 0.00434 (T_a - T_{cal})]$$
 (A.2)

in which  $R_{cal}$  is the wire resistance obtained by the laboratory calibration tests, see Table A.1.  $T_a$  is the air temperature in degrees

centigrade at time of testing and  $T_{Cal}$  is the temperature used to calibrate the cables which was 18°C. The term .00434 is the temperature coefficient of seven-strand tined copper wire (2).

The input voltage at the gage module is less than the voltage from the power supply due to desensitization of the gage circuit and is given by

$$V_{in} = \frac{V(R_g)}{(R_g + R_1)}$$
 (A.3)

in which V is the power supply voltage,  $R_g$  is the gage resistance in ohms and  $R_1$  is given by Eq. A.2.

# **Gage Strain**

The use of strain gages is based on the concept that any applied load or condition will change the gage resistance (voltage) from a beginning condition. The resulting change in voltage or voltage ratio is given by

$$Vr = (\frac{V_{out}}{V_{in}})$$
 strained -  $(\frac{V_{out}}{V_{in}})$  unstrained (A.4)

Where  $V_{out}$  is the gage voltage and  $V_{in}$  is given by Eq. A.3, the unstrained voltages represent the initial gage conditions prior to the test. The data for these conditions are obtained from Group #2 of the recorded data for each test series presented in Appendices B and C. In a similar manner, the strained data represent the gage response to the applied load and these values may be found in Group 3, Appendices B & C.

The strain in the Wheatstone Quarter Bridge circuit shown in Figure A.1 is given by

$$\epsilon = \frac{-4 V_{r}}{GF(1+2 V_{r})}$$
(A.5)

in which the voltage ratio  $(V_r)$  is given by Eq. A.4, and the GF is obtained from Eq. A.1.

Cable or	Length	Red-Black	Green-White	Temp.
Wire No.	(ft.)	Wires	Wires	(C)
1	450	13.448	13.164	18
2	450	13.471	13.18	18
3	450	13.22	13.514	18
4	450	13.24	13.16	18
5	450	13.755	13.614	18
6	450	13.588	13.231	18
7	450	13.677	13.72	18
, 8	450	13.214	13.149	18
ğ	350	10.301	10.235	18
10	350	10.488	10.278	18
11	350	10.478	10.254	18
12	350	10.287	10.517	18
13	300	8.825	8.776	18
14	300	9.093	9.088	18
15	300	9.064	8.833	18
16	300	9.13	9.164	18
17	150	4.549	4.433	18
18	150	4.583	4.597	18
19	150	4.431	4.422	18
20	150	4.561	4.567	18
21	150	4.511	4.421	18
22	150	4.511	4.422	18
23	150	4.434	4.527	18
24	150	4.431	4.399	18
25	450	13.631	13.611	18
26	300	9.081	9.074	18
28	300	9,122	9.422	18
29	300	9.086	9.376	18
30	300	9,127	9.426	18

Table A.1 Laboratory Measured Cable (2-Wire) Resistances

## Gage Strain Example

The following calculations are presented for cable No. 2 (gage No. 6) due to the snooper truck at position No. 16 (record 11). The data were recorded in file number SLD0502. See Appendix B, pages B-2 through B-29 for the referenced file.

<u>Step 1. Find the Gage Factor (GF):</u>

The gage factor is calculated by Eq. A.1;

$$GF = 2.05 \left[1 + \frac{.007(T_m - 24)}{100}\right]$$

• The member temperature,  $T_m$  is approximated by using the average girder temperature at the beginning of each test. This is determined from seven thermistor temperatures found in record 1, Group #1 of each file (see page B-2).

 $T_m = (12.44+13.38+13.44+13.25+12.93+12.58+12.65)/7 = 12.94$ °C

$$GF= 2.05 \left[1 + \frac{.007(12.94-24)}{100}\right] = 2.0484$$

<u>Step 2. Find the Circuit Resistance (R1)</u>

The wire resistance of the cable,  $R_1$ , is given by Eq. A.2:

 $R_1 = R_{cal} [1+0.00434(T_a-T_{cal})]$ 

• This equation accounts for wire resistance as a function of the ambient air temperature,  $T_a$ , at the time of the test.

• Record 2 in Group No. 2 of each file contains the ambient air temperature,  $T_a$ , in degrees centigrade at the beginning of each test as found on page B.2 of Appendix B.

 $T_a = 11.7$  °C

• Table A.1 gives the laboratory calibration wire resistance measurement data for each cable. The red-black wire combination was used. The values for Cable No. 2 are

 $R_{cal} = 13.417$  ohms  $T_{cal} = 18^{\circ}C$ 

Substituting these values into Eq. A.2 gives

 $R_1 = 13.417 [1+.00434(11.7-18)] = 13.1027 \text{ ohms}$ 

Step 3. Find the Voltage Ratio (Vr)

The input voltage at the gage module is given by Eq. A.3:

$$V_{in} = \frac{V(R_g)}{(R_g + R_1)}$$

The results from this equation for the unstrained and strained conditions are substituted into Eq. A.4 to give

$$Vr = (\frac{V_{out}}{V_{in}})$$
 strained -  $(\frac{V_{out}}{V_{in}})$  unstrained.

 First, obtain V<sub>in</sub> and V<sub>out</sub> for the strained condition. Group No. 3 gives the strained power supply voltage and strained cable voltage. For this example, the power supply voltage (V) and gage voltage for cable No. 2 are given on page B-11 of Appendix B.

V = 4.9776 volts Vout = +0.001765 volts

substituting these values into Eq. A.3 gives

Vin =  $\frac{4.9776 (350)}{(350+13.1027)} = 4.798$  volts

• Obtain  $V_{in}$ ,  $V_{out}$  for the unstrained condition. Group No. 2 provides these data, and for this example they may be found on page B.2 of Appendix B.

V = 4.9802 volts V<sub>out</sub> = +0.001657 volts

Substituting into Eq. A.3 gives

 $Vin = \frac{4.9802 (350)}{(350+13.1027)} = 4.80 volts$ 

• When the strained and unstrained input module voltages and strain gage voltages are determined, they are substituted into Equation A.4 to give

 $V_r = (\frac{.001765}{4.798})_{strained} - (\frac{.001657}{4.80})_{unstrained} = 22.65$ 

Step 4. Find the Gage Strain

Gage strain is given by Eq. A.5:

$$\epsilon = \frac{-4V_r}{GF(1+2V_r)}$$

The voltage ratio was found from Step 3 and the GF was determined from Step 1. Substituting these into the above equation gives

 $\in = \frac{-4}{2.084} \left[ \frac{22.65 \text{ E-06}}{1+2(22.65\text{ E-06})} \right] = 44.3 \text{ micro-strain}$ 

# A.3 Girder Temperature Profile Thermistors

The exterior face of the right box girder near the pylon at the downstation end of the bridge was instrumented with eight equally spaced Thermistors. The eighth thermistor solder connection shorted out; therefore seven were used to establish the temperature profile through the depth of the girder.

The thermistors used to instrument the William Moore Creek Bridge were YSI 44030 precision thermistors supplied by YSI Incorporated (9). YSI recommends the Steinhart and Hart empirical temperature-resistance equation given as

$$\frac{1}{T_{k}} = a + b (\log_{e} R) + c (\log_{e} R)^{3}$$
 (A.6)

in which a,b, and c are coefficients derived by measurements and supplied by the manufacturer, R is the resistance of the thermistor in ohms and  $T_k$  is the thermistor temperature in degrees Kelvin. The temperature of the thermistor in degrees centigrade is given by

$$T = T_k - 273.15^{\circ}$$
 (A.7)

Coefficients a,b, and c were calculated for the ambient temperature range from the type 44030 YSI thermistor calibration curve supplied by the manufacturer. These are

The data acquisition program written by Mr. Richard W. Briggs for this project performed the conversion of resistance to temperature in degrees centigrade. Thus, all temperatures were recorded on floppy disk directly in degrees centigrade.

### A.4 Windy Velocity

The wind speed was monitored at the left downstation end of the bridge with a Met One three-cup anemometer supplied by (5). This device was borrowed from the Alaska Department of Transportation Research Section. The anemometer counts the number of pulses in a given second. This data was recorded in this manner on a floppy disk. The wind speed is calculated in miles per hour by

$$W_V = 1.789 (F) +1$$
 (A.8)

where F is the frequency in count per second and is given by

$$F = \frac{C}{60}$$
(A.9)

in which C is the number of counts per minute measured by the instrument. Wind speed in mph was recorded on floppy disk.

### A.5 Horizontal Solar Radiation

Global direct and diffuse solar radiation was monitored at the bridge site with a star pyranometer supplied by (7). This pyranometer was borrowed from the Alaska Department of Transportation Research section and provides for a 0.3 to 3 micron response.

The pyranometer was calibrated with a tractable Eppley pyranometer to give horizontal radiation, R, in watts per square meter. The calibration relationship is

$$R = \frac{V}{15.18E.06}$$
(A.10)

in which V is the output of the pyranometer in volts. Each record provides both raw voltage and the computed radiation in watts-persquare-meter (see Appendices B and C).

# A.6 Monitoring Equipment

The data monitoring equipment consisted of two Hewlett Packard 3421A data loggers controlled by an HP-71 handheld computer. Peripheral devices included an HP battery-operated ink jet printer and a 3.5 inch disk drive. The monitoring equipment was supplied by Hewlett-Packard (3) and is owned by the Alaska Department of Transportation Research section; it was borrowed for use on this project. The data logger has excellent resolution (1 part in 602,000). The input resistance on strain gage measurements was 10E16 ohms which makes meter loading on the circuit negligible.

# A.7 References

- "Belden Wire and Cable Master Catalog 885"; Belden Wire and Cable;
   2955 E. Main Street, Suite 300; Irvine, CA 92714; Telephone: 1-800-BELDEN-1.
- Eshback, O.W., Souders, M., <u>Handbook of Engineering Fundamentals</u>, 3rd Edition, John Wiley & Sons, New York, 1975, p. 1442.
- 3) Hewlett Packard; Palo Alto, CA 94304; Telephone (213)970-7500.
- 4) Lemo USA, Inc., P.O. Box 1106, 335 Tesconi Cir, Santa Rosa, CA 95406, Telephone: (707) 578-8811
- 5) Met One, Wind Speed Sensor, Mode 014A, Met One, 481 California Avenue, Grant Pass, OR 97526, Telephone: (503) 479-1248.
- 6) Practical Strain Gage Measurements, Application Note 290-1, Hewlett Packard, 1501 Page Mill Road, Palo Alto, CA, 5952-8880, Sept. 1981.
- 7) Star Pyranometer Model R413, Weather Measure Corporation; PO Box 41257, Sacramento, CA 95841, Telephone (916) 481-7565.

- 8) Wnuk, V.P., Strain Gage Development Lab; HITEC Products, Inc., PO Box 790, Ayer, MA 01432, Telephone (508) 772-6963.
- 9) YSI Incorporated, Yellow Springs, OH, 45387, Telephone (513) 767-7241.
APPENDIX B

SNOOPER TRUCK FIELD DATA

This appendix contains raw data recorded in the field for the Snooper Truck tests. The file name corresponds to the test name used for documentation and organization of the data. The letters in the names imply the test situation.

Before testing began, the researchers prepared the following technique for documentation of each test series. All data were stored on a floppy disk under a file name. Thus a seven-letter file name was selected to describe the test conditions. The seven letters were formed as follows:



U = upstation

Based on this criteria, all static load tests for the Snooper truck were described by S?? $\phi$ S?? where the question marks are filled in for the particular test conditions.

Each file is divided into three groups of data. The three groups of information are described below.

- Group #1 = This group contains the temperatures of the girder profile and instrument temperature at the beginning of the test.
- Group #2 = This group contains the initial unstrained voltages for all the strain gages (zero readings) taken immediately preceding the tests. Air temperature and wind speed are also recorded at this time.
- Group #3 = This group provides the strained voltages for all the strain gages the LVDT voltage and the horizontal solar radiation at the time of the test.

B - 1

## MOORE CREEK BRIDGE PROJECT

Date: 89/08/01 File name: SLDØSØ2 Date: 88/08/19 Record# 1 Time: 11:58:55 Group# 1 TEMPERATURE PROFILE OF GIRDER: 12.4 Dec.C Thermistor# 1 13.4 Deg.C Thermistor# 2 13.4 Deg.C Thermistor# 3 13.2 Deg.C Thermistor# 4 Thermistor# 5 12.9 Deg.C Thermistor# 6 12.6 Dec.C Thermistor# 7 12.7 Deg.C Thermistor# 8 245.2 Deg.C Instrument | Temp: 19.91 Deg.C 20.51 Deg.C Instrument 2 Temp: ZERO STRAIN VOLTAGES: Time: 12:00:54 Record# 2 Group# 2 Power supply: 4.98020 Volts DC -.007016 Volts DC Cable# 1 +.001657 Volts DC Cable# 2 +.000915 Volts DC Cable# - 3 -.001463 Volts DC Cable# 4 Cable# 5 -.001010 Volts DC -.004044 Volts DC Cable# 6 -.000914 Volts DC Cable# 7 Cable# 8 -.001971 Volts DC -.001316 Volts DC Cable# 9 Cable# 10 +.002780 Volts DC +.003539 Volts DC Cable# 11 -.000032 Volts DC Cable# 12 -.001342 Volts DC Cable# 13 -.004179 Volts DC Cable# 14 -.004330 Volts DC Cable# 15 -.001438 Volts DC Cable# 16 -.003084 Volts DC Cable# 17 -.003376 Volts DC Cable# 18 -.003338 Volts DC Cable# 19 Cable# 20 -.003326 Volts DC -.002121 Volts DC Cable# 21 +.002850 Volts DC Cable# 22 -.001956 Volts DC Cable# 23 -.001630 Volts DC Cable# 24 Cable# 25 -.002614 Volts DC LVDT: -0.063337 VDC 428.8 W/M^2 Hor. Rad.= 6.5E-3 VDC Air Temp= 11.7 Deg.C Wind Speed: 9.6 MPH

Position #24 LT

Time:	12:02:12	2 Date: 88	3/08/19	3				
Group#	3	Record#	3					
File name: SLDØSØ2								
Power :	supply:	4,9809	Volts	DC				
Cable#	1	007019	Volts	DC	8	Micro-Strains		
Cable#	2	+.001654	Volts	DC	-1.3	Micro-Strains		
Cable#	3	+.000914	Volts	DC	5	Micro-Strains		
Cable#	4	001463	Volts	DC	+.1	Micro-Strains		
Cable#	5	001011	Volts	DC	3	Micro-Strains		
Cable#	6	004049	Volts	DC	-1.8	Micro-Strains		
Cable#	7	000913	Volts	DC	+.5	Micro-Strains		
Cable#	8	001972	Volts	DC	3	Micro-Strains		
Cable#	9	001318	Volts	DC	7	Micro-Strains		
Cable#	10	+.002780	Volts	DC	2	Micro-Strains		
Cable#	11	+.003540	Volts	DC	<b>+.</b> Z	Micro-Strains		
Cable#	12	000035	Volts	DC	-1.Z	Micro-Strains		
Cable#	13	001346	Volts	DC	-1.5	Micro-Strains		
Cable#	14	004182	Volts	DC	-1.0	Micro-Strains		
Cable#	15	004329	Volts	DC	+.6	Micro-Strains		
Cable#	16	001441	Volts	DC	-1.1	Micro-Strains		
Cable#	17	003086	Volts	DC	6	Micro-Strains		
Cable#	18	003378	Volts	DC	6	Micro-Strains		
Cable#	19	003340	Volts	DC	6	Micro-Strains		
Cable#	20	003328	Volts	ÐC	6	Micro-Strains		
Cable#	21	002118	Volts	DC	+1.3	Micro-Strains		
Cable#	22	+.002850	Volts	DC	2	Micro-Strains		
Cable#	23	001956	Volts	DC	+.1	Micro-Strains		
Cable#	24	001629	Volts	DC	+.5	Micro-Strains		
Cable#	25	002623	Volts	DC	-3.5	Micro-Strains		

LVDT: -0.062892 VDC -0.000023 Inches

Hor. Rad.=.004849 VDC 319.4 W/M^2

Position #23 LT

.

Time: 1	2:03:25	5 Date: 88	3/08/19	}		
Group#	3	Record#	4			
File na	ame: SLf	DØSØ2				
Power :	supply:	4.9811	Volts	DC		
Cable#	1	007022	Volts	DC	-1.9	Micro-Strains
Cable#	2	+.001649	Volts	DC	-3.4	Micro-Strains
Cable#	3	+.000911	Volts	DC	-1.7	Micro-Strains
Cable#	4	001463	Volts	DC	+.1	Micro-Strains
Cable#	5	001011	Volts	DC	3	Micro-Strains
Cable#	6	004053	Volts	DC	-3.4	Micro-Strains
Cable#	7	000915	Volts	DC	3	Micro-Strains
Cable#	8	001977	Volts	DC	-2.3	Micro-Strains
Cable#	9	001320	Volts	DC	-1.5	Micro-Strains
Cable#	10	+.002777	Volts	DC	-1.4	Micro-Strains
Cable#	11	+.003540	Volts	DC	+.1	Micro-Strains
Cable#	12	000040	Volts	DC	-3.2	Micro-Strains
Cable#	13	001346	Volts	DC	-1.5	Micro-Strains
Cable#	14	004184	Volts	DC	-1.7	Micro-Strains
Cable#	15	004331	Volts	DC	1	Micro-Strains
Cable#	16	001441	Volts	DC	-1.1	Micro-Strains
Cable#	17	003090	Volts	DC	-2.2	Micro-Strains
Cable#	18	003381	Volts	DC	-1.7	Micro-Strains
Cable#	19	003341	Volts	DC	-1.0	Micro-Strains
Cable#	20	003331	Volts	DC	-1.7	Micro-Strains
Cable#	21	002117	Volts	DC	+1.7	Micro-Strains
Cable#	22	+.002850	Volts	DC	2	Micro-Strains
Cable#	23	001956	Volts	DC	+.1	Micro-Strains
Cable#	24	001629	Volts	DC	+.5	Micro-Strains
Cable#	25	002639	Volts	DC	-10.0	Micro-Strains

LVDT: -0.062918 VDC -0.000021 Inches

Hor, Rad.=.004926 VDC 324.5 W/M^2

Position #22 LT

Time: 1	2:04:27	? Date: 88	3/08/19	)		
Group#	3	Record#	5			
File na	ime: SLC	00502				
Power s	upply:	4.9812	Volts	DC		
Cable#	1	007024	Volts	DC	-2.7	Micro-Strains
Cable#	Z	+.001655	Volts	DC	9	Micro-Strains
Cable#	3	+.000907	Volts	DC	-3.3	Micro-Strains
Cable#	4	001477	Volts	DC	-5.6	Micro-Strains
Cable#	5	001017	Volts	DC	-2.8	Micro-Strains
Cable#	6	004059	Volts	DC	-5.8	Micro-Strains
Cable#	7	000913	Volts	DC	+.5	Micro-Strains
Cable#	8	001986	Volts	DC	-5.9	Micro-Strains
Cable#	9	001326	Volts	DC	-3.9	Micro-Strains
Cable#	10	+,002777	Volts	DC	-1.4	Micro-Strains
Cable#	11	+.003541	Volts	DC	+.5	Micro-Strains
Cable#	12	000050	Volts	DC	-7.3	Micro-Strains
Cable#	13	001346	Volts	DC	-1.5	Micro-Strains
Cable#	14	004187	Volts	DC	-Z.9	Micro-Strains
Cable#	15	004335	Volts	DC	-1.7	Micro-Strains
Cable#	16	001445	Volts	DC	-2.7	Micro-Strains
Cable#	17	003097	Volts	DC	-4.9	Micro-Strains
Cable#	18	003386	Volts	DC	-3.7	Micro-Strains
Cable#	19	003341	Volts	DC	9	Micro-Strains
Cable#	20	003335	Volts	DC	-3.3	Micro-Strains
Cable#	21	~.002118	Volts	DC	+1.4	Micro-Strains
Cable#	22	+.002849	Volts	DC	~.6	Micro-Strains
Cable#	23	001957	Volts	DC	2	Micro-Strains
Cable#	24	001628	Volts	DC	+.9	Micro-Strains
Cable#	25	002633	Volts	DC	-7.5	Micro-Strains

LVDT: -0.062940 VDC -0.000020 Inches

Hor. Rad.=.004708 VDC 310.1 W/M^2

Position #21 LT

Time: 1	2:05:33	3 Date: 88	3/08/15	}		
Group#	3	Record#	6			
File na	ame: SLD	00502				
Power s	supply:	4.9813	Volts	DC		
Cable#	1	007025	Volts	DC	-3.0	Micro-Strains
Cable#	2	+.001693	Volts	DC	+14.5	Micro-Strains
Cable#	3	+.000901	Volts	DC	-5.8	Micro-Strains
Cable#	4	001530	Volts	DC	-27.1	Micro-Strains
Cable#	5	001038	Volts	DC	-11.3	Micro-Strains
Cable#	6	004062	Volts	DC	-7.0	Micro-Strains
Cable#	7	000896	Volts	ÐC	+7.4	Micro-Strains
Cable#	8	001996	Volts	DC	-10.0	Micro-Strains
Cable#	9	001334	Volts	DC	-7.1	Micro-Strains
Cable#	10	+.002784	Volts	DC	+1.4	Micro-Strains
Cable#	11	+.003545	Volts	DC	+2.1	Micro-Strains
Cable#	12	000064	Volts	DC	-12.9	Micro-Strains
Cable#	13	001347	Volts	DC	-1.9	Micro-Strains
Cable#	14	-,004188	Volts	DC	-3.2	Micro-Strains
Cable#	15	004338	Volts	DC	-2.8	Micro-Strains
Cable#	16	001447	Volts	DC	-3.5	Micro-Strains
Cable#	17	003105	Volts	DC	-8.1	Micro-Strains
Cable#	18	003389	Volts	DC	-4.9	Micro-Strains
Cable#	19	003343	Volts	DC	-1.7	Micro-Strains
Cable#	20	003339	Volts	DC	-4.9	Micro-Strains
Cable#	21	002118	Volts	DC	+1.4	Micro-Strains
Cable#	22	+.002850	Volts	DC	3	Micro-Strains
Cable#	23	001958	Volts	DC	6	Micro-Strains
Cable#	24	001631	Volts	DC	3	Micro-Strains
Cable#	25	002622	Volts	DC	-3.0	Micro-Strains

LVDT: -0.062585 VDC -0.000038 Inches

Hor. Rad.=.004667 VDC 307.4 W/M^2

Position #20 LT

Time:	12:06:30	2 Date: 88	3/08/19	3		
Group#	3	Record#	7			
File na	ame: SLI	00502				
Power «	supply:	4.9814	Volts	DC		
Cable#	1	007022	Volts	DC	-1.8	Micro-Strains
Cable#	2	+.001733	Volts	DC	+30.8	Micro-Strains
Cable#	3	+.000895	Volts	DC	-8.2	Micro-Strains
Cable#	4	001579	Volts	DC	-47.0	Micro-Strains
Cable#	5	001059	Volts	DC	-19.9	Micro-Strains
Cable#	6	004061	Volts	DC	-6.5	Micro-Strains
Cable#	7	000878	Volts	DC	+14.8	Micro-Strains
Cable#	8	002006	Volts	ÐC	-14.0	Micro-Strains
Cable#	9	001345	Volts	DC	-11.6	Micro-Strains
Cable#	10	+.002801	Volts	DC	+8.2	Micro-Strains
Cable#	11	+.003553	Volts	DC	+5.3	Micro-Strains
Cable#	12	000085	Volts	DC	-21.4	Micro-Strains
Cable#	13	001345	Volts	DC	-1.1	Micro-Strains
Cable#	14	004186	Volts	DC	-2.4	Micro-Strains
Cable#	15	004341	Volts	DC	-4.0	Micro-Strains
Cable#	16	001450	Volts	DС	-4.7	Micro-Strains
Cable#	17	003113	Volts	DC	-11.2	Micro-Strains
Cable#	18	003389	Volts	DC	-4.8	Micro-Strains
Cable#	19	003346	Volts	DC	-2.9	Micro-Strains
Cable#	20	003346	Volts	DC	-7.6	Micro-Strains
Cable#	21	002115	Volts	DC	+2.2	Micro-Strains
Cable#	22	+.002851	Volts	DC	+.1	Micro-Strains
Cable#	23	001961	Volts	DC	-1.8	Micro-Strains
Cable#	24	001636	Volts	DC	-2.2	Micro-Strains
Cable#	25	002615	Volts	DC	2	Micro-Strains

LVDT: -0.063115 VDC -0.000011 Inches

Hor. Rad.=.004762 VDC 313.7 W/M^2

Position #19 LT

Time: 1	12:07:43	3 Date: 88	3/08/15			
Group#	3	Record#	8			
File ne	ame: SLE	)ØSØ2				
Power :	supply:	4.9815	Volts	DC		
Cable#	1	007021	Volts	DC	-1.3	Micro-Strains
Cable#	2	+.001759	Volts	DC	+41.3	Micro-Strains
Cable#	3	+.000890	Volts	DC	-10.3	Micro-Strains
Cable#	4	001606	Volts	DC	-58.0	Micro-Strains
Cable#	5	001072	Volts	DC	-25.1	Micro-Strains
Cable#	6	004057	Volts	DC	-4,9	Micro-Strains
Cable#	7	000866	Volts	DC	+19.6	Micro-Strains
Cable#	8	002012	Volts	DC	-16.5	Micro-Strains
Cable#	9	001359	Volts	DC	-17.2	Micro-Strains
Cable#	10	+.002829	Volts	DC	+19.5	Micro-Strains
Cable#	11	+.003564	Volts	DC	+9.7	Micro-Strains
Cable#	12	000113	Volts	DC	-32.7	Micro-Strains
Cable#	13	001345	Volts	DC	-1.1	Micro-Strains
Cable#	14	004183	Volts	DC	-1.2	Micro-Strains
Cable#	15	004346	Volts	DC	-6.0	Micro-Strains
Cable#	16	001448	Volts	DC	-3.9	Micro-Strains
Cable#	17	003118	Volts	DC	-13.2	Micro-Strains
Cable#	18	003388	Volts	DC	-4,4	Micro-Strains
Cable#	19	003347	Volts	DC	-3.2	Micro-Strains
Cable#	20	~.003349	Volts	DC	-8.8	Micro-Strains
Cable#	21	002115	Volts	DC	+2.6	Micro-Strains
Cable#	22	+.002853	Volts	DC	+,9	Micro-Strains
Cable#	23	001964	Volts	DC	-3.0	Micro-Strains
Cable#	24	001641	Volts	DC	-4.2	Micro-Strains
Cable#	25	002612	Volts	DC	+1.1	Micro-Strains

LVDT: -0.062852 VDC -0.000025 Inches

Hor, Rad.=.004831 VDC 318.2 W/M^2

Position #18 LT

Time: 1	2:10:0E	5 Date: 88	3/08/19	)				
Group#	3	Record#	9					
File name: SLDØSØ2								
Power s	supply:	4.9810	Volts	DC				
Cable#	1	007015	Volts	DC	+.9	Micro-Strains		
Cable#	2	+.001770	Volts	DC	+45.9	Micro-Strains		
Cable#	3	+.000884	Volts	DC	-12.7	Micro-Strains		
Cable#	4	~.001615	Volts	DC	-61.7	Micro-Strains		
Cable#	5	001077	Volts	DC	-27.2	Micro-Strains		
Cable#	6	004050	Volts	DC	-2.2	Micro-Strains		
Cable#	7	000862	Volts	DC	+21.2	Micro-Strains		
Cable#	8	002019	Volts	DC	-19.4	Micro-Strains		
Cable#	9	001375	Volts	DC	-23.7	Micro-Strains		
Cable#	10	+.002867	Volts	ÐC	+35.0	Micro-Strains		
Cable#	11	+.003577	Volts	DC	+15.1	Micro-Strains		
Cable#	12	000150	Volts	DC	-47.6	Micro-Strains		
Cable#	13	001342	Volts	DC	+.1	Micro-Strains		
Cable#	14	-,004180	Volts	DC	1	Micro-Strains		
Cable#	15	004347	Volts	DC	-6.6	Micro-Strains		
Cable#	16	001449	Volts	DC	-4.3	Micro-Strains		
Cable#	17	003122	Volts	DC	-14.9	Micro-Strains		
Cable#	18	003385	Volts	DC	-3.4	Micro-Strains		
Cable#	19	003348	Volts	DC	-3.8	Micro-Strains		
Cable#	20	003355	Volts	DC	-11.3	Micro-Strains		
Cable#	21	002111	Volts	DC	+4.1	Micro-Strains		
Cable#	22	+.002855	Volts	DC	+1.8	Micro-Strains		
Cable#	23	001969	Volts	DC	-5,0	Micro-Strains		
Cable#	24	001649	Volts	DC	-7.4	Micro-Strains		
Cable#	25	002609	Volts	DC	+2.2	Micro-Strains		

LVDT: -0.063264 VDC -0.000004 Inches

Hor, Rad.=.004239 VDC 279.2 W/M^2

Position #17 LT

12 + 17 + 10	o Date - oc		j.		
3	Record#	1Ø			
ame: SLI	00502				
supply:	4,9783	Volts	DC		
1	007001	Volts	DC	+5.0	Micro-Strains
2	+.001768	Volts	DC	+45.5	Micro-Strains
3	+,000876	Volts	DC	-15.7	Micro-Strains
4	001615	Volts	DC	-62.1	Micro-Strains
5	001076	Volts	DC	-27.1	Micro-Strains
6	004037	Volts	DC	+2.2	Micro-Strains
7	000864	Valts	DC	+2Ø.2	Micro-Strains
8	002028	Volts	DC	-23.5	Micro-Strains
9	001389	Volts	DC	-29.7	Micro-Strains
10	+.002905	Volts	DC	+50.9	Micro-Strains
11	+.003586	Volts	DC	+19.5	Micro-Strains
12	000190	Volts	DC	-63.8	Micro-Strains
13	001336	Volts	DC	+2.2	Micro-Strains
14	004175	Volts	DC	+1.0	Micro-Strains
15	004351	Volts	DC	-9.1	Micro-Strains
16	001447	Volts	DC	-3.8	Micro-Strains
17	003124	Volts	DC	-16.4	Micro-Strains
18	003379	Volts	DC	-1.7	Micro-Strains
19	-,003349	Volts	DC	-4.9	Micro-Strains
20	003362	Volts	DC	-14.8	Micro-Strains
21	002097	Volts	DC	+9.Z	Micro-Strains
22	+.002864	Volts	DC	+6,0	Micro-Strains
Z 3	001979	Volts	DC	-9.4	Micro-Strains
24	-,001663	Volts	DC	-13.4	Micro-Strains
25	002603	Volts	DC	+4.1	Micro-Strains
	3 ame: SLI supply: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25	3  Record#    ame: SLD0S02    supply: 4,9783    1 007001    2  +.001768    3  +.000876    4 001615    5 001076    6 004037    7 000864    8 002028    9 001389    10  +.002905    11  +.003586    12 000190    13 001336    14 004475    15 001447    16 003324    18 003379    19 003349    20 003362    21 002864    23 001979    24 001979    24 001863	3Record#10ame:SLD0S02supply: $4.9783$ Volts1 $007001$ Volts2 $+.001768$ Volts3 $+.000876$ Volts4 $001615$ Volts5 $001076$ Volts6 $004037$ Volts7 $000864$ Volts8 $002028$ Volts9 $001389$ Volts10 $+.002905$ Volts11 $+.003586$ Volts12 $000190$ Volts13 $001336$ Volts14 $004175$ Volts15 $001447$ Volts16 $003379$ Volts17 $003349$ Volts18 $003362$ Volts20 $003362$ Volts21 $00297$ Volts23 $001979$ Volts24 $001663$ Volts25 $002603$ Volts	3Record#103Record#10ame: SLD0S02supply: $4.9783$ VoltsDC1 $007001$ VoltsDC2 $+.001768$ VoltsDC3 $+.000876$ VoltsDC4 $001615$ VoltsDC5 $001076$ VoltsDC6 $004037$ VoltsDC7 $000864$ VoltsDC8 $002028$ VoltsDC9 $001389$ VoltsDC10 $+.002905$ VoltsDC11 $+.003586$ VoltsDC12 $000190$ VoltsDC13 $001336$ VoltsDC14 $004175$ VoltsDC15 $001447$ VoltsDC16 $003324$ VoltsDC17 $003349$ VoltsDC18 $003362$ VoltsDC20 $003362$ VoltsDC21 $002864$ VoltsDC23 $001979$ VoltsDC24 $001663$ VoltsDC25 $002603$ VoltsDC	3 Record# 10 3 Record# 10 ame: SLD0S02 supply: 4.9783 Volts DC 1007001 Volts DC +5.0 2 +.001768 Volts DC -15.7 4001615 Volts DC -62.1 5001076 Volts DC -62.1 5001076 Volts DC -27.1 6004037 Volts DC +2.2 7000864 Volts DC +2.2 8002028 Volts DC -23.5 9001389 Volts DC -29.7 10 +.002905 Volts DC +50.9 11 +.003586 Volts DC +19.5 12000190 Volts DC +50.9 11 +.003586 Volts DC +2.2 14004175 Volts DC +2.2 14004175 Volts DC +2.2 14004351 Volts DC -3.8 17003124 Volts DC -3.8 17003362 Volts DC -16.4 18003379 Volts DC -116.4 18003362 Volts DC -1.7 19003362 Volts DC -4.9 20003362 Volts DC +9.2 22 +.002864 Volts DC -9.4 24001663 Volts DC -13.4 25002603 Volts DC -13.4

LVDT: -0.063285 VDC -0.000003 Inches

Hor. Rad.=.004414 VDC 290.8 W/M^2

Position #16 LT

01 Date: 80	3/08/19	3		
Record#	11			
_00502				
: 4,9776	Volts	DC		
006998	Volts	DC	+5.8	Micro-Strains
+.001765	Volts	DC	+44.3	Micro-Strains
+.000876	Volts	DC	-15.7	Micro-Strains
001608	Volts	DC	-59.3	Micro-Strains
001073	Volts	DC	-25.9	Micro-Strains
004034	Volts	DC	+3.2	Micro-Strains
000865	Volts	DC	+19.8	Micro-Strains
-,002027	Volts	DC	-23.2	Micro-Strains
001396	Volts	DC	-32.6	Micro-Strains
+,002929	Volts	00	+60.8	Micro-Strains
+.003591	Volts	DC	+21.8	Micro-Strains
000208	Volts	DC	-71.1	Micro-Strains
001339	Volts	DC	+.9	Micro-Strains
004179	Volts	DC	- , 9	Micro-Strains
004348	Volts	DC	-8.2	Micro-Strains
001444	Volts	DC	-2.7	Micro-Strains
003119	Volts	DC	-14.6	Micro-Strains
003371	Volts	DC	+1.3	Micro-Strains
003351	Volts	DC	-5.9	Micro-Strains
003368	Volts	DC	-17,4	Micro-Strains
002100	Volts	DC	+7.9	Micro-Strains
+,002864	Volts	DC	+6.2	Micro-Strains
001982	Volts	DC	-10.7	Micro-Strains
001669	Volts	DC	-15.8	Micro-Strains
002602	Volts	DC	+4.3	Micro-Strains
	<pre>01 Date: 88 Record# _D0S02 : 4.9776 006998 +.001765 +.000876 001608 001073 004034 000865 002027 001396 +.002929 +.003591 004348 001339 004179 004348 001444 003119 003351 003368 002100 +.002864 001669 002602</pre>	<pre>Date: 88/08/19 Record# 11 D0502 4.9776 Volts 006998 Volts +.001765 Volts +.001765 Volts 001608 Volts 001073 Volts 001073 Volts 002027 Volts 002027 Volts 002027 Volts 001396 Volts +.002929 Volts +.002929 Volts 001339 Volts 001339 Volts 004179 Volts 004444 Volts 001444 Volts 003351 Volts 003351 Volts 003351 Volts 003351 Volts 003368 Volts 002100 Volts +.002864 Volts 001982 Volts 001669 Volts 002602 Volts</pre>	<pre>21 Date: 88/08/19 Record# 11 D0502 : 4.9776 Volts DC 006998 Volts DC +.001765 Volts DC +.001765 Volts DC 001608 Volts DC 001608 Volts DC 001073 Volts DC 001073 Volts DC 002027 Volts DC 002027 Volts DC 001396 Volts DC 001396 Volts DC +.002929 Volts DC 001339 Volts DC 001339 Volts DC 004179 Volts DC 004444 Volts DC 001444 Volts DC 003351 Volts DC 003358 Volts DC 002100 Volts DC +.002864 Volts DC 001982 Volts DC 001669 Volts DC</pre>	<pre>Date: 88/08/19 Record# 11 D0502 4.9776 Volts DC 006998 Volts DC +5.8 +.001765 Volts DC +44.3 +.000876 Volts DC -15.7 001608 Volts DC -59.3 001073 Volts DC -25.9 004034 Volts DC +3.2 000865 Volts DC +19.8 002027 Volts DC -23.2 001396 Volts DC -23.2 001396 Volts DC -23.2 001396 Volts DC +21.8 +.003591 Volts DC +21.8 000208 Volts DC +21.8 000208 Volts DC -71.1 001339 Volts DC -71.1 001339 Volts DC -99 004479 Volts DC -99 004479 Volts DC -2.7 001444 Volts DC -2.7 003119 Volts DC -14.6 003371 Volts DC -14.6 003351 Volts DC -5.9 003368 Volts DC -17.4 002100 Volts DC +7.9 +.002864 Volts DC -16.2 001982 Volts DC -15.8 001669 Volts DC -15.8 002602 Volts DC -15.8</pre>

LVDT: -0.063558 VDC 0.000011 Inches

Hor. Rad.=.009334 VDC 614.9 W/M^2

Position #15 LT

Time: 1	12:24:5	3 Date: 88	3/08/19	3		
Group#	3	Record#	12			
File na	ame: SLI	DØSØ2				
Power :	supply:	4.9758	Volts	DC		
Cable#	1	006997	Volts	DC	+5.2	Micro-Strains
Cable#	2	+.001758	Volts	DC	+41.8	Micro-Strains
Cable#	3	+.000878	Volts	DC	-14.7	Micro-Strains
Cable#	4	001596	Volts	00	-54.7	Micro-Strains
Cable#	5	001068	Volts	DC	-24.0	Micro-Strains
Cable#	6	004035	Volts	ÐC	+2.2	Micro-Strains
Cable#	7	000868	Volts	DC	+18.4	Micro-Strains
Cable#	8	002022	Volts	DC	-21.5	Micro-Strains
Cable#	9	001384	Volts	DC	-27.9	Micro-Strains
Cable#	10	+.002899	Volts	00	+49.1	Micro-Strains
Cable#	11	+.003582	Volts	DC	+18.6	Micro-Strains
Cable#	12	000177	Volts	DC	-58.6	Micro-Strains
Cable#	13	001345	Volts	DC	-1.7	Micro-Strains
Cable#	14	004190	Volts	DC	-5.9	Micro-Strains
Cable#	15	004343	Volts	DC	-6.8	Micro-Strains
Cable#	16	001439	Volts	DC	9	Micro-Strains
Cable#	17	003106	Volts	DC	-9.8	Micro-Strains
Cable#	18	003362	Volts	DC	+4.4	Micro-Strains
Cable#	19	003353	Volts	DC	-7.1	Micro-Strains
Cable#	20	003375	Volts	DC	-20.7	Micro-Strains
Cable#	21	002092	Volts	DC	+10.8	Micro-Strains
Cable#	22	+.002870	Volts	DC	+9.0	Micro-Strains
Cable#	23	001989	Volts	DC	-13.8	Micro-Strains
Cable#	24	001680	Volts	DC	-20.5	Micro-Strains
Cable#	25	002603	Volts	DC	+3.5	Micro-Strains

LVDT: -0.063810 VDC 0.000024 Inches

Hor. Rad.=.004609 VDC 303.6 W/M^2

Position #15 LT 2ND TIME

Time: 12:26	:06 Date: 80	3/08/19	}		
Group# 3	Record#	13			
File name:	SLDØSØ2				
Power suppl	y: 4.9763	Volts	DC		
Cable# 1	006996	Volts	DC	+5.9	Micro-Strains
Cable# 2	+.001757	Volts	DC	+41.3	Micro-Strains
Cable# 3	+,000878	Volts	ĐC	-14.8	Micro-Strains
Cable# 4	001596	Volts	DC	-54.6	Micro-Strains
Cable# 5	001069	Volts	DC	-24.4	Micro-Strains
Cable# 8	004034	Volts	DC	+2.8	Micro-Strains
Cable# 7	000868	Volts	DC	+18.5	Micro-Strains
Cable# 8	- , 002023	Volts	DC	-21.8	Micro-Strains
Cable# 9	-,001384	Volts	DC	-27.9	Micro-Strains
Cable# 10	+,002899	Volts	DC	+49.0	Micro-Strains
Cable# 11	+.003582	Volts	DC	+18.5	Micro-Strains
Cable# 12	000177	Volts	ÐC	-58.6	Micro-Strains
Cable# 13	001345	Volts	DC	-1.6	Micro-Strains
Cable# 14	004190	Volts	DC	-5.7	Micro-Strains
Cable# 15	004343	Volts	DC	-6.6	Micro-Strains
Cable# 16	001439	Volts	DC	9	Micro-Strains
Cable# 17	003107	Volts	DC	-10,1	Micro-Strains
Cable# 18	003362	Volts	DC	+4.5	Micro-Strains
Cable# 19	-,003354	Volts	DC	-7.4	Micro-Strains
Cable# 2Ø	003374	Volts	DC	-20.1	Micro-Strains
Cable# 21	002092	Volts	DC	+10.9	Micro-Strains
Cable# 22	+.002870	Volts	DC	+8.8	Micro-Strains
Cable# 23	001989	Volts	DC	-13.7	Micro-Strains
Cable# 24	001680	Volts	DC	-20.4	Micro-Strains
Cable# 25	002603	Volts	DC	+3.6	Micro-Strains

LVDT: -0.063835 VDC 0.000025

Inches

Hor, Rad.=.004864 VDC

320.4 W/M^2

Position #14 LT

Time: 1	2:28:0	5 Date: 88	3/08/19	3		
Group#	3	Record#	14			
File na	ame: SLI	00502				
Power s	supply:	4.9771	Volts	DC		
Cable#	1	006999	Volts	DC	+5.1	Micro-Strains
Cable#	2	+.001747	Volts	DC	+37.1	Micro-Strains
Cable#	3	+.000883	Volts	DC	-12.8	Micro-Strains
Cable#	4	001581	Volts	DC	-48.4	Micro-Strains
Cable#	5	001063	Volts	DC	-21.9	Micro-Strains
Cable#	6	- , ØØ4Ø4Ø	Volts	DC	+ , 6	Micro-Strains
Cable#	7	000874	Volts	DC	+16.1	Micro-Strains
Cable#	8	002014	Volts	DC	-18.0	Micro-Strains
Cable#	9	001366	Volts	DC	-20.5	Micro-Strains
Cable#	10	+.002853	Volts	DC	+30.2	Micro-Strains
Cable#	11	+.003568	Volts	DC	+12.6	Micro-Strains
Cable#	12	000131	Volts	DC	-40.0	Micro-Strains
Cable#	13	001352	Volts	DC	-4,4	Micro-Strains
Cable#	14	-,004206	Volts	DC	-11.9	Micro-Strains
Cable#	15	004338	Volts	DC	~4.3	Micro-Strains
Cable#	16	-,001433	Volts	DC	+1.7	Micro-Strains
Cable#	17	003089	Volts	DC	-2.8	Micro-Strains
Cable#	18	003352	Volts	DC	+8.7	Micro-Strains
Cable#	19	003359	Volts	DC	-9.2	Micro-Strains
Cable#	2Ø	003384	Volts	DC	-23.9	Micro-Strains
Cable#	21	002091	Volts	DC	+11.4	Micro-Strains
Cable#	22	+.002874	Volts	DC	+10.2	Micro-Strains
Cable#	23	001993	Volts	DC	-15.2	Micro-Strains
Cable#	24	001688	Volts	DC	-23.5	Micro-Strains
Cable#	25	002604	Volts	DC	+3.4	Micro-Strains

LVDT: -0.063738 VDC 0.000020 Inches

Hor. Rad.=.005459 VDC 359.6 W/M^2

Position #13 LT

Time: 12:30:1	2 Date: 88/08/19	)	
Group# 3	Record# 15		
File name: SL	.DØSØ2		
Power supply:	4,9780 Volts	DC	
Cable# 1	007006 Volts	DC +2.8	Micro-Strains
Cable# 2	+.001736 Volts	DC +32.5	Micro-Strains
Cable# 3	+.000892 Volts	DC -9.2	Micro-Strains
Cable# 4	-,001564 Volts	DC -41.4	Micro-Strains
Cable# 5	001054 Volts	DC -18.1	Micro-Strains
Cable# 6	-,004050 Volts	DC -3.2	Micro-Strains
Cable# 7	000880 Volts	DC +13.7	Micro-Strains
Cable# 8	-,002000 Volts	DC -12.2	Micro-Strains
Cable# 9	001351 Volts	DC -14.4	Micro-Strains
Cable# 10	+.002826 Volts	DC +19.1	Micro-Strains
Cable# 11	+.003557 Volts	DC +7.9	Micro-Strains
Cable# 12	000099 Volts	DC -27.1	Micro-Strains
Cable# 13	001361 Volts	DC -7.9	Micro-Strains
Cable# 14	-,004231 Volts	DC -21.7	Micro-Strains
Cable# 15	004328 Volts	DC +.Ø	Micro-Strains
Cable# 16	001427 Volts	DC +4.2	Micro-Strains
Cable# 17	003061 Volts	DC +8.6	Micro-Strains
Cable# 18	-,003337 Volts	DC +14.9	Micro-Strains
Cable# 19	003365 Volts	DC -11.3	Micro-Strains
Cable# 20	-,003397 Volts	DC -28.8	Micro-Strains
Cable# 21	002090 Volts	DC +12.0	Micro-Strains
Cable# 22	+,002879 Volts	DC +12.0	Micro-Strains
Cable# 23	-,001997 Volts	DC -16.6	Micro-Strains .
Cable# 24	001698 Volts	DC -27.3	Micro-Strains
Cable# 25	002606 Volts	DC +2.8	Micro-Strains

LVDT: -0.063754 VDC 0.000021 Inches

Hor. Rad.=.005316 VDC 350.2 W/M^2

Position #12 LT

Time: 1	2:31:21	Date: 88	3/08/15	)		
Group#	3	Record#	16			
File ne	ime: SLD	00502				
Power s	upply:	4.9785	Volts	DC		
Cable#	1	007015	Volts	DC	-,6	Micro-Strains
Cable#	2	+.001722	Volts	DC	+26.7	Micro-Strains
Cable#	3	+.000906	Volts	DC	-3.5	Micro-Strains
Cable#	4	001546	Volts	DC	-34.0	Micro-Strains
Cable#	5	001044	Volts	DC	-14.0	Micro-Strains
Cable#	6	-,004069	Volts	DC	-10.7	Micro-Strains
Cable#	7	000887	Volts	DC	+10.9	Micro-Strains
Cable#	8	-,001978	Volts	DC	-3.1	Micro-Strains
Cable#	9	001336	Volts	DC	-8.3	Micro-Strains
Cable#	10	+.002801	Volts	DC	+8.9	Micro-Strains
Cable#	11	+.003545	Volts	DC	+2.9	Micro-Strains
Cable#	12	-,000073	Volts	DC	-16.6	Micro-Strains
Cable#	13	001372	Volts	DC	-12.3	Micro-Strains
Cable#	14	004263	Volts	DC	-34,4	Micro-Strains
Cable#	15	004319	Volts	DC	+3.8	Micro-Strains
Cable#	16	001419	Volts	DC	+7.5	Micro-Strains
Cable#	17	003030	Volts	DC	+21.0	Micro-Strains
Cable#	18	003321	Volts	DC	+21.4	Micro-Strains
Cable#	19	003372	Volts	DC	-14.0	Micro-Strains
Cable#	20	003410	Volts	DC	-33.8	Micro-Strains
Cable#	21	002090	Volts	DC	+12.0	Micro-Strains
Cable#	22	+.002882	Volts	DC	+13.1	Micro-Strains
Cable#	23	001999	Volts	DC	-17.4	Micro-Strains
Cable#	24	001704	Volts	DC	-29.6	Micro-Strains
Cable#	25	-,002608	Volts	DC	+2.1	Micro-Strains

LVDT: -0.063696 VDC 0.000018 Inches

Hor. Rad.=.005247 VDC 345.7 W/M^2

Position #11 LT

Time: i	2:32:32	? Date: 80	3708719	9		
Group#	3	Record#	17			
File na	ame: SLI	00502				
Power :	supply:	4.9786	Volts	DC		
Cable#	1	007029	Volts	DC	-6.2	Micro-Strains
Cable#	2	+.001708	Volts	DC	+21.0	Micro-Strains
Cable#	3	+,000923	Volts	DC	+3.4	Micro-Strains
Cable#	4	001528	Volts	DC	-26.6	Micro-Strains
Cable#	5	001035	Volts	DC	-10.3	Micro-Strains
Cable#	6	004095	Volts	DC	-21.3	Micro-Strains
Cable#	7	000895	Volts	DC	+7.6	Micro-Strains
Cable#	8	001946	Volts	DC	+9.9	Micro-Strains
Cable#	9	001324	Volts	DC	-3.4	Micro-Strains
Cable#	10	+.002783	Volts	DC	+1.6	Micro-Strains
Cable#	11	+.003536	Volts	DC	8	Micro-Strains
Cable#	12	000051	Volts	DC	-7.7	Micro-Strains
Cable#	13	001377	Volts	DC	-14.2	Micro-Strains
Cable#	14	004283	Volts	DC	-42.4	Micro-Strains
Cable#	15	004317	Volts	DC	+4.7	Micro-Strains
Cable#	16	001408	Volts	DC	+11.9	Micro-Strains
Cable#	17	003013	Volts	DC	+27.8	Micro-Strains
Cable#	18	003300	Volts	DC	+29.8	Micro-Strains
Cable#	19	003379	Volts	DC	-16.7	Micro-Strains
Cable#	20	003426	Volts	DC	-40.2	Micro-Strains
Cable#	21	002089	Volts	DC	+12.4	Micro-Strains
Cable#	22	+.002887	Volts	DC	+15.1	Micro-Strains
Cable#	23	002003	Volts	DC	-18.9	Micro-Strains
Cable#	24	001713	Volts	DC	-33.2	Micro-Strains
Cable#	25	002609	Volts	DC	+1.7	Micro-Strains

LVDT: -0.063695 VDC 0.000018 Inches

Hor. Rad.=.005106 VDC 336.4 W/M^2

Position #10 LT

Time: 1	2:36:2	Date: 88	3/08/15	)		
Group#	3	Record#	18			
File na	ame: SLI	00502				
Power e	supply:	4.9793	Volts	DC		
Cable#	1	007043	Volts	DC	-11.5	Micro-Strains
Cable#	Z	+.001698	Volts	ÐC	+16.8	Micro-Strains
Cable#	3	+.000942	Volts	DC	+11.1	Micro-Strains
Cable#	4	001516	Volts	ÐC	-21.7	Micro-Strains
Cable#	5	001031	Volts	DC	-8,6	Micro-Strains
Cable#	6	004130	Volts	DC	-35.3	Micro-Strains
Cable#	7	000899	Volts	DC	+6.0	Micro-Strains
Cable#	8	001908	Volts	DC	+25.5	Micro-Strains
Cable#	9	001315	Volts	DC	+.3	Micro-Strains
Cable#	10	+.002769	Volts	DC	-4.2	Micro-Strains
Cable#	11	+.003530	Volts	DC	-3.4	Micro-Strains
Cable#	12	000036	Volts	DC	-1.6	Micro-Strains
Cable#	13	~.001368	Volts	DC	-10.6	Micro-Strains
Cable#	14	004253	Volts	DC	-30.1	Micro-Strains
Cable#	15	004319	Volts	DC	+4.1	Micro-Strains
Cable#	16	001398	Volts	DC	+16.0	Micro-Strains
Cable#	17	- ,003037	Volts	DC	+18.5	Micro-Strains
Cable#	18	003277	Volts	DC	+39.1	Micro-Strains
Cable#	19	-,003389	Volts	DC	-20.5	Micro-Strains
Cable#	20	003446	Volts	DC	-47.9	Micro-Strains
Cable#	21	002084	Volts	DC	+14.6	Micro-Strains
Cable#	22	+.002895	Volts	DC	+18.1	Micro-Strains
Cable#	23	002006	Volts	DC	-20.0	Micro-Strains
Cable#	24	001722	Volts	DC	-36.7	Micro-Strains
Cable#	25	002611	Volts	DC	+1.0	Micro-Strains

LVDT: -0.063483 VDC 0.000007 Inches

Hor. Rad.=.005183 VDC 341.4 W/M^2

Position #9 LT

Time: 12:3	37:59 Date: 80	3/08/19	3		
Group# 3	Record#	19			
File name:	SLDØSØ2				
Power supp	oly: 4.9796	Volte	DC		
Cable#	007060	Volts	DC	-18.3	Micro-Strains
Cable# 2	+.001688	Volts	DC	+12.7	Micro-Strains
Cable# 3	+,000963	Volts	DC	+19.6	Micro-Strains
Cable# 4	001503	Volts	DC	-16.3	Micro-Strains
Cable# 5	001022	Volts	DC	-4.9	Micro-Strains
Cable# 6	004179	Volts	DC	-55.2	Micro-Strains
Cable# 7	-,000906	Volts	DC	+3,2	Micro-Strains
Cable# 8	001855	Volts	DC	+47.1	Micro-Strains
Cable# 9	-,001309	Volts	DC	+2.8	Micro-Strains
Cable# 10	+.002760	Volts	DC	-7.9	Micro-Strains
Cable# 11	+.003525	Volts	DC	-5.5	Micro-Strains
Cable# 12	000025	Volts	ÐC	+2,8	Micro-Strains
Cable# 13	001352	Volts	DC	-4.1	Micro-Strains
Cable# 14	004210	Volts	DC	-12.7	Micro-Strains
Cable# 15	004330	Volts	DC	2	Micro-Strains
Cable# 16	001389	Volts	DC	+19.7	Micro-Strains
Cable# 17	-,003071	Volts	DC	+5.0	Micro-Strains
Cable# 18	003257	Volts	DC	+47.1	Micro-Strains
Cable# 19	003395	Volts	DC	-22.8	Micro-Strains
Cable# 20	003463	Volts	DC	-54.6	Micro-Strains
Cable# 21	002083	Volts	DC	+15.0	Micro-Strains
Cable# 22	+.002900	Volts	DC	+20.0	Micro-Strains
Cable# 23	002008	Volts	DC	-20.8	Micro-Strains
Cable# 24	001728	Volts	ÐC	-39,0	Micro-Strains
Cable# 25	002612	Volts	DC	+.7	Micro-Strains

LVDT: -0.063564 VDC 0.000011 Inches

Hor. Rad.=.005038 VDC 331.9 W/M^2

Position #8 LT

12:39:21	3 Date: 88	3/08/19	)		
3	Record#	20			
ame: SLI	00502				
supply:	4,9798	Volts	DC		
1	007076	Volts	DC	-24.7	Micro-Strains
2	+.001680	Volts	DC	+9.4	Micro-Strains
3	+.000986	Volts	DC	+28.9	Micro-Strains
4	001492	Volts	DC	-11.8	Micro-Strains
5	001018	Volts	DC	-3.3	Micro-Strains
6	004234	Volts	DC	-77.5	Micro-Strains
7	000908	Volts	DC	+2.4	Micro-Strains
8	001793	Volts	DC	+72.4	Micro-Strains
9	001305	Volts	DC	+4.4	Micro-Strains
10	+.002755	Volts	DC	-10.0	Micro-Strains
11	+.003522	Volts	DC	-6.8	Micro-Strains
12	000020	Volts	DC	+4.8	Micro-Strains
13	001344	Volts	DC	8	Micro-Strains
14	004186	Volts	DC	-3.0	Micro-Strains
15	004337	Volts	DC	-3.0	Micro-Strains
16	-,001382	Volts	DC	+22.5	Micro-Strains
17	003093	Volts	DC	-3.7	Micro-Strains
18	003238	Volts	DC	+54,7	Micro-Strains
19	-,003400	Volts	DC	-24.7	Micro-Strains
20	-,003477	Volts	DC	-60.1	Micro-Strains
21	002081	Volts	DC	+15.8	Micro-Strains
22	+.002905	Volts	DC	+21.9	Micro-Strains
23	002010	Volts	DC	-21.5	Micro-Strains
24	001733	Volts	DC	-41.0	Micro-Strains
25	002613	Volts	DC	+.3	Micro-Strains
	12:39:21 3 ame: SLI supply: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25	12:39:28  Date: 88    3  Record#    ame: SLD0S02    supply:  4.9798    1 007076    2  +.001680    3  +.000986    4 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001492    5 001493    9 001305    10  +.002755    11  +.003522    12 004337    14 001344    14 003393    18 003400    20 003400    20 003400    20 003400    20 002081    22  +.002905    23 002010    24  .002010<	12:39:28  Date:  88/08/19    3  Record#  20    supply:  4.9798  Volts    1 007076  Volts    2  +.001680  Volts    3  +.000986  Volts    3  +.000986  Volts    3  +.000986  Volts    3  +.000986  Volts    5 001018  Volts    5 001018  Volts    6 004234  Volts    7 000908  Volts    8 001793  Volts    9 001305  Volts    10  +.002755  Volts    11  +.003522  Volts    12 000020  Volts    13 001344  Volts    14 004337  Volts    15 004337  Volts    16 003238  Volts    17 003400  Volts    18 003400  Volts    20 002081  Volts	12:39:28Date: $88/08/19$ 3Record# $20$ ame:SLD0S02supply: $4.9798$ VoltsDC1 $007076$ VoltsDC2 $+.001680$ VoltsDC3 $+.000986$ VoltsDC4 $001492$ VoltsDC5 $001018$ VoltsDC6 $004234$ VoltsDC7 $000908$ VoltsDC8 $001793$ VoltsDC9 $001305$ VoltsDC9 $001305$ VoltsDC10 $+.002755$ VoltsDC11 $+.003522$ VoltsDC12 $000020$ VoltsDC13 $001344$ VoltsDC14 $004337$ VoltsDC15 $004337$ VoltsDC16 $003093$ VoltsDC17 $003093$ VoltsDC18 $003400$ VoltsDC20 $003477$ VoltsDC21 $002081$ VoltsDC23 $002010$ VoltsDC24 $001733$ VoltsDC25 $002613$ VoltsDC	12:39:28Date: $88/08/19$ 3Record#20ame:SLDØSØ2supply: $4.9798$ VoltsDC1 $007076$ VoltsDC2 $+.001680$ VoltsDC3 $+.000986$ VoltsDC4 $001492$ VoltsDC5 $001018$ VoltsDC5 $001018$ VoltsDC7 $000908$ VoltsDC7 $000908$ VoltsDC7 $000908$ VoltsDC7 $000908$ VoltsDC7 $000908$ VoltsDC7 $0009020$ VoltsDC11 $+.002755$ VoltsDC14 $001305$ VoltsDC15 $000020$ VoltsDC16 $001382$ VoltsDC15 $004337$ VoltsDC16 $001382$ VoltsDC17 $003093$ VoltsDC18 $003238$ VoltsDC20 $003400$ VoltsDC21 $002081$ VoltsDC23 $002010$ VoltsDC24 $001733$ VoltsDC24 $001733$ VoltsDC25 $002613$ VoltsDC41.0 $002613$ VoltsDC

LVDT: -0,063226 VDC -0.000006 Inches

Hor. Rad.=.004711 VDC 310.3 W/M^2

Position #7 LT

Time: 1	2:40:57	7 Date: 80	3/08/19	3		
Group#	3	Record#	21			
File na	ime: SLE	DØSØ2				
Power s	upply:	4.9799	Volts	DC		
Cable#	t	007080	Volts	DC	-26.2	Micro-Strains
Cable#	2	+.001673	Volts	DC	+6.6	Micro-Strains
Cable#	3	+,000995	Volts	DC	+32.6	Micro-Strains
Cable#	4	-,001484	Volts	DC	-8.6	Micro-Strains
Cable#	5	001016	Volts	DC	-2.5	Micro-Strains
Cable#	6	004259	Volts	DC	-87.7	Micro-Strains
Cable#	7	000913	Volts	DC	+.4	Micro-Strains
Cable#	8	001766	Volts	DC	+83.4	Micro-Strains
Cable#	9	001305	Volts	DC	+4,4	Micro-Strains
Cable#	10	+.002754	Volts	ÐC	-10.4	Micro-Strains
Cable#	11	+.003521	Volts	DC	-7.2	Micro-Strains
Cable#	12	000019	Volts	DC	+5.2	Micro-Strains
Cable#	13	001337	Volts	DC	+2.0	Micro-Strains
Cable#	14	004171	Volts	DC	+3.1	Micro-Strains
Cable#	15	-,004342	Volts	DC	-4.9	Micro-Strains
Cable#	16	-,001379	Volts	DC	+23.7	Micro-Strains
Cable#	17	003105	Volts	DC	-8.4	Micro-Strains
Cable#	18	003227	Volts	DC	+59.1	Micro-Strains
Cable#	19	003403	Volts	DC	-25.9	Micro-Strains
Cable#	20	-,003485	Volts	QC	-63.3	Micro-Strains
Cable#	21	002080	Volts	DC	+16.Z	Micro-Strains
Cable#	22	+,002908	Volts	ÐC	+23.1	Micro-Strains
Cable#	23	002008	Volts	DC	-20.7	Micro-Strains
Cable#	24	001735	Volts	DC	-41,8	Micro-Strains
Cable#	25	002614	Volts	DC	- 1	Micro-Strains

LVDT: -0.063270 VDC -0.000003 Inches

Hor. Rad.=.004669 VDC 307.6 W/M^2

Position #6 LT

Time: 1	2:42:1	7 Date: 80	3708719	3		
Group#	3	Record#	22			
File na	me: SLI	00502				
Power s	upply:	4,9801	Volts	DC		
Cable#	1	007065	Volts	DC	-20.0	Micro-Strains
Cable#	2	+,001667	Volts	DC	+4.1	Micro-Strains
Cable#	3	+.000978	Volts	DC	+25.6	Micro-Strains
Cable#	4	001478	Volts	DC	-6.1	Micro-Strains
Cable#	5	001013	Volts	DC	-1.2	Micro-Strains
Cable#	6	004207	Volts	DC	-66.4	Micro-Strains
Cable#	7	000914	Volts	DC	-,Ø	Micro-Strains
Cable#	8	001813	Volts	ĐC	+64.3	Micro-Strains
Cable#	9	001306	Volts	DC	+4.0	Micro-Strains
Cable#	10	+,002756	Volts	DC	-9.7	Micro-Strains
Cable#	11	+.003522	Volts	DC	-6.8	Micro-Strains
Cable#	12	- ,	Volts	DC	+4,8	Micro-Strains
Cable#	13	001332	Volts	DC	+4.0	Micro-Strains
Cable#	14	004164	Volts	DC	+6.0	Micro-Strains
Cable#	15	004343	Volts	DC	-5.3	Micro-Strains
Cable#	16	001380	Volts	DC	+23.3	Micro-Strains
Cable#	17	-,003110	Volts	DC	-10.4	Micro-Strains
Cable#	18	-,003224	Volts	DC	+60,4	Micro-Strains
Cable#	19	-,003401	Volts	DC	-25.1	Micro-Strains
Cable#	2Ø	003485	Volts	DC	-63.2	Micro-Strains
Cable#	Z 1	002079	Volts	DC	+16.7	Micro-Strains
Cable#	22	+,002911	Volts	DC	+24.3	Micro-Strains
Cable#	23	002005	Volts	DC	-19.5	Micro-Strains
Cable#	24	001735	Volts	DC	-41.7	Micro-Strains
Cable#	25	002615	Volts	DC	4	Micro-Strains

LVDT: -0.063002 VDC -0.000017 Inches

Hor, Rad.=.004759 VDC 313.5 W/M^2

Position #5 LT

Time: 12	2:43:41	Date: 88	3/08/19	3		
Group#	3	Record#	23			
File nam	ne: SLE	)ØSØZ				
Power su	-pply:	4.9800	Volts	DC		
Cable#	1	007040	Volts	DC	-9.9	Micro-Strains
Cable#	2	+.001662	Volts	DC	+2.1	Micro-Strains
Cable#	3	+.000952	Volts	DC	+15.1	Micro-Strains
Cable#	4	-,001472	Volts	DC	-3.7	Micro-Strains
Cable#	5	001012	Volts	DC	8	Micro-Strains
Cable#	6	004138	Volts	DC	-38.3	Micro-Strains
Cable#	7	-,000915	Volts	DC	- , 4	Micro-Strains
Cable#	8	001879	Volts	DC	+37.4	Micro-Strains
Cable#	9	001308	Volts	DC	+3.2	Micro-Strains
Cable# 1	10	+.002759	Volts	DC	-8.4	Micro-Strains
Cable#	11	+.003523	Volts	DC	-6.4	Micro-Strains
Cable# 1	12	- , 00002 3	Volts	DC	+3.6	Micro-Strains
Cable#	13	001333	Volts	DC	+3.6	Micro-Strains
Cable# 1	14	004163	Volts	DC	+6.4	Micro-Strains
Cable#	15	004343	Volts	DC	-5.3	Micro-Strains
Cable#	16	001384	Volts	DC	+21.7	Micro-Strains
Cable# 3	17	003110	Volts	DC	-10.4	Micro-Strains
Cable#	18	003235	Volts	DC	+56.0	Micro-Strains
Cable#	19	003395	Volts	DC	-22.7	Micro-Strains
Cable# 2	20	003472	Volts	DC	-58.1	Micro-Strains
Cable# 2	21	002078	Volts	DC	+17.1	Micro-Strains
Cable# 2	22	+,002911	Volts	DC	+24.3	Micro-Strains
Cable# 2	23	002003	Volts	DC	-18.7	Micro-Strains
Cable# 2	2.4	001731	Volts	DC	-40.2	Micro-Strains
Cable# 2	25	002615	Volts	DC	5	Micro-Strains

LVDT: -0.062942 VDC -0.000020 Inches

Hor. Rad.=.004933 VDC 325.0 W/M^2

Position #4 LT

Time: 12:45:	03 Date: 88	3/08/19	3		
Group# 3	Record#	24			
File name: S	LDØSØ2				
Power supply	: 4,9802	Volts	DC		
Cable# 1	007022	Volts	DC	-2,4	Micro-Strains
Cable# 2	+.001661	Volts	DC	+1.6	Micro-Strains
Cable# 3	+.000932	Volts	DC	+6.9	Micro-Strains
Cable# 4	001471	Volts	DC	-3.3	Micro-Strains
Cable# 5	001013	Volts	DC	-1.2	Micro-Strains
Cable# 6	004090	Volts	DC	-18.7	Micro-Strains
Cable# 7	000915	Volts	DC	- , 4	Micro-Strains
Cable# 8	001923	Volts	DC	+19.5	Micro-Strains
Cable# 9	001310	Volts	DC	+2,4	Micro-Strains
Cable# 10	+,002763	Volts	DC	-6.9	Micro-Strains
Cable# 11	+.003525	Volts	DC	-5.7	Micro-Strains
Cable# 12	000027	Volts	DC	+2.0	Micro-Strains
Cable# 13	001335	Volts	DC	+2.8	Micro-Strains
Cable# 14	004165	Volts	DC	+5.6	Micro-Strains
Cable# 15	004342	Volts	DC	-4.8	Micro-Strains
Cable# 16	001398	Volts	DC	+16.1	Micro-Strains
Cable# 17	003106	Volts	DC	-8.7	Micro-Strains
Cable# 18	-,003264	Volts	DC	+44.5	Micro-Strains
Cable# 19	003382	Volts	DC	-17.5	Micro-Strains
Cable# 20	003443	Volts	DC	-46.5	Micro-Strains
Cable# 21	002080	Volts	DC	+16.3	Micro-Strains
Cable# 22	+.002910	Volts	DC	+23.8	Micro-Strains
Cable# 23	001997	Volts	DC	-16.3	Micro-Strains
Cable# 24	-,001724	Volts	DC	-37.3	Micro-Strains
Cable# 25	002616	Volts	DC	8	Micro-Strains

LVDT: -0.062925 VDC -0.000021 Inches

Hor. Rad.=.005180 VDC 341.2 W/M^2

Position #3 LT

Time: 1	2:46:31	3 Date: 88	3/08/19	}		
Group#	3	Record#	25			
File na	ame: SEL	00502				
Power s	supply:	4.9804	Volts	ÐC		
Cable#	1	007010	Volts	DC	+2.6	Micro-Strains
Cable#	2	+.001659	Volts	DC	+,8	Micro-Strains
Cable#	3	+.000919	Volts	DC	+1.6	Micro-Strains
Cable#	4	001470	Volts	DC	-2.8	Micro-Strains
Cable#	5	001014	Volts	DC	-1.6	Micro-Strains
Cable#	6	-,004058	Volts	DC	-5.6	Micro-Strains
Cable#	7	000914	Volts	DC	+,Ø	Micro-Strains
Cable#	8	001952	Volts	DC	+7.8	Micro-Strains
Cable#	9	001313	Volts	DC	+1.2	Micro-Strains
Cable#	10	+,002767	Volts	DC	-5.3	Micro-Strains
Cable#	11	+.003527	Volts	DC	-4.9	Micro-Strains
Cable#	12	000032	Volts	DC	+.Ø	Micro-Strains
Cable#	13	001337	Volts	DC	+2.0	Micro-Strains
Cable#	14	004170	Volts	DC	+3.7	Micro-Strains
Cable#	15	004339	Volts	DC	-3.6	Micro-Strains
Cable#	16	001415	Volts	DC	+9.3	Micro-Strains
Cable#	17	003102	Volts	DC	-7.1	Micro-Strains
Cable#	18	003308	Volts	DC	+27.1	Micro-Strains
Cable#	19	003368	Volts	DC	-11.9	Micro-Strains
Cable#	20	003400	Volts	DC	-29.4	Micro-Strains
Cable#	21	002080	Volts	DC	+16.3	Micro-Strains
Cable#	22	+.002908	Volts	DC	+23.0	Micro-Strains
Cable#	23	001992	Volts	DC	-14.3	Micro-Strains
Cable#	24	001716	Volts	DC	-34.1	Micro-Strains
Cable#	25	002617	Volts	DC	-1.2	Micro-Strains

LVDT: -0.062864 VDC -0.000024 Inches

Hor. Rad.=.004963 VDC 326.9 W/M^2

Position #2 LT

Time: 12:52:0	B Date: 88/08/	19		
Group# 3	Record# 26			
File name: SL	DØSØ2			
Power supply:	4.9805 Volt	s DC		
Cable# 1	007004 Volt	s DC	+5.1	Micro-Strains
Cable# 2	+.001660 Volt	s DC	+1.2	Micro-Strains
Cable# 3	+.000909 Volt	s DC	-2.5	Micro-Strains
Cable# 4	-,001470 Volt	s DC	-2.8	Micro-Strains
Cable# 5	001015 Volt	s DC	~2.Ø	Micro-Strains
Cable# 6	004039 Volt	s DC	+2.1	Micro-Strains
Cable# 7	-,000913 Volt	s DC	+,4	Micro-Strains
Cable# 8	001971 Volt	s DC	+.0	Micro-Strains
Cable# 9	001315 Volt	s DC	+,4	Micro-Strains
Cable# 10	+.002770 Volt	s DC	-4.1	Micro-Strains
Cable# 11	+.003529 Volt	s DC	-4.1	Micro-Strains
Cable# 12	-,000034 Volt	s DC	8	Micro-Strains
Cable# 13	001336 Volt	s DC	+2.4	Micro-Strains
Cable# 14	-,004172 Volt	s DC	+2.9	Micro-Strains
Cable# 15	004338 Volt	s DC	-3.1	Micro-Strains
Cable# 16	001430 Volt	s DC	+3.3	Micro-Strains
Cable# 17	-,003094 Volt	s DC	-3.9	Micro-Strains
Cable# 18	-,003363 Volt	s DC	+5.2	Micro-Strains
Cable# 19	003352 Volt	s DC	~5.5	Micro-Strains
Cable# 20	003352 Volt	s DC	-10.3	Micro-Strains
Cable# 21	-,007083 Volt	s DC	+15.1	Micro-Strains
Cable# 22	+.002905 Volt	s DC	+21.8	Micro-Strains
Cable# 23	001985 Volt	s DC	-11.5	Micro-Strains
Cable# 24	-,001698 Volt	s DC	-27.0	Micro-Strains
Cable# 25	002619 Volt	s DC	-2.Ø	Micro-Strains

LVDT: -0.062574 VDC -0.000039 Inches

Hor. Rad.=.004549 VDC 299.7 W/M^2

Position #1 LT

,

12:53:1	7 Date: 8{	3/08/19	)		
3	Record#	27			
ame: SLI	00502				
supply:	4.9806	Volts	DC		
1	- ,007000	Volts	DC	+6.7	Micro-Strains
2	+.001658	Volts	ÐC	+,4	Micro-Strains
3	+.000905	Volts	DC	-4.1	Micro-Strains
4	001468	Volts	DC	-2,0	Micro-Strains
5	001014	Volts	DC	-1.6	Micro-Strains
6	004032	Volts	DC	+5.0	Micro-Strains
7	000914	Volts	DC	+.0	Micro-Strains
8	001978	Volts	DC	-2.8	Micro-Strains
9	001315	Volts	DC	+,4	Micro-Strains
10	+.002770	Volts	DC	-4,1	Micro-Strains
11	+,003530	Volts	DC	-3.7	Micro-Strains
12	-,000035	Volts	DC	-1.2	Micro-Strains
13	001338	Volts	DC	+1.7	Micro-Strains
14	-,004174	Volts	DC	+2.1	Micro-Strains
15	-,004336	Volts	DC	-2.3	Micro-Strains
16	001438	Volts	DC	+,Ø	Micro-Strains
17	003091	Volts	DC	-2.7	Micro-Strains
18	003382	Volts	DC	-2.3	Micro-Strains
19	003343	Volts	DC	-1.9	Micro-Strains
20	003332	Volts	DC	-2,3	Micro-Strains
21	002085	Volts	DC	+14.4	Micro-Strains
22	+.002897	Volts	DC	+18.6	Micro-Strains
23	001981	Volts	DC	-9.9	Micro-Strains
24	001679	Volts	DC	-19.4	Micro-Strains
25	002619	Volts	DC	-2,0	Micro-Strains
	12:53:1' ame: SLI supply: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25	12:53:17  Date: 81    3  Record#    ame: SLDØSØ2    5upply:  4.9806    1 007000    2  +.001658    3  +.000905    4 001468    5 001014    6 001014    7 000914    8 001978    9 001315    10  +.002770    11  +.002770    11  +.002770    12 000035    13 001338    14 004436    15 001438    16 001438    17 003091    18 003382    19 003332    21 00285    22  +.002897    23 001579    25 002619	12:53:17Date: $88/08/19$ 3Record#27ame:SLDØSØ2supply:4.9806Volts1007000Volts2+.001658Volts3+.000905Volts4001468Volts5001014Volts6004032Volts7000914Volts8001315Volts9001315Volts10+.002770Volts11+.003530Volts12000035Volts13001338Volts14004436Volts15001438Volts16003391Volts17003343Volts18002085Volts20002332Volts21002897Volts23001981Volts24001679Volts25002619Volts	12:53:17Date: $88/08/19$ 3Record# $27$ ame:SLDØSØ2supply: $4.9806$ VoltsDC1 $007000$ VoltsDC2 $+.001658$ VoltsDC3 $+.000905$ VoltsDC4 $001468$ VoltsDC5 $001014$ VoltsDC6 $004032$ VoltsDC7 $000914$ VoltsDC8 $001978$ VoltsDC9 $001315$ VoltsDC10 $+.002770$ VoltsDC11 $+.003530$ VoltsDC12 $000035$ VoltsDC13 $001338$ VoltsDC14 $0044374$ VoltsDC15 $004336$ VoltsDC16 $001438$ VoltsDC17 $003091$ VoltsDC18 $003342$ VoltsDC20 $002857$ VoltsDC21 $002897$ VoltsDC23 $001679$ VoltsDC24 $002619$ VoltsDC25 $002619$ VoltsDC	12:53:17  Date: 88/08/19    3  Record#  27    ame: SLD0S02  Supply:  4.9806  Volts DC    1 007000  Volts DC  +.4    3  +.000905  Volts DC  -4.1    4 001468  Volts DC  -4.1    4 001468  Volts DC  -1.6    5 001014  Volts DC  +.5.0    7 000914  Volts DC  +.4    8 001978  Volts DC  +.16    6 004032  Volts DC  +.28    9 001978  Volts DC  +.28    9 001315  Volts DC  -2.8    9 001315  Volts DC  -4.1    11  +.002770  Volts DC  -4.1    12 0003530  Volts DC  -4.1    14 00270  Volts DC  -1.2    13 001338  Volts DC  -2.3    14 004336  Volts DC  -2.3    15 0043382  Volts DC  -2.7

LVDT: -0.061977 VDC -0.000069 Inches

Hor. Rad.=.004567 VDC 300.9 W/M^2

Position #0 LT

Time:	12:54:2	0 Date: 88	3/08/19	9		
Group#	3	Record#	28			
File na	ame: SL	DØSØ2				
Power :	supply:	4,9808	Volts	DC		
Cable#	1	007001	Volts	DC	+6.4	Micro-Strains
Cable#	2	+.001661	Volts	DC	+1.5	Micro-Strains
Cable#	3	+.000905	Volts	DC	-4.1	Micro-Strains
Cable#	4	001471	Volts	DC	-3.2	Micro-Strains
Cable#	5	001017	Volts	DC	-2.8	Micro-Strains
Cable#	6	004031	Volts	DC	+5.5	Micro-Strains
Cable#	7	000912	Volts	DC	+.9	Micro-Strains
Cable#	8	001979	Volts	DC	-3.2	Micro-Strains
Cable#	9	001317	Volts	DC	-,3	Micro-Strains
Cable#	10	+.002771	Volts	DC	-3.8	Micro-Strains
Cable#	11	+.003531	Volts	DC	-3.4	Micro-Strains
Cable#	12	000036	Volts	DC	-1.6	Micro-Strains
Cable#	13	001338	Volts	ÐC	+1.7	Micro-Strains
Cable#	14	-,004174	Volts	DC	+2.2	Micro-Strains
Cable#	15	004336	Volts	DC	-2.2	Micro-Strains
Cable#	16	001441	Volts	DC	-1.1	Micro-Strains
Cable#	17	003092	Volts	DC	-3.0	Micro-Strains
Cable#	18	003382	Volts	DC	-2.2	Micro-Strains
Cable#	19	003340	Volts	DC	6	Micro-Strains
Cable#	20	003331	Volts	DC	-1.8	Micro-Strains
Cable#	21	002087	Volts	DC	+13.6	Micro-Strains
Cable#	22	+.002885	Volts	DC	+13.8	Micro-Strains
Cable#	23	001974	Volts	DC	-7.1	Micro-Strains
Cable#	24	001655	Volts	DC	-9.9	Micro-Strains
Cable#	25	002619	Volts	DC	-1.9	Micro-Strains

LVDT: -0.061980 VDC -0.000069 Inches

Hor. Rad.=.004557 VDC 300.2 W/M^2

Position #OFF BRIDGE

Time: 1	2:56:27	7 Date: 80	3/08/19	]		
Group#	3	Record#	29			
File na	me: SLD	DØSØ2				
Power s	upply:	4.9811	Volts	DC		
Cable#	1	007002	Volts	DC	+6.2	Micro-Strains
Cable#	2	+.001660	Volts	DC	+1.1	Micro-Strains
Cable#	3	+.000904	Volts	DC	-4.5	Micro-Strains
Cable#	4	001470	Volts	DC	-2.7	Micro-Strains
Cable#	5	001016	Volts	DC	-2.4	Micro-Strains
Cable#	6	004034	Volts	DC	+4.4	Micro-Strains
Cable#	7	000912	Volts	DC	+,9	Micro-Strains
Cable#	8	001977	Volts	ÐC	-Z.3	Micro-Strains
Cable#	9	001316	Volts	DC	+.1	Micro-Strains
Cable#	10	+.002771	Volts	DC	-3.8	Micro-Strains
Cable#	11	+.003531	Volts	DC	-3.5	Micro-Strains
Cable#	12	000036	Volts	DC	-1.6	Micro-Strains
Cable#	13	001336	Volts	DC	+2.5	Micro-Strains
Cable#	14	004173	Volts	DC	+2.7	Micro-Strains
Cable#	15	004336	Volts	DC	-2.1	Micro-Strains
Cable#	16	-,001441	Volts	DC	-1.1	Micro-Strains
Cable#	17	003092	Volts	DC	-3.0	Micro-Strains
Cable#	18	003382	Volts	DC	-2.1	Mícro-Strains
Cable#	19	003340	Volts	DC	6	Micro-Strains
Cable#	20	003330	Volts	DC	-1.4	Micro-Strains
Cable#	Z 1	002088	Volts	DC	+13.3	Micro-Strains
Cable#	22	+.002876	Volts	DC	+10.1	Micro-Strains
Cable#	23	001969	Volts	DC	-5.0	Micro-Strains
Cable#	24	001638	Volts	DC	-3.1	Micro-Strains
Cable#	25	002619	Volts	DC	-1.8	Micro-Strains

LVDT: -0.061606 VDC -0.000088 Inches

Hor. Rad.=.004436 VDC 292.2 W/M^2

## MOORE CREEK BRIDGE PROJECT

Date: 89/08/01 File name: SRU0S03 Date: 88/08/19 Record# 1 Time: 13:10:12 Group# 1 TEMPERATURE PROFILE OF GIRDER: 12.1 Deg.C Thermistor# 1 13.4 Deg.C Thermistor# - 2 Thermistor# 3 13.4 Deg.C Thermistor# 4 13.3 Dec.C Thermistor# 5 13.1 Deg.C Thermistor# 6 12.7 Deg.C 7 Thermistor# 12.7 Deg.C Thermistor# 8 245.2 Deg.C Instrument | Temp: 17.96 Dec.C 2 Temp: 18.94 Deq.C Instrument ZERO STRAIN VOLTAGES: Record# 2 Time: 13:15:44 Group# 2 Power supply: 4,98110 Volts DC -.007014 Volts DC Cable# 1 +.001667 Volts DC Cable# 2 +.000911 Volts DC Cable# 3 -.001471 Volts DC Cable# 4 Cable# 5 -.001019 Volts DC -,004046 Volts DC Cable# 6 Cable# 7 -.000910 Volts DC Cable# 8 -.001969 Volts DC -.001315 Volts DC Cable# 9 Cable# 10 +,002773 Volts DC +.003531 Volts DC Cable# 11 -,000032 Volts DC Cable# 12 -.001345 Volts DC Cable# 13 -.004181 Volts DC Cable# 14 Cable# 15 -.004331 Volts DC -.001436 Volts DC Cable# 16 -.003084 Volts DC Cable# 17 Cable# 18 -,003383 Volts DC -.003336 Volts DC Cable# 19 -.003324 Volts DC Cable# 20 -.002092 Volts DC Cable# 21 +,002866 Volts DC Cable# 22 -.001964 Volts DC Cable# 23 -.001628 Volts DC Cable# 24 Cable# 25 -.002624 Volts DC LVDT: -0.062518 VDC 822.1 W/M^2 Hor, Rad. = 1.2E-2 VDC Air Temp= 14.0 Deg.C Wind Speed: 9.4 MPH

Position #0 RT

Time: 13:17:5	4 Date: 88	3/08/19	<u>)</u>		
Group# 3	Record#	3			
File name: SR	UØSØ3				
Power supply:	4,9813	Volts	DC		
Cable# 1	007025	Volts	DC	-4.4	Micro-Strains
Cable# 2	+.001671	Volts	DC	+1.6	Micro-Strains
Cable# 3	+.000914	Volts	DC	+1.2	Micro-Strains
Cable# 4	001472	Volts	DC	4	Micro-Strains
Cable# 5	001020	Volts	DC	4	Micro-Strains
Cable# 6	004058	Volts	DC	-4.8	Micro-Strains
Cable# 7	000909	Volts	DC	+.4	Micro-Strains
Cable# 8	001962	Volts	DC	+2.9	Micro-Strains
Cable# 9	-,001314	Volts	DC	+,4	Micro-Strains
Cable# 10	+.002777	Volts	DC	+1.6	Micro-Strains
Cable# 11	+,003534	Volts	DC	+1.2	Micro-Strains
Cable# 12	- , ØØØØ3Ø	Volts	DC	+,8	Micro-Strains
Cable# 13	001357	Volts	DC	-4.8	Micro-Strains
Cable# 14	-,004192	Volts	DC	-4.4	Micro-Strains
Cable# 15	004325	Volts	DC	+2.5	Micro-Strains
Cable# 16	001433	Volts	DC	+1.2	Micro-Strains
Cable# 17	003078	Volts	DC	+2.4,	Micro-Strains
Cable# 18	003385	Volts	DC	7	Micro-Strains
Cable# 19	003336	Volts	DC	+ 1	Micro-Strains
Cable# 20	003322	Volts	DC	+.8	Micro-Strains
Cable# 21	002092	Volts	DC	+.Ø	Micro-Strains
Cable# 22	+.002856	Volts	DC	-4,0	Micro-Strains
Cable# 23	001969	Volts	DC	-2.0	Micro-Strains
Cable# 24	001626	Volts	DC	+,8	Micro-Strains
Cable# 25	002626	Volts	DC	8	Micro-Strains

LVDT: -0,060909 VDC -0.000081 Inches

Hor. Rad.=.009508 VDC 626.4 W/M^2

Position #1 RT

Time:	3:19:44	1 Date: 88	3/08/19	)		
Group#	3	Record#	4			
File na	ame: SRL	JØSØ3				
Power :	supply:	4.9810	Volts	DC		
Cable#	1	007030	Volts	DC	-6.6	Micro-Strains
Cable#	2	+.001672	Volts	DC	+2.0	Micro-Strains
Cable#	3	+.000916	Volts	DC	+2.0	Micro-Strains
Cable#	4	001471	Volts	DC	Ø	Micro-Strains
Cable#	5	001019	Volts	DC	Ø	Micro-Strains
Cable#	6	004064	Volts	DC	-7.4	Micro-Strains
Cable#	7	-,000910	Volts	DC	0	Micro-Strains
Cable#	8	001959	Volts	DC	+4.1	Micro-Strains
Cable#	9	001314	Volts	DC	+ 4	Micro-Strains
Cable#	10	+.002779	Volts	DC	+2.4	Micro-Strains
Cable#	11	+.003534	Volts	DC	+1.2	Micro-Strains
Cable#	12	-,000029	Volts	DC	+1.2	Micro-Strains
Cable#	13	001359	Volts	DC	-5.6	Micro-Strains
Cable#	14	004195	Volts	DC	-5,7	Micro-Strains
Cable#	15	004325	Volts	DC	+2.4	Micro-Strains
Cable#	16	-,001434	Volts	DC	+.8	Micro-Strains
Cable#	17	003077	Volts	DC	+2.8	Micro-Strains
Cable#	18	003386	Volts	DC	-1.2	Micro-Strains
Cable#	19	003338	Volts	DC	-,8	Micro-Strains
Cable#	20	003323	Volts	DC	+.4	Micro-Strains
Cable#	Z 1	002087	Volts	DC	+2.0	Micro-Strains
Cable#	22	+.002858	Volts	DC	-3.2	Micro-Strains
Cable#	23	001984	Volts	DC	-8.0	Micro-Strains
Cable#	Z 4	001631	Volts	DC	-1,2	Micro-Strains
Cable#	25	002627	Volts	DC	-1.Z	Micro-Strains

LVDT: -0.060218 VDC -0.000115 Inches

Hor, Rad.=.007229 VDC 476.2 W/M^2

Position #2 RT

Time:	13:21:22	2 Date: 88	3/08/19	<u>}</u>		
Group#	3	Record#	5			
File na	ame: SRL	JØSØ3				
Power	supply:	4.9812	Volts	DC		
Cable#	1	007039	Volts	DC	-10.1	Micro-Strains
Cable#	2	+.001673	Volts	DC	+2.4	Micro-Strains
Cable#	3	+,000925	Volts	DC	+5.7	Micro-Strains
Cable#	4	001474	Volts	DC	-1.2	Micro-Strains
Cable#	5	001022	Volts	DC	-1.Z	Micro-Strains
Cable#	6	-,004070	Volts	DC	-9.7	Micro-Strains
Cable#	7	000909	Volts	DC	+,4	Micro-Strains
Cable#	8	001954	Volts	ÐC	+6.1	Micro-Strains
Cable#	9	001314	Volts	DC	+,4	Micro-Strains
Cable#	10	+.002778	Volts	DC	+2.0	Micro-Strains
Cable#	11	+.003533	Volts	DC	+.8	Micro-Strains
Cable#	12	- , ØØØØ2 9	Volts	DC	+1.2	Micro-Strains
Cable#	13	001359	Volts	DC	-5.6	Micro-Strains
Cable#	14	004194	Volts	DC	-5.2	Micro-Strains
Cable#	15	004325	Volts	DC	+2,4	Micro-Strains
Cable#	16	001416	Volts	DC	+8.1	Micro-Strains
Cable#	17	003077	Volts	DC	+2.8	Micro-Strains
Cable#	18	- ,003379	Volts	DC	+1.6	Micro-Strains
Cable#	19	003358	Volts	DC	-8.7	Micro-Strains
Cable#	20	003333	Volts	DC	-3.5	Micro-Strains
Cable#	21	002083	Volts	DC	+3.6	Micro-Strains
Cable#	22	+.002860	Volts	DC	-2.4	Micro-Strains
Cable#	23	001997	Volts	DC	-13.1	Micro-Strains
Cable#	24	001637	Volts	DC	-3.6	Micro-Strains
Cable#	25	002627	Volts	DC	-1.Z	Micro-Strains

LVDT: -0.059875 VDC -0.000134 Inches

Hor. Rad.=.008554 VDC 563.5 W/M^2

Position #3 RT

Time: 13:2	23:01 Date: 80	3/08/19		
Group# 3	Record#	6		
File name:	SRUØSØ3			
Power supp	oly: 4.9812	Volts DC		
Cable# 1	007059	Volts DC	-18.3	Micro-Strains
Cable# 2	+.001672	Volts DC	+2.0	Micro-Strains
Cable# 3	+.000944	Volts DC	+13.4	Micro-Strains
Cable# 4	001472	Volts DC	-,4	Micro-Strains
Cable# 5	001022	Volts DC	-1.2	Micro-Strains
Cable# 6	- ,004081	Volts DC	-14.2	Micro-Strains
Cable# 7	000909	Volts DC	+,4	Micro-Strains
Cable# 8	001943	Volts DC	+10.6	Micro-Strains
Cable# 9	001310	Volts DC	+2.0	Micro-Strains
Cable# 10	+.002775	Volts DC	+ 8	Micro-Strains
Cable# 11	+.003530	Volts DC	-,4	Micro-Strains
Cable# 12	000028	Volts DC	+1.6	Micro-Strains
Cable# 13	001353	Volts DC	-3.2	Micro-Strains
Cable# 14	-,004193	Volts DC	-4.8	Micro-Strains
Cable# 15	004331	Volts DC	+,Ø	Micro-Strains
Cable# 16	001368	Volts DC	+27.4	Micro-Strains
Cable# 17	003079	Volts DC	+2.0	Micro-Strains
Cable# 18	003360	Volts DC	+9.2	Micro-Strains
Cable# 19	003402	Volts DC	-26.2	Micro-Strains
Cable# 20	003349	Volts DC	-9.9	Micro-Strains
Cable# 21	002080	Volts DC	+4.8	Micro-Strains
Cable# 22	+.002862	Volts DC	-1.6	Micro-Strains
Cable# 23	002009	Volts DC	-17.9	Micro-Strains
Cable# 24	- , 001643	Volts DC	-5.9	Micro-Strains
Cable# 25	002627	Volts DC	-1.2	Micro-Strains
LVDT: -Ø.4	059774 VDC	-0.000139	Inches	

Hor. Rad.=.007748 VDC 510.4 W/M^2

Position #4 RT

Time:	13:27:16	5 Date: 80	3/08/19			
Group#	3	Record#	7			
File na	ame: SRL	JØSØ3				
Power :	supply:	4.9813	Volts	DC		
Cable#	1	007089	Volts	DC	-30.4	Micro-Strains
Cable#	2	+.001674	Volts	DC	+2.8	Micro-Strains
Cable#	3	+.000976	Volts	DC	+26.4	Micro-Strains
Cable#	4	001473	Volts	DC	8	Micro-Strains
Cable#	5	001025	Volts	DC	-2.4	Micro-Strains
Cable#	6	004097	Volts	DC	-2Ø.7	Micro-Strains
Cable#	7	000907	Volts	DC	+1.2	Micro-Strains
Cable#	8	001927	Volts	DC	+17.1	Micro-Strains
Cable#	9	001308	Volts	DC	+2.8	Micro-Strains
Cable#	10	+.002774	Volts	DC	+.4	Micro-Strains
Cable#	11	+.003527	Volts	DC	-1.7	Micro-Strains
Cable#	12	000027	Volts	DC	+2.0	Micro-Strains
Cable#	13	001352	Volts	DC	-2.8	Micro-Strains
Cable#	14	004192	Volts	DC	-4.4	Micro-Strains
Cable#	15	004335	Volts	DC	-1.5	Micro-Strains
Cable#	16	001328	Volts	DC	+43.5	Micro-Strains
Cable#	17	003080	Volts	DC	+1.6	Micro-Strains
Cable#	18	003343	Volts	DC	+16.0	Micro-Strains
Cable#	19	003441	Volts	DC	-41.7	Micro-Strains
Cable#	20	003365	Volts	DC	-16.2	Micro-Strains
Cable#	21	002077	Volts	DC	+6.0	Micro-Strains
Cable#	22	+.002864	Volts	DC	8	Micro-Strains
Cable#	23	002019	Volts	DC	-21.8	Micro-Strains
Cable#	24	001649	Volts	DC	-8.3	Micro-Strains
Cable#	25	002631	Volts	DC	-2.8	Micro-Strains

LVDT: -0.059570 VDC -0.000149 Inches

Hor. Rad.=.005417 VDC 356.9 W/M^2
Position #5 RT

Time: 1	3:28:5	Date: 88	3/08/19	)		
Group#	3	Record#	8			
File na	ame: SR(	JØSØ3				
Power :	supply:	4.9815	Volts	DC		
Cable#	1	007136	Volts	DC	-49.4	Micro-Strains
Cable#	2	+.001673	Volts	DC	+2.4	Micro~Strains
Cable#	3	+.001022	Volts	DC	+45.1	Micro-Strains
Cable#	4	001475	Volts	DC	-1.6	Micro-Strains
Cable#	5	001028	Volts	DC	-3.6	Micro-Strains
Cable#	6	004118	Volts	DC	-29.2	Micro-Strains
Cable#	7	000904	Volts	DC	+2.5	Micro-Strains
Cable#	8	001908	Volts	DC	+24.9	Micro-Strains
Cable#	9	001302	Volts	DC	+5.3	Micro-Strains
Cable#	10	+.002771	Volts	00	9	Micro-Strains
Cable#	11	+.003523	Volts	DC	-3.3	Micro-Strains
Cable#	12	000026	Volts	DC	+2.4	Micro-Strains
Cable#	13	001348	Volts	DC	-1.2	Micro-Strains
Cable#	14	004189	Volts	DC	-3.1	Micro-Strains
Cable#	15	004339	Volts	DC	-3.1	Micro-Strains
Cable#	16	001302	Volts	DC	+54.0	Micro-Strains
Cable#	17	003081	Volts	DC	+1.3	Micro-Strains
Cable#	18	003330	Volts	DC	+21.2	Micro-Strains
Cable#	19	003469	Volts	DC	-52.7	Micro-Strains
Cable#	20	003378	Volts	DC	-21.4	Micro-Strains
Cable#	Z 1	002074	Volts	DC	+7.2	Micro-Strains
Cable#	22	+.002865	Volts	DC	5	Micro-Strains
Cable#	23	002026	Volts	DC	-24.6	Micro-Strains
Cable#	24	001653	Volts	DC	-9.9	Micro-Strains
Cable#	25	002630	Volts	DC	-2.4	Micro-Strains

LVDT: -0.059586 VDC -0.000148 Inches

Hor. Rad.=.007673 VDC 505.5 W/M^2

Position #6 RT

Time: 1	13:30:21	5 Date: 88	3/08/19	3		
Group#	3	Record#	9			
File na	ame: SRl	JØSØ3				
Power e	supply:	4.9818	Volts	DC		
Cable#	1	007203	Volts	DC	-76.5	Micro-Strains
Cable#	2	+.001675	Volts	DC	+3.2	Micro-Strains
Cable#	3	+.001093	Volts	DC	+74.0	Micro-Strains
Cable#	4	001476	Volts	DC	-2.0	Micro-Strains
Cable#	5	001033	Volts	DC	-5.6	Micro-Strains
Cable#	6	004145	Volts	DC	-40.1	Micro-Strains
Cable#	7	000900	Volts	DC	+4.1	Micro-Strains
Cable#	8	001882	Volts	DC	+35.5	Micro-Strains
Cable#	9	001300	Volts	DC	+6.1	Micro-Strains
Cable#	10	+.002769	Volts	DC	-1.8	Micro-Strains
Cable#	11	+.003520	Volts	DC	-4.6	Micro-Strains
Cable#	12	000025	Volts	DC	+2.8	Micro-Strains
Cable#	13	001350	Volts	DC	-1.9	Micro-Strains
Cable#	14	004191	Volts	DC	-3.8	Micro-Strains
Cable#	15	004340	Volts	DC	-3.4	Micro-Strains
Cable#	16	~.001292	Volts	DC	+58.0	Micro-Strains
Cable#	17	003081	Volts	DC	+1.4	Micro-Strains
Cable#	18	003326	Volts	00	+22.8	Micro-Strains
Cable#	19	003481	Volts	DC	-57.4	Micro-Strains
Cable#	20	003385	Volts	DC	-24.1	Micro-Strains
Cable#	21	002074	Volts	DC	+7.3	Micro-Strains
Cable#	22	+.002863	Volts	DC	-1.4	Micro-Strains
Cable#	23	002030	Volts	DC	-26.1	Micro-Strains
Cable#	24	001654	Volts	DC	-10.2	Micro-Strains
Cable#	25	002630	Volts	DC	-2.3	Micro-Strains

LVDT: -0.059684 VDC -0.000143 Inches

Hor. Rad.=.006355 VDC 418.6 W/M^2

Position #7 RT

Time:	3:35:2	8 Date: 80	3/ <b>0</b> 8/19	3		
Group#	3	Record#	10			
File na	ame: SRI	UØSØ3				
Power :	supply:	4.9821	Volts	DC		
Cable#	1	007253	Volts	DC	-96.7	Micro-Strains
Cable#	2	+.001676	Volts	DC	+3.5	Micro-Strains
Cable#	3	+.001141	Volts	DC	+93.5	Micro-Strains
Cable#	4	001480	Volts	DC	-3.5	Micro-Strains
Cable#	5	001041	Volts	DC	-8.9	Micro-Strains
Cable#	6	004164	Volts	DC	-47.7	Micro-Strains
Cable#	7	000896	Volts	DC	+5.8	Micro-Strains
Cable#	8	001867	Volts	DC	+41.7	Micro-Strains
Cable#	9	001301	Volts	DC	+5.8	Micro-Strains
Cable#	10	+.002768	Volts	DC	-2.2	Micro-Strains
Cable#	11	+.003517	Volts	DC	-5.9	Micro-Strains
Cable#	12	000027	Volts	DC	+2.0	Micro-Strains
Cable#	13	001355	Volts	DC	-3.9	Micro-Strains
Cable#	14	004193	Volts	DC	-4.5	Micro-Strains
Cable#	15	004337	Volts	DC	-2.1	Micro-Strains
Cable#	16	001297	Volts	DC	+56.0	Micro-Strains
Cable#	17	003079	Volts	DC	+2.2	Micro-Strains
Cable#	18	003329	Volts	DC	+21.7	Micro-Strains
Cable#	19	003483	Volts	DC	-58.1	Micro-Strains
Cable#	200	003387	Volts	DC	-24.8	Micro-Strains
Cable#	Z 1	002074	Volts	DC	+7.3	Micro-Strains
Cable#	22	+.002861	Volts	DC	-2.2	Micro-Strains
Cable#	23	002032	Volts	DC	-26.9	Micro-Strains
Cable#	24	001652	Volts	DC	-9.4	Micro-Strains
Cable#	25	002630	Volts	DC	-2.2	Micro-Strains

LVDT: -0.060006 VDC -0.000127 Inches

Hor. Rad.=.005630 VDC 370.9 W/M^2

Position #8 RT

Time:	3:37:19	] Date: 88	3/08/19	]		
Group#	3	Record#	11			
File na	ame: SRI	JØSØ3				
Power :	supply:	4.9825	Volts	DC		
Cable#	1	007232	Volts	DC	-87.9	Micro-Strains
Cable#	2	+.001678	Volts	DC	+4.3	Micro-Strains
Cable#	3	+.001110	Volts	DC	+80.9	Micro-Strains
Cable#	4	001482	Volts	DC	-4.3	Micro-Strains
Cable#	5	001048	Volts	DC	-11.7	Micro-Strains
Cable#	6	004160	Volts	DC	-46.0	Micro-Strains
Cable#	7	000890	Volts	DC	+8.3	Micro-Strains
Cable#	8	001876	Volts	DC	+38.1	Micro-Strains
Cable#	9	001302	Volts	DC	+5.4	Micro-Strains
Cable#	10	+.002768	Volts	DC	-2.3	Micro-Strains
Cable#	11	+.003518	Volts	DC	-5.7	Micro-Strains
Cable#	12	000029	Volts	DC	+1.2	Micro-Strains
Cable#	13	001371	Volts	DC	-10.3	Micro-Strains
Cable#	14	004201	Volts	DC	-7.6	Micro-Strains
Cable#	15	004326	Volts	DC	+2.5	Micro-Strains
Cable#	16	001307	Volts	DC	+52.1	Micro-Strains
Cable#	17	003075	Volts	DC	+3.9	Micro-Strains
Cable#	18	003336	Volts	DC	+19.1	Micro-Strains
Cable#	19	003475	Volts	DC	-54.8	Micro-Strains
Cable#	2 <b>0</b>	003383	Volts	DC	-23.1	Micro-Strains
Cable#	21	002077	Volts	DC	+6.2	Micro-Strains
Cable#	22	+.002854	Volts	DC	-5.1	Micro-Strains
Cable#	23	002030	Volts	DC	-26.0	Micro-Strains
Cable#	24	001647	Volts	DC	-7.4	Micro-Strains
Cable#	25	002630	Volts	DC	-2.1	Micro-Strains

LVDT: -0.060182 VDC -0.000118 Inches

Hor. Rad.=.005394 VDC 355.3 W/M^2

Position #9 RT

Time:	13:42:26	5 Date: 88	3/08/19	3		
Group#	3	Record#	12			
File na	ame: SRI	Jøsøj				
Power :	supply:	4.9826	Volts	DC		
Cable#	1	007178	Volts	DC	-65.9	Micro-Strains
Cable#	2	+.001682	Volts	DC	+5.9	Micro-Strains
Cable#	3	+.001046	Volts	DC	+54.8	Micro-Strains
Cable#	4	001487	Volts	DC	-6.3	Micro-Strains
Cable#	5	001060	Volts	DC	-16.6	Micro-Strains
Cable#	6	004142	Volts	DC	-38.6	Micro-Strains
Cable#	7	000881	Volts	DC	+11.9	Micro-Strains
Cable#	8	001898	Volts	DC	+29.1	Micro-Strains
Cable#	9	001311	Volts	DC	+1.8	Micro-Strains
Cable#	10	+.002773	Volts	DC	3	Micro-Strains
Cable#	11	+.003523	Volts	DC	-3.7	Micro-Strains
Cable#	12	000035	Volts	DC	-1.2	Micro-Strains
Cable#	13	001397	Volts	DC	-20.7	Micro-Strains
Cable#	14	004211	Volts	DC	-11.6	Micro-Strains
Cable#	15	004303	Volts	DC	+11.8	Micro-Strains
Cable#	16	001324	Volts	DC	+45.2	Micro-Strains
Cable#	17	003064	Volts	DC	+8.3	Micro-Strains
Cable#	18	003346	Volts	DC	+15.1	Micro-Strains
Cable#	19	003463	Volts	DC	-50.0	Micro-Strains
Cable#	20	003378	Volts	DC	-21.1	Micro-Strains
Cable#	21	002079	Volts	DC	+5.4	Micro-Strains
Cable#	22	+.002854	Volts	DC	-5.1	Micro-Strains
Cable#	23	002028	Volts	DC	-25.2	Micro-Strains
Cable#	24	001644	Volts	DC	-6.2	Micro-Strains
Cable#	25	002630	Volts	DC	-2.1	Micro-Strains

LVDT: -0.060661 VDC -0.000094 Inches

Hor. Rad.=.005251 VDC 345.9 W/M^2

Position #10 RT

Time	13:44:22	Date: 88	3/08/15	}					
Group#	3	Record#	13						
File na	File name: SRU0S03								
Power a	supply:	4.9825	Volts	DC					
Cable#	1	007130	Volts	DC	-46.4	Micro-Strains			
Cable#	2	+.001684	Volts	DC	+6.7	Micro-Strains			
Cable#	3	+.000991	Volts	DC	+32.4	Micro-Strains			
Cable#	4	001493	Volts	DC	-8.8	Micro-Strains			
Cable#	5	001072	Volts	DC	-21.5	Micro-Strains			
Cable#	6	004121	Volts	DC	-30.1	Micro-Strains			
Cable#	7	000872	Volts	DC	+15.6	Micro-Strains			
Cable#	8	001922	Volts	DC	+19.3	Micro-Strains			
Cable#	9	001322	Volts	DC	-2.7	Micro-Strains			
Cable#	10	+.002776	Volts	DC	+.9	Micro-Strains			
Cable#	11	+.003529	Volts	DC	-1.2	Micro-Strains			
Cable#	12	000043	Volts	DC	-4.4	Micro-Strains			
Cable#	13	001436	Volts	DC	-36.4	Micro-Strains			
Cable#	14	004222	Volts	DC	-16.0	Micro-Strains			
Cable#	15	004272	Volts	DC	+24.2	Micro-Strains			
Cable#	16	001345	Volts	DC	+36.8	Micro-Strains			
Cable#	17	003057	Volts	DC	+11.1	Micro-Strains			
Cable#	18	003357	Volts	DC	+10.7	Micro-Strains			
Cable#	19	003446	Volts	DC	-43.3	Micro-Strains			
Cable#	2 <b>0</b>	003370	Volts	DC	-17.9	Micro-Strains			
Cable#	21	002078	Volts	DC	+5.8	Micro-Strains			
Cable#	22	+.002855	Volts	DC	-4.7	Micro-Strains			
Cable#	23	002027	Volts	DC	-24.8	Micro-Strains			
Cable#	24	001644	Volts	DC	-6.2	Micro-Strains			
Cable#	25	002630	Volts	DC	-2.1	Micro-Strains			

LVDT: -0.060851 VDC -0.000084 Inches

Hor. Rad.=.004688 VDC 308.8 W/M^2

8-41

Position #11 RT

Time: 1	3:46:14	4 Date: 88	3/08/19	3		
Group#	3	Record#	14			
File na	ame: SRI	JØSØ3				
Power :	supply:	4.9823	Volts	DC		
Cable#	1	007094	Volts	DC	-31.9	Micro-Strains
Cable#	2	+.001690	Volts	DC	+9.2	Micro-Strains
Cable#	3	+.000949	Volts	DC	+15.4	Micro-Strains
Cable#	4	001502	Volts	DC	-12.5	Micro-Strains
Cable#	5	001089	Volts	DC	-28.4	Micro-Strains
Cable#	6	004102	Volts	DC	-22.4	Micro-Strains
Cable#	7	000860	Volts	DC	+20.5	Micro-Strains
Cable#	8	001942	Volts	DC	+11.2	Micro-Strains
Cable#	9	001340	Volts	DC	-10.0	Micro-Strains
Cable#	10	+.002783	Volts	DC	+3.8	Micro-Strains
Cable#	11	+.003542	Volts	DC	+4.1	Micro-Strains
Cable#	12	000052	Volts	DC	-8.1	Micro-Strains
Cable#	13	001467	Volts	DC	-48.9	Micro-Strains
Cable#	14	004230	Volts	DC	-19.3	Micro-Strains
Cable#	15	004251	Volts	DC	+32.6	Micro-Strains
Cable#	16	001366	Volts	DC	+28.3	Micro-Strains
Cable#	17	003054	Volts	DC	+12.2	Micro-Strains
Cable#	18	003368	Volts	DC	+6.3	Micro-Strains
Cable#	19	003429	Volts	DC	-36.6	Micro-Strains
Cable#	20	003361	Volts	DC	-14.4	Micro-Strains
Cable#	21	002078	Volts	DC	+5.8	Micro-Strains
Cable#	22	+.002854	Volts	DC	-5.0	Micro-Strains
Cable#	23	002022	Volts	DC	-22.8	Micro-Strains
Cable#	24	001640	Volts	DC	-4.6	Micro-Strains
Cable#	25	002630	Volts	ÐC	-2.2	Micro-Strains

LVDT: -0.060822 VDC -0.000086 Inches

,

Hor. Rad.=.005079 VDC 334.6 W/M^2

Position #12 RT

Time	13:47:2	9 Date: 88	3/08/19	3		
Group#	3	Record#	15			
File na	ame: SR	UØSØ3				
Power :	supply:	4.9825	Volts	DC		
Cable#	1	007068	Volts	DC	-21.2	Micro-Strains
Cable#	2	+.001696	Volts	00	+11.6	Micro-Strains
Cable#	3	+.000916	Volts	DC	+1.9	Micro-Strains
Cable#	4	001509	Volts	DC	-15.3	Micro-Strains
Cable#	5	001107	Volts	DC	-35.7	Micro-Strains
Cable#	6	004089	Volts	DC	-17.0	Micro-Strains
Cable#	7	000846	Volts	DC	+26.2	Micro-Strains
Cable#	8	001958	Volts	DC	+4.7	Micro-Strains
Cable#	9	001362	Volts	DC	-18.8	Micro-Strains
Cable#	10	+.002792	Volts	DC	+7.4	Micro-Strains
Cable#	11	+.003559	Volts	DC	+10.9	Micro-Strains
Cable#	12	000062	Volts	DC	-12.1	Micro-Strains
Cable#	13	001448	Volts	DC	-41.2	Micro-Strains
Cable#	14	004224	Volts	DC	-16.8	Micro-Strains
Cable#	15	004267	Volts	DC	+26.2	Micro-Strains
Cable#	16	~.001386	Volts	DC	+20.3	Micro-Strains
Cable#	17	003059	Volts	DC	+10.3	Micro-Strains
Cable#	18	003378	Volts	DC	+2.4	Micro-Strains
Cable#	19	003412	Volts	DC	-29.8	Micro-Strains
Cable#	20	003354	Volts	DC	-11.5	Micro-Strains
Cable#	21	002080	Volts	DC	+5.0	Micro-Strains
Cable#	22	+.002853	Volts	DC	-5.5	Micro-Strains
Cable#	23	002017	Volts	DC	-20.8	Micro-Strains
Cable#	24	001637	Volts	DC	-3.4	Micro-Strains
Cable#	25	002631	Volts	DC	-2.6	Micro-Strains

LVDT: -0.060753 VDC -0.000089 Inches

Hor. Rad.=.005779 VDC 380.7 W/M^2

Position #13 RT

Time:	3:49:Ø	0 Date: 88	B/ <b>0</b> 8/19	3		
Group#	3	Record#	16			
File na	ame: SRI	JØSØ3				
Power :	supply:	4.9822	Volts	DC		
Cable#	1	007050	Volts	DC	-14.0	Micro-Strains
Cable#	2	+.001703	Volts	DC	+14.5	Micro-Strains
Cable#	3	+.000893	Volts	DC	-7.4	Micro-Strains
Cable#	4	001519	Volts	DC	-19.4	Micro-Strains
Cable#	5	001127	Volts	DC	-43.9	Micro-Strains
Cable#	6	004077	Volts	DC	-12.3	Micro-Strains
Cable#	7	000831	Volts	DC	+32.3	Micro-Strains
Cable#	8	001970	Volts	DC	2	Micro-Strains
Cable#	9	001391	Volts	DC	-30.6	Micro-Strains
Cable#	10	+.002803	Volts	DC	+11.9	Micro-Strains
Cable#	11	+.003581	Volts	DC	+19.9	Micro-Strains
Cable#	12	000075	Volts	DC	-17.4	Micro-Strains
Cable#	13	001416	Volts	DC	-28.4	Micro-Strains
Cable#	14	004212	Volts	DC	-12.1	Micro-Strains
Cable#	15	004298	Volts	DC	+13.7	Micro-Strains
Cable#	16	001401	Volts	DC	+14.2	Micro-Strains
Cable#	17	003069	Volts	DC	+6.2	Micro-Strains
Cable#	18	003387	Volts	DC	-1.3	Micro-Strains
Cable#	19	003400	Volts	DC	-25.1	Micro-Strains
Cable#	20	003348	Volts	DC	-9.2	Micro-Strains
Cable#	21	002080	Volts	DC	+5.0	Micro-Strains
Cable#	22	+.002852	Volts	DC	-5.8	Micro-Strains
Cable#	23	002012	Volts	DC	-18.9	Micro-Strains
Cable#	24	001635	Volts	DC	-2.6	Micro-Strains
Cable#	25	002630	Volts	DC	-2.2	Micro-Strains

LVDT: -0.060534 VDC -0.000100 Inches

Hor. Rad.=.005707 VDC 376.0 W/M^2

Position #14 RT

Time:	13:50:22	2 Date: 88	3/08/19	)		
Group#	3	Record#	17			
File na	ame: SRI	Jøsø3				
Power :	supply:	4.9822	Volts	DC		
Cable#	1	007037	Volts	DC	-8.7	Micro-Strains
Cable#	Z	+.001709	Volts	DC	+16.9	Micro-Strains
Cable#	3	+.000876	Volts	DC	-14.3	Micro-Strains
Cable#	4	001527	Volts	DC	-22.7	Micro-Strains
Cable#	5	001145	Volts	DC	-51.2	Micro-Strains
Cable#	6	004069	Volts	DC	-9.0	Micro-Strains
Cable#	7	000816	Volts	DC	+38.4	Micro-Strains
Cable#	8	001980	Volts	DC	-4.3	Micro-Strains
Cable#	9	001427	Volts	DC	-45.1	Micro-Strains
Cable#	10	+.002815	Volts	DC	+16.7	Micro-Strains
Cable#	11	+.003609	Volts	DC	+31.2	Micro-Strains
Cable#	12	000090	Volts	DC	-23.4	Micro-Strains
Cable#	13	001388	Volts	DC	-17.2	Micro-Strains
Cable#	14	004204	Volts	DC	-8.9	Micro-Strains
Cable#	15	004327	Volts	ÐC	+2.0	Micro-Strains
Cable#	16	001416	Volts	DC	+8.2	Micro-Strains
Cable#	17	003080	Volts	DC	+1.9	Micro-Strains
Cable#	18	003392	Volts	DC	-3.3	Micro-Strains
Cable#	19	003389	Volts	DC	-20.8	Micro-Strains
Cable#	20	003343	Volts	DC	-7.3	Micro-Strains
Cable#	21	002081	Volts	DC	+4.6	Micro-Strains
Cable#	22	+.002854	Volts	DC	-5.0	Micro-Strains
Cable#	23	002007	Volts	DC	-16.9	Micro-Strains
Cable#	24	001633	Volts	ÐC	-1.8	Micro-Strains
Cable#	25	002630	Volts	DC	-2.2	Micro-Strains

LVDT: -0.060492 VDC -0.000102 Inches

Hor. Rad.=.005720 VDC 376.8 W/M^2

Position #15 RT

Time:	13:52	:10 Date: 88	3/08/19	)		
Group#	3	Record#	18			
File n	ame:	SRUØSØ3				
Power	suppl	y: 4.9823	Volts	DC		
Cable#	1	007029	Volts	DC	-5.4	Micro-Strains
Cable#	2	+.001714	Volts	DC	+19.0	Micro-Strains
Cable#	3	+.000866	Volts	DC	-18.4	Micro-Strains
Cable#	4	001535	Volts	ÐC	-25.9	Micro-Strains
Cable#	5	001162	Volts	DC	-58.2	Micro-Strains
Cable#	6	004063	Volts	DC	-6.5	Micro-Strains
Cable#	7	000804	Volts	DC	+43.3	Micro-Strains
Cable#	8	001986	Volts	DC	-6.7	Micro-Strains
Cable#	9	001478	Volts	DC	-65.7	Micro-Strains
Cable#	10	+.002831	Volts	DC	+23.2	Micro-Strains
Cable#	11	+.003649	Volts	DC	+47.3	Micro-Strains
Cable#	12	000106	Volts	DC	-29.9	Micro-Strains
Cable#	13	001372	Volts	DC	-10.7	Micro-Strains
Cable#	14	004197	Volts	DC	-6.0	Micro-Strains
Cable#	15	004345	Volts	DC	-5.2	Micro-Strains
Cable#	16	001427	Volts	DC	+3.8	Micro-Strains
Cable#	17	003089	Volts	DC	-1.7	Micro-Strains
Cable#	18	003399	Volts	DC	-6.0	Micro-Strains
Cable#	19	003381	Volts	DC	-17.6	Micro-Strains
Cable#	ZØ	003340	Volts	DC	-6.0	Micro-Strains
Cable#	21	002082	Volts	DC	+4.2	Micro-Strains
Cable#	22	+.002855	Volts	DC	-4.6	Micro-Strains
Cable#	23	002001	Volts	DC	-14.5	Micro-Strains
Cable#	24	001631	Volts	DC	-1.0	Micro-Strains
Cable#	Z5	002630	Volts	DC	-2.2	Micro-Strains

LVDT: -0.060424 VDC -0.000106 Inches

Hor. Rad.=.005639 VDC 371.5 W/M^2

Position #16 RT

Time: 13:5	53:47 Date: 80	8/08/19	3		
Group# 3	Record#	19			
File name	: SRUØSØ3				
Power supp	⊐ly: 4.9822	Volts	DC		
Cable# 1	007027	Volts	DC	-4.7	Micro-Strains
Cable# Z	+.001716	Volts	DC	+19.8	Micro-Strains
Cable# 3	+.000862	Volts	DC	-20.0	Micro-Strains
Cable# 4	001539	Volts	DC	-27.5	Micro-Strains
Cable# 5	001174	Volts	DC	-63.1	Micro-Strains
Cable# 6	004061	Volts	ÐC	-5.7	Micro-Strains
Cable# 7	000797	Volts	DC	+46.1	Micro-Strains
Cable# 8	001989	Volts	DC	-8.0	Micro-Strains
Cable# 9	001511	Volts	DC	-79.0	Micro-Strains
Cable# 10	+.002839	Volts	DC	+26.4	Micro-Strains
Cable# 11	+.003675	Volts	DC	+57.8	Micro-Strains
Cable# 12	000114	Volts	DC	-33.1	Micro-Strains
Cable# 13	001363	Volts	DC	-7.1	Micro-Strains
Cable# 14	004193	Volts	DC	-4.5	Micro-Strains
Cable# 15	004355	Volts	DC	-9.3	Micro-Strains
Cable# 16	001436	Volts	DC	+.1	Micro-Strains
Cable# 17	003093	Volts	DC	-3.3	Micro-Strains
Cable# 18	003402	Volts	DC	-7.3	Micro-Strains
Cable# 19	003373	Volts	DC	-14.4	Micro-Strains
Cable# 20	003336	Volts	DC	-4.5	Micro-Strains
Cable# 21	002081	Volts	DC	+4.6	Micro-Strains
Cable# 22	+.002855	Volts	DC	-4.6	Micro-Strains
Cable# 23	001995	Volts	DC	-12.1	Micro-Strains
Cable# 24	001627	Volts	DC	+.5	Micro-Strains
Cable# 25	002630	Volts	DC	-2,2	Micro-Strains

LVDT: -0.060334 VDC -0.000110 Inches

Hor. Rad.=.005938 VDC 391.2 W/M^2

Position #17 RT

Time: 1	3:55:35	5 Date: 88	3/08/19	]		
Group#	3	Record#	20			
File na	ame: SRU	JØSØ3				
Power s	supply:	4.9824	Volts	DC		
Cable#	1	007028	Volts	DC	-5.0	Micro-Strains
Cable#	2	+.001718	Volts	DC	+20.6	Micro-Strains
Cable#	3	+.000862	Volts	DC	-20.0	Micro-Strains
Cable#	4	001543	Volts	DC	-29.1	Micro-Strains
Cable#	5	001181	Volts	DC	-65.9	Micro-Strains
Cable#	6	004060	Volts	DC	-5.3	Micro-Strains
Cable#	7	000792	Volts	DC	+48.2	Micro-Strains
Cable#	8	001989	Volts	DC	-7.9	Micro-Strains
Cable#	9	001491	Volts	DC	-70.9	Micro-Strains
Cable#	10	+.002831	Volts	DC	+23.1	Micro-Strains
Cable#	11	+.003652	Volts	DC	+48.5	Micro-Strains
Cable#	12	000110	Volts	DC 00	-31.5	Micro-Strains
Cable#	13	001359	Volts	DC	-5.5	Micro-Strains
Cable#	14	004191	Volts	DC	-3.6	Micro-Strains
Cable#	15	004360	Volts	DC	-11.2	Micro-Strains
Cable#	16	001444	Volts	DC	-3.1	Micro-Strains
Cable#	17	003096	Volts	DC	-4.4	Micro-Strains
Cable#	18	003406	Volts	DC	-8.8	Micro-Strains
Cable#	19	003367	Volts	DC	-12.0	Micro-Strains
Cable#	20	~.003334	Volts	DC	-3.6	Micro-Strains
Cable#	21	002082	Volts	DC	+4.2	Micro-Strains
Cable#	22	+.002857	Volts	DC	-3.9	Micro-Strains
Cable#	23	001988	Volts	DC	-9.3	Micro-Strains
Cable#	24	001625	Volts	DC	+1.4	Micro-Strains
Cable#	25	002631	Volts	DC	-2.6	Micro-Strains

LVDT: -0.060042 VDC -0.000125 Inches

Hor. Rad.=.005405 VDC 356.1 W/M^2

Position #18 RT

Time:	13:57:3	1 Date: 88	3/08/19	3		
Group#	3	Record#	21			
File na	ame: SRI	JØSØ3				
Power :	supply:	4.9825	Volts	DC		
Cable#	1	007031	Volts	DC	-6.1	Micro-Strains
Cable#	2	+.001716	Volts	DC	+19.8	Micro-Strains
Cable#	3	+.000865	Volts	DC	-18.8	Micro-Strains
Cable#	4	001540	Volts	DC	-27.9	Micro-Strains
Cable#	5	001181	Volts	DC	-65.9	Micro-Strains
Cable#	6	004062	Volts	DC	-6.1	Micro-Strains
Cable#	7	000796	Volts	DC	+46.5	Micro-Strains
Cable#	8	001986	Volts	DC	-6.7	Micro-Strains
Cable#	9	001449	Volts	DC	-53.9	Micro-Strains
Cable#	10	+.002814	Volts	DC	+16.2	Micro-Strains
Cable#	11	+.003612	Volts	DC	+32.3	Micro-Strains
Cable#	12	000096	Volts	DC	-25.8	Micro-Strains
Cable#	13	001359	Volts	DC	-5.5	Micro-Strains
Cable#	14	004191	Volts	DC	-3.5	Micro-Strains
Cable#	15	004361	Volts	DC	-11.6	Micro-Strains
Cable#	16	001449	Volts	DC	-5.1	Micro-Strains
Cable#	17	003096	Volts	DC	-4.4	Micro-Strains
Cable#	18	003409	Volts	DC	-10.0	Micro-Strains
Cable#	19	003362	Volts	DC	-10.0	Micro-Strains
Cable#	20	0033333	Volts	DC	-3.2	Micro-Strains
Cable#	21	002084	Volts	DC	+3.4	Micro-Strains
Cable#	22	+.002853	Volts	DC	~5.5	Micro-Strains
Cable#	23	001981	Volts	DC	-6.5	Micro-Strains
Cable#	24	001620	Volts	DC	+3.4	Micro-Strains
Cable#	25	002632	Volts	DC	-3.0	Micro-Strains

LVDT: -0.060031 VDC -0.000126 Inches

Hor. Rad.=.005084 VDC 334.9 W/M^2

Position #19 RT

Time: 13:59:11 Date: 88/08/19	
Geouptt 3 Recordt 22	
File name: CPU/CG/X	
Price name, SRUVSVS	
	77 Minna-Charing
	7.3 Missa Clarks
	7.2 Missey Chains
Lable# 3 +.000869 Volts UL -1	7.2 Micro-Strains
Cable# 4001534 Volts DC -2	5.4 Micro-Strains
Cable# 5001173 Volts DC -E	2.6 Micro-Strains
Cable# 6004062 Volts DC -	6.0 Micro-Strains
Cable# 7000805 Volts DC +4	2.9 Micro-Strains
Cable# 8001984 Volts DC -	5.9 Micro-Strains
Cable# 9001412 Volts DC -3	9.0 Micro-Strains
Cable# 10 +.002798 Volts DC +	9.8 Micro-Strains
Cable# 11 +.003576 Volts DC +1	7.7 Micro-Strains
Cable# 12000083 Volts DC -2	0.6 Micro-Strains
Cable# 13001359 Volts DC -	5.5 Micro-Strains
Cable# 14004189 Volts DC -	2.7 Micro-Strains
Cable# 15004361 Volts DC -1	1.5 Micro-Strains
Cable# 16001453 Volts DC -	6.7 Micro-Strains
Cable# 17003095 Volts DC -	4.0 Micro-Strains
Cable# 18003410 Volts DC -1	0.3 Micro-Strains
Cable# 19003355 Volts DC -	7.1 Micro-Strains
Cable# 20003330 Volts DC -	2.0 Micro-Strains
Cable# 21002085 Volts DC +	3.0 Micro-Strains
Cable# 22 +.002855 Volts DC -	4.7 Micro-Strains
Cable# 23001975 Volts DC -	4.1 Micro-Strains
Cable# 24001619 Volts DC +	3.8 Micro-Strains
Cable# 25002633 Volts DC -	3.3 Micro-Strains

LVDT: -0.059922 VDC -0.000131 Inches

Hor. Rad.=.004903 VDC 323.0 W/M^2

Position #20 RT

Time:	14:01:1	1 Date: 88	3/08/19	3		
Group#	3	Record#	23			
File na	ame: SRI	UØSØ3				
Power :	supply:	4.9829	Volts	DC		
Cable#	1	007038	Volts	DC	-8.7	Micro-Strains
Cable#	2	+.001699	Volts	DC	+12.8	Micro-Strains
Cable#	3	+.000876	Volts	DC	-14.4	Micro-Strains
Cable#	4	001523	Volts	DC	-20.9	Micro-Strains
Cable#	5	001148	Volts	DC	-52.4	Micro-Strains
Cable#	6	004065	Volts	DC	-7.1	Micro-Strains
Cable#	7	000832	Volts	DC	+31.9	Micro-Strains
Cable#	8	001980	Volts	DC	-4.2	Micro-Strains
Cable#	9	001381	Volts	DC	-26.4	Micro-Strains
Cable#	10	+.002786	Volts	DC	+4.8	Micro-Strains
Cable#	11	+.003549	Volts	DC	+6.8	Micro-Strains
Cable#	12	000070	Volts	DC	-15.3	Micro-Strains
Cable#	13	001361	Volts	DC	-6.2	Micro-Strains
Cable#	14	004191	Volts	DC	-3.4	Micro-Strains
Cable#	15	004356	Volts	DC	-9.4	Micro-Strains
Cable#	16	001457	Volts	DC	-8.2	Micro-Strains
Cable#	17	003093	Volts	DC	-3.1	Micro-Strains
Cable#	18	003409	Volts	DC	-9.8	Micro-Strains
Cable#	19	003352	Volts	DC	-5.9	Micro-Strains
Cable#	20	003330	Volts	DC	-1.9	Micro-Strains
Cable#	21	002086	Volts	DC	+2.7	Micro-Strains
Cable#	22	+.002856	Volts	DC	-4.4	Micro-Strains
Cable#	23	001970	Volts	DC	-2.1	Micro-Strains
Cable#	24	001618	Volts	DC	+4.2	Micro-Strains
Cable#	25	002634	Volts	DC	-3.7	Micro-Strains

LVDT: -0.059878 VDC -0.000134 Inches

Hor. Rad.=.005244 VDC 345.5 W/M^2

Position #21 RT

Time:	4:04:5	1 Date: 88	3/08/19	3		
Group#	3	Record#	24			
File na	ame: SRI	JØSØ3				
Power a	supply:	4.9827	Volts	DC		
Cable#	1	007041	Volts	DC	-10.1	Micro-Strains
Cable#	2	+.001686	Volts	DC	+7.5	Micro-Strains
Cable#	3	+.000887	Volts	DC	-9.9	Micro-Strains
Cable#	4	001503	Volts	DC	-12.8	Micro-Strains
Cable#	5	001095	Volts	DC	-30.8	Micro-Strains
Cable#	6	004069	Volts	DC	-8.8	Micro-Strains
Cable#	7	000879	Volts	DC	+12.7	Micro-Strains
Cable#	8	001975	Volts	DC	-2.2	Micro-Strains
Cable#	9	001359	Volts	DC	-17.6	Micro-Strains
Cable#	10	+.002776	Volts	DC	+.9	Micro-Strains
Cable#	11	+.003533	Volts	DC	+.3	Micro-Strains
Cable#	12	000059	Volts	DC	-10.9	Micro-Strains
Cable#	13	001363	Volts	DC	-7.1	Micro-Strains
Cable#	14	004191	Volts	DC	-3.5	Micro-Strains
Cable#	15	004350	Volts	DC	-7.1	Micro-Strains
Cable#	16	001457	Volts	DC	-8.3	Micro-Strains
Cable#	17	003088	Volts	DC	-1.2	Micro-Strains
Cable#	18	003408	Volts	DC	-9.5	Micro-Strains
Cable#	19	003346	Volts	DC	-3.5	Micro-Strains
Cable#	20	003326	Volts	DC	4	Micro-Strains
Cable#	21	002087	Volts	DC	+2.3	Micro-Strains
Cable#	22	+.002856	Volts	DC	-4.3	Micro-Strains
Cable#	23	001966	Volts	DC	~.5	Micro-Strains
Cable#	24	001615	Volts	DC	+5.4	Micro-Strains
Cable#	25	002636	Volts	DC	-4.5	Micro-Strains

LVDT: -0.059853 VDC -0.000135 Inches

Hor. Rad.=.005274 VDC 347.4 W/M^2

Position #22 RT

Time:	14:09:	33 Date: 88	3/08/15	}		
Group#	3	Record#	25			
File na	ame: S	RUØSØ3				
Power :	supply	: 4.9823	Volts	DC		
Cable#	1	007043	Volts	DC	-11.1	Micro-Strains
Cable#	2	+.001673	Volts	DC	+2.3	Micro-Strains
Cable#	3	+.000897	Volts	DC	-5.8	Micro-Strains
Cable#	4	001485	Volts	DC	-5.6	Micro-Strains
Cable#	5	001040	Volts	DC	-8.5	Micro-Strains
Cable#	6	004076	Volts	DC	-11.8	Micro-Strains
Cable#	7	000925	Volts	DC	-6.0	Micro-Strains
Cable#	8	001966	Volts	DC	+1.4	Micro-Strains
Cable#	9	001344	Volts	DC	-11.6	Micro-Strains
Cable#	10	+.002773	Volts	DC	3	Micro-Strains
Cable#	11	+.003527	Volts	DC	-2.0	Micro-Strains
Cable#	12	000053	Volts	DC	-8.5	Micro-Strains
Cable#	13	001369	Volts	DC	-9.5	Micro-Strains
Cable#	14	004199	Volts	DC	-6.8	Micro-Strains
Cable#	15	004339	Volts	DC	-2.8	Micro-Strains
Cable#	16	001455	Volts	DC	-7.5	Micro-Strains
Cable#	17	003081	Volts	DC	+1.5	Micro-Strains
Cable#	18	003406	Volts	DC	-8.8	Micro-Strains
Cable#	19	003344	Volts	DC	-2.9	Micro-Strains
Cable#	2 <b>0</b>	003326	Volts	DC	5	Micro-Strains
Cable#	21	002087	Volts	DC	+2.2	Micro-Strains
Cable#	22	+.002855	Volts	DC	-4.6	Micro-Strains
Cable#	23	001960	Volts	DC	+1.8	Micro-Strains
Cable#	Z 4	001611	Volts	DC	+6.9	Micro-Strains
Cable#	25	002638	Volts	DC	-5.4	Micro-Strains

LVDT: -0.059993 VDC -0.000128 Inches

Hor. Rad.=.005668 VDC 373.4 W/M^2

`

Position #23 RT

Time:	14:11:0	7 Date: 88	3/08/19	3		
Group#	3	Record#	26			
File na	ame: SRI	JØSØ3				
Power a	supply:	4.9825	Volts	DC		
Cable#	1	007039	Volts	DC	-9.4	Micro-Strains
Cable#	2	+.001670	Volts	DC	+1.0	Micro-Strains
Cable#	3	+.000909	Volts	DC	9	Micro-Strains
Cable#	4	001482	Volts	DC	-4.3	Micro-Strains
Cable#	5	001027	Volts	DC	-3.1	Micro-Strains
Cable#	6	004076	Volts	DC	-11.8	Micro-Strains
Cable#	7	000926	Volts	DC	-6.4	Micro-Strains
Cable#	8	001960	Volts	DC	+3.9	Micro-Strains
Cable#	9	001334	Volts	DC	-7.5	Micro-Strains
Cable#	10	+.002772	Volts	DC	7	Micro-Strains
Cable#	11	+.003528	Volts	DC	-1.6	Micro-Strains
Cable#	12	000050	Volts	DC	-7.3	Micro-Strains
Cable#	13	001367	Volts	DC	-8.7	Micro-Strains
Cable#	14	004199	Volts	DC	-6.8	Micro-Strains
Cable#	15	004331	Volts	DC	+.5	Micro-Strains
Cable#	16	001453	Volts	DC	-6.7	Micro-Strains
Cable#	17	003080	Volts	DC	+1.9	Micro-Strains
Cable#	18	003404	Volts	DC	-8.0	Micro-Strains
Cable#	19	003338	Volts	DC	4	Micro-Strains
Cable#	2 <b>0</b>	003324	Volts	DC	+.4	Micro-Strains
Cable#	21	002087	Volts	DC	+2.2	Micro-Strains
Cable#	22	+.002856	Volts	DC	-4.3	Micro-Strains
Cable#	23	001961	Volts	DC	+1.4	Micro-Strains
Cable#	24	001611	Volts	DC	+6.9	Micro-Strains
Cable#	25	002641	Volts	DC	-6.6	Micro-Strains

LVDT: -0.059645 VDC -0.000145 Inches

Hor. Rad.=.005248 VDC 345.7 W/M^2

Position #24 RT

Time	14:14:22	2 Date: 8{	3/08/19	3		
Group#	3	Record#	27			
File na	ame: SRi	JØSØ3				
Power :	supply:	4.9824	Volts	DC		
Cable#	1	007037	Volts	DC	-8.6	Micro-Strains
Cable#	Z	+.001670	Volts	DC	+1.0	Micro-Strains
Cable#	3	+.000916	Volts	DC	+1.9	Micro-Strains
Cable#	4	001480	Volts	DC	-3.5	Micro-Strains
Cable#	5	001025	Volts	DC	-2.3	Micro-Strains
Cable#	6	004076	Volts	DC	-11.8	Micro-Strains
Cable#	7	000919	Volts	DC	-3.6	Micro-Strains
Cable#	8	001955	Volts	DC	+5.9	Micro-Strains
Cable#	9	001326	Volts	DC	-4.3	Micro-Strains
Cable#	10	+.002772	Volts	DC	7	Micro-Strains
Cable#	11	+.003529	Volts	DC	-1.Z	Micro-Strains
Cable#	12	000046	Volts	DC	-5.6	Micro-Strains
Cable#	13	001362	Volts	DC	-6.7	Micro-Strains
Cable#	14	004197	Volts	DC	-6.0	Micro-Strains
Cable#	15	004327	Volts	DC	+2.1	Micro-Strains
Cable#	16	001448	Volts	DC	-4.7	Micro-Strains
Cable#	17	003073	Volts	DC	+4.7	Micro-Strains
Cable#	18	003404	Volts	DC	-8.0	Micro-Strains
Cable#	19	003332	Volts	DC	+1.9	Micro-Strains
Cable#	20	003319	Volts	DC	+2.3	Micro-Strains
Cable#	21	002089	Volts	DC	+1.4	Micro-Strains
Cable#	22	+.002855	Volts	DC	-4.7	Micro-Strains
Cable#	23	001958	Volts	DC	+2.6	Micro-Strains
Cable#	24	001607	Volts	DC	+8.5	Micro-Strains
Cable#	25	002637	Volts	DC	-5.0	Micro-Strains

LVDT: -0.060172 VDC -0.000119 Inches

Hor. Rad.=.009607 VDC 632.9 W/M^2

Position #OFF BRIDGE

Time:	4:17:34	Date: 88	3/08/15	}		
Group#	3	Record#	28			
File na	ame: SRL	10503				
Power s	supply:	4.9827	Volts	DC		
Cable#	1	007036	Volts	DC	-8.0	Micro-Strains
Cable#	Z	+.001670	Volts	DC	+1.0	Micro-Strains
Cable#	3	+.000921	Volts	DC	+3.9	Micro-Strains
Cable#	4	001481	Volts	DC	-3.9	Micro-Strains
Cable#	5	001027	Volts	DC	-3.1	Micro-Strains
Cable#	6	004078	Volts	DC ·	-12.5	Micro-Strains
Cable#	7	000915	Volts	DC	-1.9	Micro-Strains
Cable#	8	001952	Volts	DC	+7.2	Micro-Strains
Cable#	9	001326	Volts	DC	-4.3	Micro-Strains
Cable#	10	+.002773	Volts	DC	4	Micro-Strains
Cable#	11	+.003531	Volts	DC	5	Micro-Strains
Cable#	12	000046	Volts	DC	-5.6	Micro-Strains
Cable#	13	-,001364	Volts	DC	-7.5	Micro-Strains
Cable#	14	004198	Volts	DC	-6.3	Micro-Strains
Cable#	15	004324	Volts	DC	+3.4	Micro-Strains
Cable#	16	001448	Volts	DC	-4.6	Micro-Strains
Cable#	17	003073	Volts	ÐC	+4.8	Micro-Strains
Cable#	18	~.003403	Volts	DC	-7.5	Micro-Strains
Cable#	19	003332	Volts	DC	+2.0	Micro-Strains
Cable#	20	003319	Volts	DC	+2.4	Micro-Strains
Cable#	21	002087	Volts	DC	+2.3	Micro-Strains
Cable#	22	+.002857	Volts	DC	-3.9	Micro-Strains
Cable#	23	001959	Volts	DC	+Z.Z	Micro-Strains
Cable#	24	~.001608	Volts	DC	+8.2	Micro-Strains
Cable#	25	002638	Volts	DC	-5.4	Micro-Strains

LVDT: -0.059679 VDC -0.000144 Inches

.

Hor. Rad.=.004898 VDC 322.7 W/M^2

•

## MOORE CREEK BRIDGE PROJECT

Date: 89/08/01 File name: SCD0S04 Date: 88/08/19 Record# 1 Group# 1 Time: 15:10:11 TEMPERATURE PROFILE OF GIRDER: Thermistor# 1 12.7 Deg.C Thermistor# 2 14.0 Deg.C Thermistor# 3 13.8 Deg.C Thermistor# 4 13.6 Deg.C Thermistor# 5 13.3 Deg.C Thermistor# 6 12.9 Deg.C Thermistor# 7 13.0 Deg.C Thermistor# 8 246.6 Deg.C Instrument | Temp: 17.04 Deg.C Instrument 2 Temp: 17.78 Deg.C ZERO STRAIN VOLTAGES: Record# 2 Time: 15:11:35 Group# 2 Power supply: 4.97880 Volts DC -.007009 Volts DC Cable# 1 +.001662 Volts DC Cable# 2 Cable# 3 +,000913 Volts DC -.001482 Volts DC Cable# 4 Cable# \_ Cable# 6 \_\_\_\_\_7 Cable# 5 -.001025 Volts DC -.004049 Volts DC -.000913 Volts DC -.001967 Volts DC Cable# 8 Cable# 9 -.001321 Volts DC +.002758 Volts DC Cable# 10 +.003527 Volts DC Cable# 11 -.000048 Volts DC Cable# 12 -.001347 Volts DC Cable# 13 -.004181 Volts DC Cable# 14 -.004324 Volts DC Cable# 15 -.001442 Volts DC Cable# 16 -.003083 Volts DC Cable# 17 -.003389 Volts DC Cable# 18 Cable# 19 -.003328 Volts DC -.003323 Volts DC Cable# 20 -.002066 Volts DC Cable# 21 +.002873 Volts DC Cable# 22 -.001968 Volts DC Cable# 23 -.001629 Volts DC Cable# 24 -.002636 Volts DC Cable# 25 LVDT: -0.059698 VDC Hor. Rad.= 3.5E-3 VDC 232.4 W/M^2 Air Temp= 8.8 Deg.C Wind Speed: 10.5 MPH

Position #24 CL

Time: 15:14:0	)4 Date: 88	3/08/19	l –		
Group# 3	Record#	3			
File name: SC	CDØSØ4				
Power supply:	4.9746	Volts	DC		
Cable# 1	007004	Volts	DC	4	Micro-Strains
Cable# Z	+.001660	Volts	DC	2	Micro-Strains
Cable# 3	+.000910	Volts	DC	9	Micro-Strains
Cable# 4	001482	Volts	DC	5	Micro-Strains
Cable# 5	001025	Volts	DC	4	Micro-Strains
Cable# 6	004048	Volts	DC	-1.0	Micro-Strains
Cable# 7	000914	Volts	DC	7	Micro-Strains
Cable# 8	001967	Volts	DC	7	Micro-Strains
Cable# 9	001320	Volts	DC	0	Micro-Strains
Cable# 10	+.002755	Volts	DC	3	Micro-Strains
Cable# 11	+.003521	Volts	DC	-1.2	Micro-Strains
Cable# 12	000050	Volts	DC	8	Micro-Strains
Cable# 13	001346	Volts	DC	1	Micro-Strains
Cable# 14	004177	Volts	DC	+.2	Micro-Strains
Cable# 15	004324	Volts	DC	-1.5	Micro-Strains
Cable# 16	001442	Volts	DC	5	Micro-Strains
Cable# 17	003081	Volts	DC	2	Micro-Strains
Cable# 18	003388	Volts	DC	7	Micro-Strains
Cable# 19	003326	Volts	DC	3	Micro-Strains
Cable# 20	003320	Volts	DC	+.1	Micro-Strains
Cable# 21	002065	Volts	DC	3	Micro-Strains
Cable# 22	+.002870	Volts	DC	2	Micro-Strains
Cable# 23	-,001968	Volts	DC	7	Micro-Strains
Cable# 24	001628	Volts	DC	1	Micro-Strains
Cable# 25	002639	Volts	DC	-2.1	Micro-Strains
LVDT: ~0.0609	18 VDC	0.000	0062	Inches	

Hor. Rad.=.004070 VDC 268.1 W/M^2

Position #23 CL

Time: 1	5:15:55	5 Date: 88	3/08/19	3		
Group#	3	Record#	4			
File na	ame: SCC	00504				
Power s	upply:	4.9735	Volts	DC		
Cable#	1	007005	Volts	DC	-1.4	Micro-Strains
Cable#	2	+.001656	Volts	DC	-1.7	Micro-Strains
Cable#	3	+.000905	Volts	DC	-2.9	Micro-Strains
Cable#	4	001482	Volts	DC	6	Micro-Strains
Cable#	5	001024	Volts	DC	0	Micro-Strains
Cable#	6	004050	Volts	DC	-2.2	Micro-Strains
Cable#	7	000920	Volts	DC	-3.3	Micro-Strains
Cable#	8	001972	Volts	DC	-2.9	Micro-Strains
Cable#	9	001324	Volts	DC	-1.8	Micro-Strains
Cable#	10	+.002752	Volts	DC	-1.2	Micro-Strains
Cable#	11	+.003519	Volts	DC	-1.7	Micro-Strains
Cable#	12	000054	Volts	DC	-2.4	Micro-Strains
Cable#	13	001346	Volts	DC	2	Micro-Strains
Cable#	14	004178	Volts	DC	6	Micro-Strains
Cable#	15	004328	Volts	DC	-3.5	Micro-Strains
Cable#	16	001444	Volts	DC	-1.4	Micro-Strains
Cable#	17	003084	Volts	DC	-1.7	Micro-Strains
Cable#	18	003390	Volts	DC	-1.8	Micro-Strains
Cable#	19	003326	Volts	DC	6	Micro-Strains
Cable#	ZØ	003322	Volts	DC	-1.0	Micro-Strains
Cable#	21	002065	Volts	DC	5	Micro-Strains
Cable#	22	+.002869	Volts	DC	4	Micro-Strains
Cable#	23	001968	Volts	DC	8	Micro-Strains
Cable#	24	001627	Volts	DC	+.1	Micro-Strains
Cable#	25	002648	Volts	DC	-6.0	Micro-Strains

LVDT: -0.060352 VDC 0.000033 Inches

Hor. Rad.=.003839 VDC 252.9 W/M^2

Position #22 CL

Time:	15:17:38	3 Date: 88	3/08/19	9		
Group#	3	Record#	5			
File na	ame: SCE	)0504				
Power e	supply:	4.9729	Volts	DC		
Cable#	1	007007	Volts	DC	-2.6	Micro-Strains
Cable#	2	+.001664	Volts	DC	+1.6	Micro-Strains
Cable#	3	+.000897	Volts	DC	-6.1	Micro-Strains
Cable#	4	001490	Volts	DC	-4.0	Micro-Strains
Cable#	5	001034	Volts	DC	-4.2	Micro-Strains
Cable#	6	004051	Volts	DC	-2.8	Micro-Strains
Cable#	7	000915	Volts	DC	-1.3	Micro-Strains
Cable#	8	001977	Volts	DC	-5.0	Micro-Strains
Cable#	9	001332	Volts	DC	-5.1	Micro-Strains
Cable#	10	+.002752	Volts	DC	-1.1	Micro-Strains
Cable#	11	+.003519	Volts	DC	-1.5	Micro-Strains
Cable#	12	000060	Volts	DC	-4.9	Micro-Strains
Cable#	13	001350	Volts	DC	-1.9	Micro-Strains
Cable#	14	004179	Volts	DC	-1.2	Micro-Strains
Cable#	15	004331	Volts	DC	-4.9	Micro-Strains
Cable#	16	001447	Volts	DC	-2.7	Micro-Strains
Cable#	17	~.003090	Volts	DC	-4.2	Micro-Strains
Cable#	18	003390	Volts	DC	-2.0	Micro-Strains
Cable#	19	003332	Volts	DC	-3.2	Micro-Strains
Cable#	20	003326	Volts	DC	-2.8	Micro-Strains
Cable#	21	002064	Volts	DC	2	Micro-Strains
Cable#	22	+.002870	Volts	DC	+.2	Micro-Strains
Cable#	23	001967	Volts	DC	5	Micro-Strains
Cable#	24	001628	Volts	DC	4	Micro-Strains
Cable#	25	002644	Volts	DC	-4.5	Micro-Strains

LVDT: -0.060108 VDC 0.000021 Inches

Hor. Rad.=.004121 VDC 271.5 W/M^2

Position #21 CL

Time:	15:19:2	5 Date: 88	3/08/19	Ð		
Group#	3	Record#	6			
File na	ame: SCI	DØSØ4				
Power a	supply:	4.9726	Volts	DC		
Cable#	1	007007	Volts	DC	-2.7	Micro-Strains
Cable#	Z	+.001687	Volts	DC	+11.0	Micro-Strains
Cable#	3	+.000889	Volts	DC	-9.3	Micro-Strains
Cable#	4	001524	Volts	DC	~17.9	Micro-Strains
Cable#	5	001071	Volts	DC	-19.3	Micro-Strains
Cable#	6	004052	Volts	DC	-3.3	Micro-Strains
Cable#	7	000886	Volts	DC	+10.5	Micro-Strains
Cable#	8	001985	Volts	DC	-8.3	Micro-Strains
Cable#	9	001342	Volts	DC	-9.2	Micro-Strains
Cable#	10	+.002758	Volts	DC	+1.4	Micro-Strains
Cable#	11	+.003524	Volts	DC	+.6	Micro-Strains
Cable#	12	000070	Volts	DC	-8.9	Micro-Strains
Cable#	13	001348	Volts	DC	-1.1	Micro-Strains
Cable#	14	004178	Volts	DC	9	Micro-Strains
Cable#	15	004336	Volts	DC	-7.0	Micro-Strains
Cable#	16	001447	Volts	DC	-2.7	Micro-Strains
Cable#	17	~.003094	Volts	DC	-5.9	Micro-Strains
Cable#	18	003394	Volts	DC	-3.7	Micro-Strains
Cable#	19	003334	Volts	DC	-4.0	Micro-Strains
Cable#	20	003327	Volts	DC	-3.2	Micro-Strains
Cable#	21	002064	Volts	DC	Z	Micro-Strains
Cable#	22	+.002869	Volts	DC	2	Micro-Strains
Cable#	23	001969	Volts	DC	-1.4	Micro-Strains
Cable#	24	001630	Volts	DC	-1.2	Micro-Strains
Cable#	25	002637	Volts	DC	-1.7	Micro-Strains

LVDT: -0.060025 VDC 0.000017 Inches

Hor. Rad.=.004001 VDC 263.6 W/M^2

Position #20 CL

Time: 15:21:	26 Date: 88	3/08/19	)		
Group# 3	Record#	7			
File name: S	CDØSØ4				
Power supply	: 4.9721	Volts	DC		
Cable# 1	007006	Volts	DC	-2.6	Micro-Strains
Cable# 2	+.001714	Volts	DC	+22.1	Micro-Strains
Cable# 3	+.000881	Volts	DC	-12.5	Micro-Strains
Cable# 4	001560	Volts	DC	-32.6	Micro-Strains
Cable# 5	001110	Volts	DC	-35.Z	Micro-Strains
Cable# 6	004049	Volts	DC	-2.2	Micro-Strains
Cable# 7	000851	Volts	DC	+24.8	Micro-Strains
Cable# 8	001993	Volts	DC	-11.7	Micro-Strains
Cable# 9	001359	Volts	D£	-16.1	Micro-Strains
Cable# 10	+.002769	Volts	DC	+5.9	Micro-Strains
Cable# 11	+.003535	Volts	DC	+5.2	Micro-Strains
Cable# 12	000085	Volts	DC	-15.0	Micro-Strains
Cable# 13	001347	Volts	DC	7	Micro-Strains
Cable# 14	004177	Volts	DC	7	Micro-Strains
Cable# 15	004340	Volts	DC	-8.8	Micro-Strains
Cable# 16	001449	Volts	DC	-3.6	Micro-Strains
Cable# 17	003100	Volts	DC	-8.4	Micro-Strains
Cable# 18	003394	Volts	DC	-3.8	Micro-Strains
Cable# 19	003336	Volts	DC	-5.0	Micro-Strains
Cable# 20	003331	Volts	DC	-5.0	Micro-Strains
Cable# 21	002063	Volts	DC	+.1	Micro-Strains
Cable# 22	+.002869	Volts	DC	1	Micro-Strains
Cable# 23	001973	Volts	DC	-3.0	Micro-Strains
Cable# 24	001632	Volts	DC	-2.1	Micro-Strains
Cable# 25	002632	Volts	DC	+.2	Micro-Strains

LVDT: -0.060286 VDC 0.000030 Inches

Hor. Rad.=.003651 VDC

240.5 W/M^2

Position #19 CL

Time: 15	:23:15 Date: :	88/08/15	}		
Group#	3 Record	# 8			
File nam	ie: SCDØSØ4				
Power su	ipply: 4.9719	Volts	DC		
Cable#	100700	1 Volts	DC	7	Micro-Strains
Cable#	2 +.00173	Z Volts	DC	+29.5	Micro-Strains
Cable#	3 +.000874	4 Volts	DC	-15.4	Micro-Strains
Cable#	400157	9 Volts	DC	-40.3	Micro-Strains
Cable#	500112	9 Volts	DC	-43.0	Micro-Strains
Cable#	6004049	5 Volts	DC	7	Micro-Strains
Cable#	700083	3 Volts	DC	+32.1	Micro-Strains
Cable#	800200	Ø Volts	DC	-14.6	Micro-Strains
Cable#	900138	2 Volts	DC	-25.4	Micro-Strains
Cable# 1	0 +.00278	9 Volts	DC	+14.1	Micro-Strains
Cable# 1	1 +.00355	4 Volts	DC	+12.9	Micro-Strains
Cable# 1	2000104	4 Volts	DC	-22.7	Micro-Strains
Cable# 1	300134	4 Volts	DC	+.5	Micro-Strains
Cable# 1	400417	3 Volts	DC	+.9	Micro-Strains
Cable# 1	500434	7 Volts	DC	-11.7	Micro-Strains
Cable# 1	600144	7 Volts	DC	-2.8	Micro-Strains
Cable# 1	7003104	4 Volts	DC	-10.1	Micro-Strains
Cable# 1	800339	3 Volts	DC	-3.5	Micro-Strains
Cable# 1	9003340	0 Volts	DC	-6.6	Micro-Strains
Cable# 2	000333	5 Volts	DC	-6.6	Micro-Strains
Cable# Z	00205	2 Volts	DC	+.5	Micro-Strains
Cable# 2	+.00287	0 Volts	00	+.4	Micro-Strains
Cable# 2	300197	7 Volts	DC	-4.7	Micro-Strains
Cable# 2	400163	5 Volts	DC	-3.3	Micro-Strains
Cable# 2	00262	9 Volts	DC	+1.4	Micro-Strains
LVDT: -0	0.060154 VDC	0.000	<b>b@2 3</b>	Inches	

Hor. Rad.=.003633 VDC 239.3 W/M^2

.

Position #18 CL

Time: 15:28:5	51 Date: 80	3/08/19	)		
Group# 3	Record#	9			
File name: SC	DØSØ4				
Power supply:	4.9717	Volts	DC		
Cable# 1	006994	Volts	DC	+2.0	Micro-Strains
Cable# 2	+.001743	Volts	ÐC	+34.0	Micro-Strains
Cable# 3	+.000867	Volts	DC	-18.2	Micro-Strains
Cable# 4	001587	Volts	DC	-43.6	Micro-Strains
Cable# 5	001135	Volts	DC	-45.5	Micro-Strains
Cable# 6	004038	Volts	DC	+2.1	Micro-Strains
Cable# 7	000826	Volts	DC	+35.0	Micro-Strains
Cable# 8	002007	Volts	DC	-17.4	Micro-Strains
Cable# 9	001405	Volts	DC	-34.7	Micro-Strains
Cable# 10	+.002815	Volts	DC	+24.6	Micro-Strains
Cable# 11	+.003577	Volts	DC	+22.3	Micro-Strains
Cable# 1Z	000127	Volts	DC	-32.0	Micro-Strains
Cable# 13	001339	Volts	DC	+2.4	Micro-Strains
Cable# 14	004170	Volts	DC	+2.0	Micro-Strains
Cable# 15	004349	Volts	DC	-12.6	Micro-Strains
Cable# 16	001445	Volts	DC	-2.0	Micro-Strains
Cable# 17	003108	Volts	DC	-11.7	Micro-Strains
Cable# 18	003389	Volts	DC	-1.9	Micro-Strains
Cable# 19	003343	Volts	DC	-7.9	Micro-Strains
Cable# 20	003339	Volts	DC	-8.3	Micro-Strains
Cable# 21	002060	Volts	DC	+1.Z	Micro-Strains
Cable# 22	+.002873	Volts	DC	+1.6	Micro-Strains
Cable# 23	001984	Volts	DC	-7.5	Micro-Strains
Cable# 24	001642	Volts	DC	-6.1	Micro-Strains
Cable# 25	002626	Volts	DC	+2.5	Micro-Strains
LVDT: -0.0595	48 VDC	~0.000	8000	Inches	

Hor. Rad.=.003789 VDC 249.6 W/M^2

Position #17 CL

Time: 15:32:44 Dat	:e: 88/08/1	9		
Group# 3 Red	cond# 10			
File name: SCDØSØ4	ļ			
Power supply: 4.9	718 Volts	DC		
Cable# 100	06987 Volts	DC	+5.0	Micro-Strains
Cable# 2 +.00	01746 Volts	DC	+35.2	Micro-Strains
Cable# 3 +.00	MØ863 Volts	DC	-19.8	Micro-Strains
Cable# 400	)1588 Volts	DC	-44.0	Micro-Strains
Cable# 500	01135 Volts	DC	-45.5	Micro-Strains
Cable# 600	04032 Volts	DC	+4.6	Micro-Strains
Cable# 700	WØ823 Volts	DC	+36.2	Micro-Strains
Cable# 800	02010 Volts	DC	-18.6	Micro-Strains
Cable# 900	01434 Volts	DC	-46.4	Micro-Strains
Cable# 10 +.00	02843 Volts	DC	+35.9	Micro-Strains
Cable# 11 +.00	03603 Volts	DC	+32.7	Micro-Strains
Cable# 1200	00153 Volts	DC	-42.5	Micro-Strains
Cable# 1300	01338 Volts	DC	+2.9	Micro-Strains
Cable# 1400	04169 Volts	DC	+2.5	Micro-Strains
Cable# 1500	04350 Volts	DC	-12.9	Micro-Strains
Cable# 1600	01439 Volts	DC 00	+.4	Micro-Strains
Cable# 1700	03108 Volts	DC	-11.7	Micro-Strains
Cable# 1800	)3384 Volts	DC	+.1	Micro-Strains
Cable# 1900	)3348 Volts	DC	-9.8	Micro-Strains
Cable# 2000	3343 Volts	DC	-9.8	Micro-Strains
Cable# 2100	2058 Volts	DC	+2.0	Micro-Strains
Cable# 22 +.00	2875 Volts	DC	+2.4	Micro-Strains
Cable# 2300	)1990 Volts	DC	-9.9	Micro-Strains
Cable# 2400	)1649 Volts	DC	-8.9	Micro-Strains
Cable# 2500	02625 Volts	DC	+3.0	Micro-Strains

LVDT: -0.060149 VDC 0.000023

Inches

Hor. Rad.=.004044 VDC

266.4 W/M^2

Position #16 CL

15:35:3	7 Date: 80	3/08/19	3		
3	Record#	11			
ame: SC	00504				
supply:	4.9722	Volts	DC		
1	006986	Volts	DC	+5.6	Micro-Strains
2	+.001745	Volts	DC	+34.7	Micro-Strains
3	+.000862	Volts	DC	-20.3	Micro-Strains
4	001585	Volts	DC	-42.8	Micro-Strains
5	001133	Volts	DC	-44.6	Micro-Strains
6	004030	Volts	DC	+5.6	Micro-Strains
7	000823	Volts	DC	+36.2	Micro-Strains
8	002011	Volts	DC	-19.0	Micro-Strains
9	001447	Volts	DC	-51.6	Micro-Strains
10	+.002860	Volts	DC	+42.7	Micro-Strains
11	+.003617	Volts	DC	+38.3	Micro-Strains
12	000162	Volts	DC	-46.1	Micro-Strains
13	001343	Volts	DC	+.9	Micro-Strains
14	004171	Volts	DC	+1.8	Micro-Strains
15	004346	Volts	DC	-11.2	Micro-Strains
16	001433	Volts	DC	+2.9	Micro-Strains
17	003106	Volts	DC	-10.8	Micro-Strains
18	003377	Volts	DC	+3.0	Micro-Strains
19	003354	Volts	DC	-12.1	Micro-Strains
20	003349	Volts	DC	-12.1	Micro-Strains
21	002056	Volts	DC	+2.9	Micro-Strains
22	+.002876	Volts	DC	+2.7	Micro-Strains
23	001996	Volts	DC	-12.2	Micro-Strains
24	001655	Volts	DC	-11.2	Micro-Strains
25	002624	Volts	DC	+3.5	Micro-Strains
	I5:35:3 ame: SC supply: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	15:35:37 Date: $88/08/19$ 3 Record# 11 ame: SCDØSØ4 supply: 4.9722 Volts DC 1 $006986$ Volts DC 2 +. $001745$ Volts DC 3 +. $000862$ Volts DC 3 +. $000862$ Volts DC 4 $001585$ Volts DC 5 $001133$ Volts DC 6 $004030$ Volts DC 7 $000823$ Volts DC 8 $002011$ Volts DC 9 $001447$ Volts DC 10 +. $002860$ Volts DC 11 +. $003617$ Volts DC 12 $000162$ Volts DC 13 $001343$ Volts DC 14 $004171$ Volts DC 15 $004346$ Volts DC 16 $001433$ Volts DC 17 $003106$ Volts DC 18 $003354$ Volts DC 19 $003354$ Volts DC 20 $003349$ Volts DC 21 $002866$ Volts DC 22 +. $002876$ Volts DC 23 $001996$ Volts DC 24 $001655$ Volts DC 25 $002624$ Volts DC	15:35:37  Date: 88/08/19    3  Record# 11    ame: SCD0S04    supply: 4.9722  Volts DC    1 006986  Volts DC    2  +.001745  Volts DC    3  +.000862  Volts DC    3  +.000862  Volts DC    4 001585  Volts DC    5 001133  Volts DC    6 004030  Volts DC    7 000823  Volts DC    8 002011  Volts DC    9 001447  Volts DC    9 001447  Volts DC    9 000162  Volts DC    11  +.002860  Volts DC    12 000162  Volts DC    13 000162  Volts DC    14 0001433  Volts DC    15 0001343  Volts DC    16 0001433  Volts DC    17 003106  Volts DC    18 003377  Volts DC    19 003354  Volts DC

LVDT: -0.060328 VDC 0.000032 Inches

Hor. Rad.=.004089 VDC 269.4 W/M^2

Position #15 CL

Time:	15:37:0	9 Date: 88	3/08/19	3		
Group#	3.	Record#	12			
File na	ame: SCI	00504				
Power s	supply:	4.9720	Volts	DC		
Cable#	1	006986	Volts	DC	+5.5	Micro-Strains
Cable#	2	+.001740	Volts	DC	+32.7	Micro-Strains
Cable#	3	+.000864	Volts	DC	-19.5	Micro-Strains
Cable#	4	001577	Volts	DC	-39.5	Micro-Strains
Cable#	5	001124	Volts	DC	-41.0	Micro-Strains
Cable#	6	004030	Volts	DC	+5.5	Micro-Strains
Cable#	7	000829	Volts	DC	+33.8	Micro-Strains
Cable#	8	002009	Volts	DC	-18.2	Micro-Strains
Cable#	9	001426	Volts	DC	-43.2	Micro-Strains
Cable#	10	+.002840	Volts	DC	+34.7	Micro-Strains
Cable#	11	+.003599	Volts	DC	+31.1	Micro-Strains
Cable#	12	000143	Volts	DC	-38.4	Micro-Strains
Cable#	13	001348	Volts	DC	-1.1	Micro-Strains
Cable#	14	004177	Volts	DC	7	Micro-Strains
Cable#	15	004340	Volts	DC	-8.8	Micro-Strains
Cable#	16	001427	Volts	DC	+5.3	Micro-Strains
Cable#	17	003099	Volts	DC	-8.0	Micro-Strains
Cable#	18	003371	Volts	DC	+5.3	Micro-Strains
Cable#	19	003358	Volts	DC	-13.7	Micro-Strains
Cable#	20	003354	Volts	DC	-14.1	Micro-Strains
Cable#	21	002056	Volts	DC	+2.9	Micro-Strains
Cable#	22	+.002877	Volts	DC	+3.2	Micro-Strains
Cable#	23	002001	Volts	DC	-14.2	Micro-Strains
Cable#	24	001658	Volts	DC	-12.4	Micro-Strains
Cable#	25	002625	Volts	DC	+3.0	Micro-Strains

LVDT: -0.060641 VDC 0.000048 Inches

Hor. Rad.=.003945 VDC 259.9 W/M^2

Position #14 CL

Time:	15:44:0	6 Date: 88	8/ <b>0</b> 8/19	3		
Group#	3	Record#	13			
File na	ame: SCI	DØSØ4				
Power s	supply:	4.9730	Volts	DC		
Cable#	1	006987	Volts	DC	+5.6	Micro-Strains
Cable#	2	+.001733	Volts	DC	+29.7	Micro-Strains
Cable#	3	+.000865	Volts	DC	-19.1	Micro-Strains
Cable#	4	001566	Volts	<b>DC</b>	-34.9	Micro-Strains
Cable#	5	001108	Volts	DC	-34.3	Micro-Strains
Cable#	6	004031	Volts	DC	+5.4	Micro-Strains
Cable#	7	000843	Volts	DC	+28.1	Micro-Strains
Cable#	8	002008	Volts	DC	-17.6	Micro-Strains
Cable#	9	001392	Volts	DC	-29.3	Micro-Strains
Cable#	10	+.002810	Volts	DC	+22.3	Micro-Strains
Cable#	11	+.003569	Volts	DC	+18.6	Micro-Strains
Cable#	12	000116	Volts	DC	-27.5	Micro-Strains
Cable#	13	001357	Volts	DC	-4.7	Micro-Strains
Cable#	14	004187	Volts	DC	-4.4	Micro-Strains
Cable#	15	004333	Volts	DC	-5.7	Micro-Strains
Cable#	16	001420	Volts	DC	+8.2	Micro-Strains
Cable#	17	003092	Volts	DC	-5.0	Micro-Strains
Cable#	18	003362	Volts	DC	+9.Z	Micro-Strains
Cable#	19	003367	Volts	DC	-17.1	Micro-Strains
Cable#	2 <b>0</b>	003364	Volts	DC	-17.9	Micro-Strains
Cable#	21	002051	Volts	DC	+5.0	Micro-Strains
Cable#	22	+.002884	Volts	DC	+5.7	Micro-Strains
Cable#	23	002010	Volts	DC	-17.6	Micro-Strains
Cable#	24	001670	Volts	DC	-17.1	Micro-Strains
Cable#	25	002623	Volts	DC	+4.0	Micro-Strains

LVDT: -0.060379 VDC 0.000034 Inches

Hor. Rad.=.003895 VDC 256.6 W/M^2

Position #13 CL

Time: 1	6:03:2	i Date: 88	3/08/19	}		
Group#	3	Record#	14			
File na	ame: SCI	)0504				
Power e	supply:	4.9742	Volts	DC		
Cable#	1	006979	Volts	DC	+9.6	Micro-Strains
Cable#	2	+.001724	Volts	DC	+25.9	Micro-Strains
Cable#	3	+.000867	Volts	DC	-18.4	Micro-Strains
Cable#	4	001550	Volts	DC	-28.2	Micro-Strains
Cable#	5	001094	Volts	DC	-28.5	Micro-Strains
Cable#	6	004022	Volts	DC	+9.5	Micro-Strains
Cable#	7	000850	Volts	DC	+25.3	Micro-Strains
Cable#	8	002007	Volts	DC	-17.0	Micro-Strains
Cable#	9	001361	Volts	DC	-16.7	Micro-Strains
Cable#	10	+.002781	Volts	DC	+10.3	Micro-Strains
Cable#	11	+.003548	Volts	DC	+9.8	Micro-Strains
Cable#	12	000084	Volts	DC	-14.6	Micro-Strains
Cable#	13	001363	Volts	DC	-6.9	Micro-Strains
Cable#	14	004194	Volts	DC	-6.8	Micro-Strains
Cable#	15	004323	Volts	DC	-1.2	Micro-Strains
Cable#	16	001405	Volts	DC	+14.4	Micro-Strains
Cable#	17	003082	Volts	DC	7	Micro-Strains
Cable#	18	003345	Volts	DC	+16.3	Micro-Strains
Cable#	19	003381	Volts	DC	-22.3	Micro-Strains
Cable#	2 <b>0</b>	003377	Volts	DC	-22.7	Micro-Strains
Cable#	21	002042	Volts	DC	+8.8	Micro-Strains
Cable#	22	+.002893	Volts	DC	+9.0	Micro-Strains
Cable#	23	002024	Volts	DC	-23.0	Micro-Strains
Cable#	24	001685	Volts	DC	-22.9	Micro-Strains
Cable#	25	-,002621	Volts	DC	+5.1	Micro-Strains

LVDT: -0.060921 VDC 0.000062 Inches

Hor. Rad.=.004056 VDC 267.2 W/M^2

Position #12 CL

Time: 16:06:49 Date: 88/08/19							
Group# 3	Record#	15					
File name: SC	DØSØ4						
Power supply:	4.9743 V	olts	DC				
Cable# 1	006989 V	olts	DC	+5.6	Micro-Strains		
Cable# 2	+.001715 V	olts	DC ·	+22.2	Micro-Strains		
Cable# 3	+.000884 V	olts	DC ·	-11.5	Micro-Strains		
Cable# 4	001535 V	olts	DC ·	-22.1	Micro-Strains		
Cable# 5	~.001080 V	olts	DC ·	-22.8	Micro-Strains		
Cable# 6	004033 V	olts	DC	+5.0	Micro-Strains		
Cable# 7	~.000861 V	olts	DC ·	+20.9	Micro-Strains		
Cable# 8	001992 V	olts	DC ·	-10.9	Micro-Strains		
Cable# 9	001339 V	olts	DC	-7.8	Micro-Strains		
Cable# 10	+.002763 V	olts	DC	+3.0	Micro-Strains		
Cable# 11	+.003532 V	olts	DC	+3.3	Micro-Strains		
Cable# 12	000064 V	olts	DC	-6.5	Micro-Strains		
Cable# 13	001383 V	olts	DC ·	-15.0	Micro-Strains		
Cable# 14	004212 V	olts	DC ·	-14.0	Micro-Strains		
Cable# 15	004304 V	olts	DC	+6.5	Micro-Strains		
Cable# 16	001391 V	olts	DC ·	+20.0	Micro-Strains		
Cable# 17	003063 V	olts	DC	+6.8	Micro-Strains		
Cable# 18	003332 V	olts	DC ·	+21.5	Micro-Strains		
Cable# 19	003392 V	olts	DC -	-26.6	Micro-Strains		
Cable# 20	003387 V	olts	DC ·	-26.7	Micro-Strains		
Cable# Z1	002040 V	olts	DC	+9.6	Micro-Strains		
Cable# 22	+.002892 V	olts	DC	+8.6	Micro-Strains		
Cable# 23	002030 V	olts	DC ·	-25.4	Micro-Strains		
Cable# 24	001691 V	olts	DC ·	-25.2	Mícro-Strains		
Cable# 25	002622 V	olts	DC	+4.7	Micro-Strains		

LVDT: -0.061071 VDC 0.000069 Inches

Hor. Rad.=.002945 VDC 194.0 W/M^2

Position #11 CL

Time:	16:08:0	9 Date: 88	3/08/19	3		
Group#	3	Record#	16			
File na	ame: SC	DØSØ4				
Power :	supply:	4.9741	Volts	DC		
Cable#	1	007006	Volts	DC	-1.5	Micro-Strains
Cable#	2	+.001704	Volts	DC	+17.8	Micro-Strains
Cable#	3	+.000908	Volts	DC	-1.7	Micro-Strains
Cable#	4	001522	Volts	DC	-16.9	Micro-Strains
Cable#	5	~.001068	Volts	DC	-17.9	Micro-Strains
Cable#	6	004051	Volts	DC	-2.4	Micro-Strains
Cable#	7	000871	Volts	DC	+16.8	Micro-Strains
Cable#	8	001969	Volts	DC	-1.6	Micro-Strains
Cable#	9	001321	Volts	DC	5	Micro-Strains
Cable#	10	+.002748	Volts	DC	-3.0	Micro-Strains
Cable#	11	+.003518	Volts	DC	-2.3	Micro-Strains
Cable#	12	000047	Volts	DC	+.4	Micro-Strains
Cable#	13	001392	Volts	DC	-18.6	Micro-Strains
Cable#	14	004224	Volts	DC	-18.9	Micro-Strains
Cable#	15	004299	Volts	DC	+8.4	Micro-Strains
Cable#	16	001376	Volts	DC	+26.0	Micro-Strains
Cable#	17	003054	Volts	DC	+10.4	Micro-Strains
Cable#	18	003315	Volts	DC	+28.2	Micro-Strains
Cable#	19	003404	Volts	DC	-31.5	Micro-Strains
Cable#	20	003400	Volts	DC	-31.9	Micro-Strains
Cable#	21	002039	Volts	DC	+10.0	Micro-Strains
Cable#	22	+.002895	Volts	DC	+9.8	Micro-Strains
Cable#	23	002034	Volts	DC	-27.0	Micro-Strains
Cable#	24	001697	Volts	DC	-27.7	Micro-Strains
Cable#	25	002624	Volts	DC	+3.9	Micro-Strains

LVDT: -0.060812 VDC 0.000056 Inches

Hor. Rad.=.002778 VDC 183.0 W/M^2
Position #10 CL

Time:	1 <b>6:0</b> 9:2	1 Date: 88	3/08/19	3		
Group#	3	Record#	17			
File na	ame: SCI	DØSØ4				
Power s	supply:	4.9743	Volts	DC		
Cable#	1	007030	Volts	DC	-11.1	Micro-Strains
Cable#	2	+.001697	Volts	DC	+14.9	Micro-Strains
Cable#	3	+.000937	Volts	DC	+10.1	Micro-Strains
Cable#	4	001511	Volts	DC	-12.4	Micro-Strains
Cable#	5	001056	Volts	DC	-13.0	Micro-Strains
Cable#	6	004073	Volts	DC	-11.3	Micro-Strains
Cable#	7	000880	Volts	DC	+13.1	Micro-Strains
Cable#	8	001942	Volts	DC	+9.5	Micro-Strains
Cable#	9	001308	Volts	DC	+4.8	Micro-Strains
Cable#	10	+.002738	Volts	DC	-7.1	Micro-Strains
Cable#	11	+.003507	Volts	DC	-6.8	Micro-Strains
Cable#	12	000034	Volts	DC	+5.6	Micro-Strains
Cable#	13	001372	Volts	DC	-10.6	Micro-Strains
Cable#	14	004203	Volts	DC	-10.4	Micro-Strains
Cable#	15	004308	Volts	DC	+4.9	Micro-Strains
Cable#	16	001360	Volts	DC	+32.5	Micro-Strains
Cable#	17	003065	Volts	DC	+6.1	Micro-Strains
Cable#	18	003300	Volts	DC	+34.2	Micro-Strains
Cable#	19	003417	Volts	DC	-36.6	Micro-Strains
Cable#	ZØ	003411	Volts	DC	-36.2	Micro-Strains
Cable#	21	002038	Volts	DC	+10.4	Micro-Strains
Cable#	22	+.002896	Volts	DC	+10.Z	Micro-Strains
Cable#	23	002038	Volts	DC	-28.5	Micro-Strains
Cable#	24	001701	Volts	DC	-29.2	Micro-Strains
Cable#	25	002625	Volts	DC	+3.5	Micro-Strains

LVDT: -0.060916 VDC 0.000062 Inches

Hor. Rad.=.004280 VDC 281.9 W/M^2

Position #9 CL

Time: 1	6:11:34	1 Date: 88	3/08/19	}		
Group#	3	Record#	18			
File na	ame: SC(	)0504				
Power e	supply:	4.9744	Volts	DC		
Cable#	1	007059	Volts	DC	-22.9	Micro-Strains
Cable#	2	+.001691	Volts	DC	+12.4	Micro-Strains
Cable#	3	+.000976	Volts	DC	+26.0	Micro-Strains
Cable#	4	001502	Volts	DC	-8.7	Micro-Strains
Cable#	5	001046	Volts	DC	-8.9	Micro-Strains
Cable#	6	004105	Volts	DC	-24.3	Micro-Strains
Cable#	7	000888	Volts	DC	+9.9	Micro-Strains
Cable#	8	001904	Volts	DC	+24.9	Micro-Strains
Cable#	9	001298	Volts	DC	+8.8	Micro-Strains
Cable#	10	+.002731	Volts	DC	-9.9	Micro-Strains
Cable#	11	+.003501	Volts	DC	-9.2	Micro-Strains
Cable#	12	000025	Volts	DC	+9.3	Micro-Strains
Cable#	13	001342	Volts	DC	+1.5	Micro-Strains
Cable#	14	004174	Volts	DC	+1.3	Micro-Strains
Cable#	15	004329	Volts	DC	-3.6	Micro-Strains
Cable#	16	001344	Volts	DC	+39.0	Micro-Strains
Cable#	17	003088	Volts	DC	-3.1	Micro-Strains
Cable#	18	003283	Volts	DC	+41.0	Micro-Strains
Cable#	19	003429	Volts	DC	-41.3	Micro-Strains
Cable#	2 <b>0</b>	003424	Volts	DC	-41.3	Micro-Strains
Cable#	21	002035	Volts	DC	+11.6	Micro-Strains
Cable#	22	+.002903	Volts	DC	+12.9	Micro-Strains
Cabl <b>e</b> #	23	002043	Volts	DC	-30.5	Micro-Strains
Cable#	24	001707	Volts	DC	-31.6	Micro-Strains
Cable#	25	002627	Volts	DC	+2.7	Micro-Strains

LVDT: -0.060946 VDC 0.000063 Inches

Hor. Rad.=.002236 VDC 147.3 W/M^2

Position #8 CL

Time: 1	6:31:1	1 Date: 88	37 <b>0</b> 8719	3		
Group#	3	Record#	19			
File na	ame: SCI	00504				
Power a	supply:	4.9758	Volts	DC		
Cable#	1	007097	Volts	DC	-37.6	Micro-Strains
Cable#	2	+.001695	Volts	DC	+13.8	Micro-Strains
Cable#	3	+.001022	Volts	DC	+44.6	Micro-Strains
Cable#	4	001496	Volts	DC	-6.1	Micro-Strains
Cable#	5	001039	Volts	DC	-6.0	Micro-Strains
Cable#	6	004145	Volts	DC	-40.1	Micro-Strains
Cable#	7	000890	Volts	DC	+9.1	Micro-Strains
Cable#	8	001860	Volts	DC	+43.1	Micro-Strains
Cable#	9	001289	Volts	DC	+12.6	Micro-Strains
Cable#	10	+.002732	Volts	DC	-9.8	Micro-Strains
Cable#	11	+.003498	Volts	DC	-10.9	Micro-Strains
Cable#	12	000012	Volts	DC	+14.5	Micro-Strains
Cable#	13	001322	Volts	DC	+9.7	Micro-Strains
Cable#	14	004161	Volts	DC	+7.0	Micro-Strains
Cable#	15	004346	Volts	DC	-9.9	Micro-Strains
Cable#	16	001322	Volts	DC	+48.0	Micro-Strains
Cable#	17	003099	Volts	DC	-7.1	Micro-Strains
Cable#	18	003265	Volts	DC	+48.5	Micro-Strains
Cable#	19	003443	Volts	DC	-46.5	Micro-Strains
Cable#	20	003434	Volts	DC	-44.9	Micro-Strains
Cable#	21	002035	Volts	DC	+11.8	Micro-Strains
Cable#	22	+.002901	Volts	DC	+11.8	Micro-Strains
Cable#	23	002044	Volts	DC	-30.7	Micro-Strains
Cable#	24	001706	Volts	DC	-31.0	Micro-Strains
Cable#	25	002629	Volts	DC	+2.2	Micro-Strains

LVDT: -0.059845 VDC 0.000007 Inches

Hor. Rad.=.003066 VDC 202.0 W/M^2

Position #7 CL

Time:	16:32	:25 Date: 88	3/08/19	}		
Group#	3	Record#	2Ø			
File n	ame:	SCDØSØ4				
Power	suppl	y: 4.9757	Volts	DC		
Cable#	1	007113	Volts	DC	-44.1	Micro-Strains
Cable#	2	+.001691	Volts	DC	+12.2	Micro-Strains
Cable#	3	+.001043	Volts	DC	+53.1	Micro-Strains
Cable#	4	001489	Volts	DC	-3.2	Micro-Strains
Cable#	5	001033	Volts	DC	-3.5	Micro-Strains
Cable#	6	004160	Volts	DC	-46.2	Micro-Strains
Cable#	7	000896	Volts	DC	+6.7	Micro-Strains
Cable#	8	001841	Volts	DC	+50.8	Micro-Strains
Cable#	9	001288	Volts	DC	+13.0	Micro-Strains
Cable#	10	+.002731	Volts	DC	-10.2	Micro-Strains
Cable#	11	+.003497	Volts	DC	-11.2	Micro-Strains
Cable#	12	000009	Volts	DC	+15.7	Micro-Strains
Cable#	13	001312	Volts	DC	+13.7	Micro-Strains
Cable#	14	004152	Volts	DC	+10.6	Micro-Strains
Cable#	15	004351	Volts	DC	-12.0	Micro-Strains
Cable#	16	001314	Volts	DC	+51.2	Micro-Strains
Cable#	17	003106	Volts	DC	-9.9	Micro-Strains
Cable#	18	003258	Volts	DC	+51.3	Micro-Strains
Cable#	19	003449	Volts	DC	-48.9	Micro-Strains
Cable#	2Ø	003439	Volts	DC	-47.0	Micro-Strains
Cable#	21	002036	Volts	DC	+11.4	Micro-Strains
Cable#	Z 2	+.002902	Volts	DC	+12.2	Micro-Strains
Cable#	23	002044	Volts	DC	-30.7	Micro-Strains
Cable#	24	001706	Volts	DC	-3t.Ø	Micro-Strains
Cable#	25	002630	Volts	DC	+1.8	Micro-Strains

LVDT: -0.059703 VDC 2.528662E-7 Inches

Hor. Rad.=.003197 VDC 210.6 W/M^2

Position #6 CL

Time: 1	6:33:42	2 Date: 88	3/08/19	)		
Group#	3	Record#	21			
File na	ame: SCE	JØSØ4				
Power s	supply:	4.9757	Volts	DC		
Cable#	1	007080	Volts	DC	-30.7	Micro-Strains
Cable#	2	+.001688	Volts	DC	+11.0	Micro-Strains
Cable#	3	+.001010	Volts	DC	+39.7	Micro-Strains
Cable#	4	001485	Volts	DC	-1.6	Micro-Strains
Cable#	5	001029	Volts	DC	-1.9	Micro-Strains
Cable#	6	004128	Volts	DC	-33.2	Micro-Strains
Cable#	7	000900	Volts	DC	+5.1	Micro-Strains
Cable#	8	001869	Volts	DC	+39.4	Micro-Strains
Cable#	9	001289	Volts	DC	+12.6	Micro-Strains
Cable#	10	+.002734	Volts	DC	-9.0	Micro-Strains
Cable#	11	+.003499	Volts	DC	-10.4	Micro-Strains
Cable#	12	000011	Volts	DC	+14.9	Micro-Strains
Cable#	13	001307	Volts	DC	+15.8	Micro-Strains
Cable#	14	004147	Volts	DC	+12.6	Micro-Strains
Cable#	15	004354	Volts	DC	-13.2	Micro-Strains
Cable#	16	001314	Volts	DC	+51.2	Micro-Strains
Cable#	17	003107	Volts	DC	-10.3	Micro-Strains
Cable#	18	003257	Volts	DC	+51.7	Micro-Strains
Cable#	19	003448	Volts	DC	-48.5	Micro-Strains
Cable#	2 <b>0</b>	003437	Volts	DC	-46.2	Micro-Strains
Cable#	21	002035	Volts	DC	+11.8	Micro-Strains
Cable#	22	+.002905	Volts	DC	+13.4	Micro-Strains
Cable#	23	002042	Volts	DC	-29.9	Micro-Strains
Cable#	24	001703	Volts	DC	-29.8	Micro-Strains
Cable#	25	002632	Volts	DC	+1.0	Micro-Strains

LVDT: -0.059762 VDC 0.000003 Inches

Hor. Rad.=.006193 VDC 408.0 W/M^2

Position #5 CL

Time:	16:35:0	3 Date: 88	3/08/19	3		
Group#	3	Record#	22			
File na	ame: SCI	00504				
Power :	supply:	4.9756	Volts	DC		
Cable#	1	007036	Volts	DC	-12.8	Micro-Strains
Cable#	2	+.001691	Volts	DC	+12.2	Micro-Strains
Cable#	3	+.000963	Volts	DC	+20.6	Micro-Strains
Cable#	4	001481	Volts	DC	+.0	Micro-Strains
Cable#	5	001027	Volts	DC	-1.1	Micro-Strains
Cable#	6	004082	Volts	DC	-14.5	Micro-Strains
Cable#	7	000901	Volts	DC	+4.7	Micro-Strains
Cable#	8	001910	Volts	DC	+22.7	Micro-Strains
Cable#	9	001291	Volts	DC	+11.8	Micro-Strains
Cable#	10	+.002739	Volts	DC	-7.0	Micro-Strains
Cable#	11	+.003503	Volts	DC	-8.8	Micro-Strains
Cable#	12	000010	Volts	DC	+15.3	Micro-Strains
Cable#	13	001307	Volts	DC	+15.7	Micro-Strains
Cable#	14	004148	Volts	DC	+12.2	Micro-Strains
Cable#	15	004352	Volts	DC	-12.4	Micro-Strains
Cable#	16	001320	Volts	DC	+48.8	Micro-Strains
Cable#	17	003103	Volts	DC	-8.7	Micro-Strains
Cable#	18	003267	Volts	DC	+47.7	Micro-Strains
Cable#	19	003439	Volts	DC	-45.0	Micro-Strains
Cable#	20	003424	Volts	DC	-41.0	Micro-Strains
Cable#	21	002036	Volts	DC	+11.4	Micro-Strains
Cable#	22	+.002905	Volts	DC	+13.5	Micro-Strains
Cable#	23	002038	Volts	DC	-28.3	Micro-Strains
Cable#	24	001695	Volts	DC	-26.7	Micro-Strains
Cable#	25	002637	Volts	DC	-1.1	Micro-Strains

LVDT: -0.059018 VDC -0.000034 Inches

Hor. Rad.=.007726 VDC 509.0 W/M^2

Position #4 CL

Time: 1	6:50:05	5 Date: 88	3/08/19	]		
Group#	3	Record#	23			
File na	ame: SC(	JØSØ4				
Power :	supply:	4.9774	Volts	DC		
Cable#	1	007006	Volts	DC	+.4	Micro-Strains
Cable#	2	+.001698	Volts	DC	+14.8	Micro-Strains
Cable#	3	+.000933	Volts	DC	+8.2	Micro-Strains
Cable#	4	001478	Volts	DC	+1.5	Micro-Strains
Cable#	5	001024	Volts	DC	+.3	Micro-Strains
Cable#	6	004053	Volts	DC	-2.1	Micro-Strains
Cable#	7	000903	Volts	DC	+4.0	Micro-Strains
Cable#	8	001930	Volts	DC	+14.8	Micro-Strains
Cable#	9	001292	Volts	DC	+11.6	Micro-Strains
Cable#	10	+.002750	Volts	DC	-2.9	Micro-Strains
Cable#	11	+.003506	Volts	DC	-8.1	Micro-Strains
Cable#	12	000012	Volts	DC	+14.5	Micro-Strains
Cable#	13	001305	Volts	DC	+16.7	Micro-Strains
Cable#	14	004149	Volts	DC	+12.4	Micro-Strains
Cable#	15	004349	Volts	DC	-10.5	Micro-Strains
Cable#	16	001340	Volts	DC	+40.9	Micro-Strains
Cable#	17	003092	Volts	DC	-3.9	Micro-Strains
Cable#	18	003293	Volts	DC	+37.8	Micro-Strains
Cable#	19	003418	Volts	DC	-36.1	Micro-Strains
Cable#	20	003398	Volts	DC	-30.2	Micro-Strains
Cable#	Z 1	002042	Volts	DC	+9.3	Micro-Strains
Cable#	22	+.002910	Volts	DC	+15.0	Micro-Strains
Cable#	23	002033	Volts	DC	-26.1	Micro-Strains
Cable#	24	001674	Volts	DC	-18.1	Micro-Strains
Cable#	25	002641	Volts	DC	-2.3	Micro-Strains

LVDT: -0.058624 VDC -0.000054 Inches

Hor. Rad.=.002315 VDC 152.5 W/M^2

Position #3 CL

Time:	16:51:5	7 Date: 88	3/08/19	3		
Group#	3	Record#	24			
File na	ame: SC	DØSØ4				
Power a	supply:	4.9772	Volts	DC		
Cable#	1	006983	Volts	DC	+9.7	Micro-Strains
Cable#	2	+.001696	Volts	DC	+14.1	Micro-Strains
Cable#	3	+.000912	Volts	DC	3	Micro-Strains
Cable#	4	001476	Volts	DC	+2.2	Micro-Strains
Cable#	5	001023	Volts	DC	+.7	Micro-Strains
Cable#	6	004030	Volts	DC	+7.2	Micro-Strains
Cable#	7	000904	Volts	DC	+3.5	Micro-Strains
Cable#	8	001951	Volts	DC	+6.3	Micro-Strains
Cable#	9	001295	Volts	DC	+10.3	Micro-Strains
Cable#	10	+.002753	Volts	DC	-1.7	Micro-Strains
Cable#	11	+.003509	Volts	DC	-6.8	Micro-Strains
Cable#	12	000016	Volts	DC	+12.9	Micro-Strains
Cable#	13	001309	Volts	DC	+15.1	Micro-Strains
Cable#	14	004151	Volts	DC	+11.5	Micro-Strains
Cable#	15	004346	Volts	ĐC	-9.4	Micro-Strains
Cable#	16	001370	Volts	DC	+28.8	Micro-Strains
Cable#	17	003088	Volts	DC	-2.4	Micro-Strains
Cable#	18	003325	Volts	DC	+25.0	Micro-Strains
Cable#	19	003390	Volts	DC	-25.1	Micro-Strains
Cable#	20	003368	Volts	DC	-18.3	Micro-Strains
Cable#	21	002043	Volts	DC	+8.9	Micro-Strains
Cable#	22	+.002907	Volts	DC	+13.9	Micro-Strains
Cable#	23	002026	Volts	DC	-23.3	Micro-Strains
Cable#	24	001668	Volts	DC	-15.7	Micro-Strains
Cable#	25	002641	Volts	DC	-2.4	Micro-Strains

LVDT: -0.058550 VDC -0.000058 Inches

Hor. Rad.=.001790 VDC 117.9 W/M^2

Position #2 CL

16:53:31	5 Date: 88	3/08/19			
3	Record#	25			
ame: SCI	00504				
supply:	4.9771	Volts	DC		
1	006968	Volts	DC	+15.7	Micro-Strains
Z	+.001695	Volts	DC	+13.7	Micro-Strains
3	+.000896	Volts	DC	-6.8	Micro-Strains
4	001476	Volts	DC	+2.2	Micro-Strains
5	001023	Volts	DC	+.7	Micro-Strains
6	004013	Volts	DC	+14.1	Micro-Strains
7	000905	Volts	DC	+3.1	Micro-Strains
8	001966	Volts	DC	+.1	Micro-Strains
9	001298	Volts	DC	+9.1	Micro-Strains
10	+.002756	Volts	DC	4	Micro-Strains
11	+.003510	Volts	DC	-6.4	Micro-Strains
12	000019	Volts	DC	+11.7	Micro-Strains
13	001311	Volts	DC	+14.3	Micro-Strains
14	004153	Volts	DC	+10.7	Micro-Strains
15	004344	Volts	DC	-8.6	Micro-Strains
16	001402	Volts	DC	+15.9	Micro-Strains
17	003086	Volts	DC	-1.6	Micro-Strains
18	003360	Volts	DC	+11.1	Micro-Strains
19	003363	Volts	DC	-14.4	Micro-Strains
2 <b>0</b>	003340	Volts	DC	-7.2	Micro-Strains
21	~.002045	Volts	ÐC	+8.1	Micro-Strains
22	+.002904	Volts	DC	+12.7	Micro-Strains
23	002017	Volts	DC	-19.7	Micro-Strains
24	001659	Volts	DC	-12.1	Micro-Strains
25	002640	Volts	DC	-2.0	Micro-Strains
	16:53:3 ame: SCI supply: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25	16:53:36   Date: 88     3   Record#     supply:   4.9771     1  006968     2   +.001695     3   +.000896     4  001476     5  001023     6  001023     7  000905     8  001966     9  001298     10   +.002756     11   +.003510     12  000019     13  001311     14  0044453     15  004344     16  003086     18  003360     19  003340     21  002045     22   +.002904     23  002045     24  002645	16:53:36   Date:   88/08/19     3   Record#   25     ame:   SCDØSØ4     supply:   4.9771   Volts     1  006968   Volts     2   +.001695   Volts     3   +.000896   Volts     3   +.000896   Volts     3   +.0001023   Volts     5  001023   Volts     6  004013   Volts     7  000905   Volts     8  001966   Volts     9  001298   Volts     10   +.002756   Volts     11   +.003510   Volts     12  000019   Volts     13  001311   Volts     14  004153   Volts     15  001402   Volts     16  003360   Volts     19  003360   Volts     20  003340   Volts     21  002045   Volts     23  002017   Volts  2	16:53:36Date: $88/08/19$ 3Record#25ame:SCD0S04supply: $4.9771$ VoltsDC1 $006968$ VoltsDC2 $+.001695$ VoltsDC3 $+.000896$ VoltsDC4 $001476$ VoltsDC5 $001023$ VoltsDC6 $004013$ VoltsDC7 $000905$ VoltsDC8 $001966$ VoltsDC9 $001298$ VoltsDC9 $001298$ VoltsDC10 $+.002756$ VoltsDC11 $+.003510$ VoltsDC12 $000019$ VoltsDC13 $001311$ VoltsDC14 $004402$ VoltsDC15 $0043444$ VoltsDC16 $003360$ VoltsDC17 $003360$ VoltsDC18 $003360$ VoltsDC20 $003340$ VoltsDC21 $0029044$ VoltsDC23 $002017$ VoltsDC24 $001659$ VoltsDC25 $002640$ VoltsDC	16:53:36   Date: 88/08/19     3   Record#   25     ame: SCD0S04   1  006968   Volts   DC     1  006968   Volts   DC   +15.7     2   +.001695   Volts   DC   +13.7     3   +.000896   Volts   DC   -6.8     4  001476   Volts   DC   +2.2     5  001023   Volts   DC   +.7     6  004013   Volts   DC   +.1     7  000905   Volts   DC   +.1     8  001966   Volts   DC   +.1     9  001298   Volts   DC   +.1     9  001298   Volts   DC   +.1     10   +.002756   Volts   DC  4     11   +.003510   Volts   DC   +.1     12  000019   Volts   DC   +14.3     14  0024153   Volts   DC   +14.3     14  003360   Volts   DC

LVDT: -0.058687 VDC -0.000051 Inches

Hor. Rad.=.001898 VDC 125.0 W/M^2

Position #1 CL

Time: 1	6:54:4	3 Date: 88	3/08/19	)		
Group#	3	Record#	Z6			
File na	ame: SCI	)0504				
Power s	supply:	4.9770	Volts	DC		
Cable#	1	006961	Volts	DC	+18.5	Micro-Strains
Cable#	2	+.001693	Volts	DC	+12.9	Micro-Strains
Cable#	3	+.000889	Volts	DC	-9.6	Micro-Strains
Cable#	4	001476	Volts	DC	+2.2	Micro-Strains
Cable#	5	001022	Volts	DC	+1.1	Micro-Strains
Cable#	6	004005	Volts	DC	+17.3	Micro-Strains
Cable#	7	000906	Volts	DC	+2.7	Micro-Strains
Cable#	8	001974	Volts	DC	-3.1	Micro-Strains
Cable#	9	001299	Volts	DC	+8.7	Micro-Strains
Cable#	10	+.002755	Volts	DC	8	Micro-Strains
Cable#	11	+.003512	Volts	DC	-5.5	Micro-Strains
Cable#	12	000021	Volts	DC	+10.9	Micro-Strains
Cable#	13	001312	Volts	DC	+13.9	Micro-Strains
Cable#	14	004154	Volts	DC	+10.3	Micro-Strains
Cable#	15	004342	Volts	DC	-7.9	Micro-Strains
Cable#	16	001416	Volts	DC	+10.3	Micro-Strains
Cable#	17	003085	Volts	DC	-1.2	Micro-Strains
Cable#	18	003373	Volts	DC	+5.9	Micro-Strains
Cable#	19	003346	Volts	DC	-7.6	Micro-Strains
Cable#	20	003323	Volts	DC	5	Micro-Strains
Cable#	21	002048	Volts	DC	+6.9	Micro-Strains
Cable#	22	+.002898	Volts	DC	+10.4	Micro-Strains
Cable#	23	002007	Volts	DC	-15.8	Micro-Strains
Cable#	24	001646	Volts	DC	-7.0	Micro-Strains
Cable#	25	002641	Volts	DC	-2.4	Micro-Strains

LVDT: -0.058634 VDC -0.000054 Inches

Hor. Rad.=.001747 VDC 115.1 W/M^2

Position #0 CL

16:55	:45 Date: 88	3/08/15	}		
3	Record#	27			
ame:	SCDØSØ4				
suppl	y: 4.9768	Volts	DC		
1	006958	Volts	DC	+19.6	Micro-Strains
Z	+.001692	Volts	DC	+12.5	Micro-Strains
3	+.000889	Volts	DC	-9.6	Micro-Strains
4	001476	Volts	OC	+2.2	Micro-Strains
5	001022	Volts	DC	+1.1	Micro-Strains
6	004003	Volts	DC	+18.1	Micro-Strains
7	000906	Volts	DC	+2.7	Micro-Strains
8	~.001975	Volts	DC	-3.6	Micro-Strains
9	001300	Volts	DC	+8.3	Micro-Strains
10	+,002755	Volts	DC	8	Micro-Strains
11	+,003511	Volts	DC	-5.9	Micro-Strains
12	000022	Volts	DC	+10.5	Micro-Strains
13	001312	Volts	DC	+13.9	Micro-Strains
14	004154	Volts	DC	+10.2	Micro-Strains
15	004343	Volts	DC	-8.3	Micro-Strains
16	001416	Volts	DC	+10.2	Micro-Strains
17	003085	Volts	DC	-1.3	Micro-Strains
18	003372	Volts	DC	+6.2	Micro-Strains
19	003342	Volts	DC	-6.1	Micro-Strains
20	003321	Volts	DC	+.3	Micro-Strains
21	002050	Volts	DC	+6.0	Micro-Strains
22	+.002890	Volts	DC	+7.2	Micro-Strains
23	001997	Volts	DC	-11.8	Micro-Strains
24	001633	Volts	DC	-1.8	Micro-Strains
25	002640	Volts	DC	-2.1	Micro-Strains
	16:55 3 ame:1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 9 20 21 22 23 24 25	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	16:55:45Date: $88/08/19$ 3Record#27ame:SCD0S04supply: $4.9768$ Volts1 $006958$ Volts2 $+.001692$ Volts3 $+.000889$ Volts4 $001476$ Volts5 $001022$ Volts6 $004003$ Volts7 $000906$ Volts8 $001300$ Volts9 $001300$ Volts10 $+.002755$ Volts11 $+.003511$ Volts12 $000022$ Volts13 $001312$ Volts14 $004154$ Volts15 $001416$ Volts16 $001416$ Volts17 $003085$ Volts18 $003372$ Volts20 $003321$ Volts21 $002050$ Volts23 $001997$ Volts24 $001633$ Volts25 $002640$ Volts	16:55:45   Date:   88/08/19     3   Record#   27     ame:   SCD0S04     supply:   4.9768   Volts   DC     1  006958   Volts   DC     2   +.001692   Volts   DC     3   +.000889   Volts   DC     3   +.000889   Volts   DC     4  001476   Volts   DC     5  001022   Volts   DC     6  004003   Volts   DC     7  000906   Volts   DC     8  001300   Volts   DC     9  001300   Volts   DC     10   +.002755   Volts   DC     11   +.003511   Volts   DC     12  0004022   Volts   DC     13  001300   Volts   DC     14  004154   Volts   DC     15  0043433   Volts   DC     16  003372   Volts   DC	16:55:45 Date: $88/08/19$ 3 Record# 27 ame: SCD0S04 supply: 4.9768 Volts DC +19.6 2 +.001692 Volts DC +12.5 3 +.000889 Volts DC -9.6 4001476 Volts DC +2.2 5001022 Volts DC +1.1 6004003 Volts DC +18.1 7000906 Volts DC +2.7 8001975 Volts DC +2.7 8001975 Volts DC -3.6 9001300 Volts DC +8.3 10 +.002755 Volts DC -3.6 9001300 Volts DC -88.3 10 +.002755 Volts DC -5.9 12000022 Volts DC +10.5 13001312 Volts DC +10.5 13001312 Volts DC +13.9 14004154 Volts DC +10.2 15004343 Volts DC -1.3 16001416 Volts DC -1.3 18003372 Volts DC -1.3 18003372 Volts DC +5.2 19003342 Volts DC +5.2 19003342 Volts DC +5.2 19003342 Volts DC +5.2 20003342 Volts DC +5.2 21002050 Volts DC +5.2 23001997 Volts DC -1.8 24001633 Volts DC -1.8 25002640 Volts DC -2.1

LVDT: -0.058740 VDC -0.000048 Inches

Hor. Rad.=.001582 VDC 104.2 W/M^2

Position #OFF BRIDGE

Time:	16:59:2	5 Date: 88	8/08/19	3		
Group#	3	Record#	28			
File na	ame: SC	DØSØ4				
Power :	supply:	4.9765	Volts	DC		
Cable#	1	006959	Volts	DC	+19.0	Micro-Strains
Cable#	2	+.001691	Volts	DC	+12.1	Micro-Strains
Cable#	3	+.000891	Volts	DC	-8.8	Micro-Strains
Cable#	4	001476	Volts	DC	+2.2	Micro-Strains
Cable#	5	001022	Volts	DC	+1.0	Micro-Strains
Cable#	6	004004	Volts	DC	+17.6	Micro-Strains
Cable#	7	000906	Volts	DC	+2.7	Micro-Strains
Cable#	8	001974	Volts	DC	-3.2	Micro-Strains
Cable#	9	001299	Volts	DC	+8.6	Micro-Strains
Cable#	10	+.002754	Volts	DC	-1.1	Micro-Strains
Cable#	11	+.003511	Volts	DC	-5.8	Micro-Strains
Cable#	12	000022	Volts	DC	+10.5	Micro-Strains
Cable#	13	001311	Volts	DC	+14.2	Micro-Strains
Cable#	14	004153	Volts	DC	+10.5	Micro-Strains
Cable#	15	004343	Volts	DC	-8.5	Micro-Strains
Cable#	16	001416	Volts	DC	+10.2	Micro-Strains
Cable#	17	003085	Volts	DC	-1.4	Micro-Strains
Cable#	18	003372	Volts	DC	+6.1	Micro-Strains
Cable#	19	003343	Volts	DC	-6.6	Micro-Strains
Cable#	20	003323	Volts	DC	6	Micro-Strains
Cable#	21	002054	Volts	DC	+4.4	Micro-Strains
Cable#	22	+.002884	Volts	DC	+4.9	Micro-Strains
Cable#	23	001990	Volts	DC	-9.1	Micro-Strains
Cable#	24	001623	Volts	DC	+2.1	Micro-Strains
Cable#	25	002640	Volts	DC	-2.1	Micro-Strains

LVDT: -0.058284 VDC -0.000072 Inches

Hor. Rad.=.001673 VDC 110.2 W/M^2

### MOORE CREEK BRIDGE PROJECT

Date: 89/08/01 File name: SCD0S05 Date: 88/08/19 Record# 1 Time: 18:18:59 Group# 1 TEMPERATURE PROFILE OF GIRDER: Thermistor# 1 10.3 Deg.C 11.1 Dec.C Thermistor# 2 Thermistor# 3 11.0 Deg.C Thermistor# 4 10.9 Deg.C 10.7 Deg.C Thermistor# 5 10.5 Deg.C Thermistor# 6 Thermistor# 7 10.7 Deq.C Thermistor# 8 246.6 Deg.C Instrument | Temp: 16.88 Deg.C Instrument 2 Temp: 17.94 Deg.C ZERO STRAIN VOLTAGES: Record# 2 Group# 2 Time: 18:20:30 Power supply: 4.98690 Volts DC -.006958 Volts DC Cable# 1 +.001671 Volts DC Cable# 2 +.000886 Volts DC Cable# 3 -.001477 Volts DC Cable# 4 -.001016 Volts DC Cable# 5 -.003994 Volts DC Cable# 6 -.000919 Volts DC Cable# 7 -.002005 Volts DC Cable# 8 -.001304 Volts DC Cable# 9 +.002745 Volts DC Cable# 10 +.003519 Volts DC Cable# 11 -.000029 Volts DC Cable# 12 -.001305 Volts DC Cable# 13 -.004153 Volts DC Cable# 14 -.004363 Volts DC Cable# 15 Cable# 16 -.001416 Volts DC -.003113 Volts DC Cable# 17 -.003362 Volts DC Cable# 18 -.003350 Volts DC Cable# 19 Cable# 20 -.003341 Volts DC -.002057 Volts DC Cable# 21 +.002886 Volts DC Cable# 22 -.002000 Volts DC Cable# 23 Cable# 24 -.001653 Volts DC -.002633 Volts DC Cable# 25 LVDT: -0.060292 VDC 68.8 W/M^2 Hor. Rad.= 1.0E-3 VDC Air Temp= 10.2 Deg.C Wind Speed: 5.3 MPH

Position #4 RT

Time: 1	8:35:Ø2	2 Date: 88	3/08/19	3		
Group#	3	Record#	3			
File na	ame: SCI	DØSØ5				
Power s	supply:	4.9845	Volts	DC		
Cable#	1	007002	Volts	DC	-19.3	Micro-Strains
Cable#	2	+.001671	Volts	DC	+.3	Micro-Strains
Cable#	3	+.000938	Volts	DC	+21.3	Micro-Strains
Cable#	4	001475	Volts	DC	+.5	Micro-Strains
Cable#	5	001016	Volts	DC	2	Micro-Strains
Cable#	6	004014	Volts	DC	-8.9	Micro-Strains
Cable#	7	000916	Volts	DC	+1.0	Micro-Strains
Cable#	8	001979	Volts	DC	+10.2	Micro-Strains
Cable#	9	001292	Volts	DC	+4.6	Micro-Strains
Cable#	10	+.002737	Volts	DC	-2.7	Micro-Strains
Cable#	11	+.003510	Volts	DC	-2.9	Micro-Strains
Cable#	12	000019	Volts	DC	+4.0	Micro-Strains
Cable#	13	001289	Volts	DC	+6.2	Micro-Strains
Cable#	14	004142	Volts	DC	+3.6	Micro-Strains
Cable#	15	004374	Volts	DC	-5.3	Micro-Strains
Cable#	16	001303	Volts	DC	+45.2	Micro-Strains
Cable#	17	003119	Volts	DC	-3.0	Micro-Strains
Cable#	18	003307	Volts	DC	+21.2	Micro-Strains
Cable#	19	003459	Volts	DC	-43.9	Micro-Strains
Cable#	20	003388	Volts	DC	-19.3	Micro-Strains
Cable#	21	002038	Volts	DC	+7.1	Micro-Strains
Cable#	22	+.002899	Volts	DC	+5.7	Micro-Strains
Cable#	23	002064	Volts	DC	-25.8	Micro-Strains
Cable#	24	001689	Volts	DC	-14.6	Micro-Strains
Cable#	25	-,002629	Volts	DC	+1.1	Micro-Strains

LVDT: -0.059774 VDC -0.000026 Inches

-

Hor. Rad.=.001268 VDC 83.5 W/M^2

Position #9 RT

Time: 1	8:51:0	5 Date: 88	3/08/19	}		
Group#	3	Record#	4			
File na	ame: SCl	00505				
Power :	supply:	4.9848	Volts	DC		
Cable#	1	007086	Volts	DC	-53.2	Micro-Strains
Cable#	2	+.001677	Volts	DC	+2.7	Micro-Strains
Cable#	3	+.001002	Volts	DC	+47.3	Micro-Strains
Cable#	4	001483	Volts	DC	-2.7	Micro-Strains
Cable#	5	001048	Volts	DC	-13.2	Micro-Strains
Cable#	6	004053	Volts	DC	-24.7	Micro-Strains
Cable#	7	000892	Volts	DC	+10.8	Micro-Strains
Cable#	8	001959	Volts	DC	+18.4	Micro-Strains
Cable#	9	001293	Volts	DC	+4.2	Micro-Strains
Cable#	10	+.002735	Volts	DC	-3.6	Micro-Strains
Cable#	11	+.003505	Volts	DC	-5.0	Micro-Strains
Cable#	12	000019	Volts	DC	+4.0	Micro-Strains
Cable#	13	001333	Volts	DC	-11.5	Micro-Strains
Cable#	14	-,004162	Volts	DC	-4.3	Micro-Strains
Cable#	15	004347	Volts	DC	+5.7	Micro-Strains
Cable#	16	001296	Volts	DC	+48.0	Micro-Strains
Cable#	17	003110	Volts	DC	+.7	Micro-Strains
Cable#	18	003301	Volts	DC	+23.7	Micro-Strains
Cable#	19	003483	Volts	DC	-53.3	Micro-Strains
Cable#	20	003405	Volts	DC	-26.0	Micro-Strains
Cable#	21	002041	Volts	DC	+6.0	Micro-Strains
Cable#	22	+.002890	Volts	DC	+2.1	Micro-Strains
Cable#	23	002074	Volts	DC	-29.7	Micro-Strains
Cable#	24	001693	Volts	DC	-16.2	Micro-Strains
Cable#	25	002621	Volts	DC	+4.4	Micro-Strains

LVDT: -0.062000 VDC 0.000086 Inches

Hor. Rad.=.001031 VDC 67.9 W/M^2

Position #14 RT

Time: 19:04	:37 Date: 88/08/19	
Group# 3	Record# 5	
File name:	SCDØSØ5	
Power supply	y: 4.9847 Volts DC	
Cable# 1	006955 Volts DC	0
Cable# 2	+.001705 Volts DC	+14.1
Cable# 3	+.000831 Volts DC	-22.2
Cable# 4	001522 Volts DC	-18.6
Cable# 5	001130 Volts DC	-46.6
Cable# 6	003986 Volts DC	+2.5
Cable# 7	000829 Volts DC	+36.5
Cable# 8	002041 Volts DC	-15.0
Cable# 9	001411 Volts DC	-43.4
Cable# 10	+.002783 Volts DC	+15.8
Cable# 11	+.003593 Volts DC	+30.5
Cable# 12	000072 Volts DC	-17.3
Cable# 13	001330 Volts DC	-10.3
Cable# 14	004158 Volts DC	-2.7
Cable# 15	004370 Volts DC	-3.6
Cable# 16	001384 Volts DC	+12.6
Cable# 17	003126 Volts DC	-5.7
Cable# 18	003346 Volts DC	+5.8
Cable# 19	003414 Volts DC	-26.0
Cable# 20	003371 Volts DC	-12.5
Cable# 21	002052 Volts DC	+1.6
Cable# 22	+.002878 Volts DC	-2.7
Cable# 23	002047 Volts DC	-19.0
Cable# 24	001675 Volts DC	-9.0
Cable# 25	002613 Volts DC	+7.7

Micro-Strains Micro-Strains

Micro-Strains

LVDT: -0.061929 VDC

C 0.000083

3 Inches

Hor. Rad.=.000927 VDC

61.1 W/M^2

Position #14 LT

<b>.</b>		n n n(		n		
lime:		B Date: 80	5/00/13	2		
Group#	3	Record#	ь			
File na	ame: SCI	00505				
Power e	supply:	4.9848	Volts	DC		
Cable#	1	006950	Volts	DC	+2.1	Micro-Strains
Cable#	2	+.001760	Volts	DC	+36.5	Micro-Strains
Cable#	3	+.000853	Volts	DC	-13.3	Micro-Strains
Cable#	4	001589	Volts	DC	-45.8	Micro-Strains
Cable#	5	001059	Volts	DC	-17.7	Micro-Strains
Cable#	6	003988	Volts	DC	+1.8	Micro-Strains
Cable#	7	000884	Volts	DC	+14.1	Micro-Strains
Cable#	8	002060	Volts	DC	-22.7	Micro-Strains
Cable#	9	001353	Volts	DC	-20.0	Micro-Strains
Cable#	10	+.002825	Volts	DC	+32.7	Micro-Strains
Cable#	11	+.003555	Volts	DC	+15.1	Micro-Strains
Cable#	12	000122	Volts	DC	-37.5	Micro-Strains
Cable#	13	001311	Volts	DC	-2.6	Micro-Strains
Cable#	14	004177	Volts	DC	-10.3	Micro-Strains
Cable#	15	004373	Volts	DC	-4.8	Micro-Strains
Cable#	16	001407	Volts	DC	+3.4	Micro-Strains
Cable#	17	003121	Volts	DC	-3.7	Micro-Strains
Cable#	18	003322	Volts	DC	+15.3	Micro-Strains
Cable#	19	003376	Volts	DC	-10.9	Micro-Strains
Cable#	2 <b>0</b>	003409	Volts	DC	-27.6	Micro-Strains
Cable#	21	002063	Volts	DC	-2.7	Micro-Strains
Cable#	22	+.002883	Volts	DC	7	Micro-Strains
Cable#	23	002022	Volts	DC	-9.1	Micro-Strains
Cable#	24	001708	Volts	DC	-22.1	Micro-Strains
Cable#	25	002607	Volts	DC	+10.1	Micro-Strains

LVDT: -0.062505 VDC 0.000112 Inches

Hor. Rad.=.000935 VDC 61.6 W/M^2

Position #9 LT

Time: 1	9:27:09	5 Date: 88	3/08/19	3		
Group#	3	Record#	7			
File na	ame: SCI	)ØSØ5				
Power a	supply:	4.9852	Volts	DC		
Cable#	1	007009	Volts	DC	-21.7	Micro-Strains
Cable#	2	+.001695	Volts	DC	+10.0	Micro-Strains
Cable#	3	+.000934	Volts	DC	+19.6	Micro-Strains
Cable#	4	001505	Volts	DC	-11.6	Micro-Strains
Cable#	5	001017	Volts	DC	5	Micro-Strains
Cable#	6	004128	Volts	DC	-55.1	Micro-Strains
Cable#	7	000917	Volts	DC	+.7	Micro-Strains
Cable#	8	001898	Volts	DC	+43.2	Micro-Strains
Cable#	9	001298	Volts	DC	+2.2	Micro-Strains
Cable#	10	+.002729	Volts	DC	-6.1	Micro-Strains
Cable#	11	+.003514	Volts	DC	-1.5	Micro-Strains
Cable#	12	000014	Volts	DC	+6.0	Micro-Strains
Cable#	13	001310	Volts	DC	-2.2	Micro-Strains
Cable#	14	004179	Volts	DC	-11.0	Micro-Strains
Cable#	15	004364	Volts	DC	-1.0	Micro-Strains
Cable#	16	001364	Volts	DC	+20.7	Micro-Strains
Cable#	17	003101	Volts	DC	+4.3	Micro-Strains
Cable#	18	003223	Volts	DC	+54.7	Micro-Strains
Cable#	19	003408	Volts	DC	-23.5	Micro-Strains
Cable#	20	003485	Volts	DC	-57.6	Micro-Strains
Cable#	21	002060	Volts	DC	-1.5	Micro-Strains
Cable#	22	+.002903	Volts	DC	+7.1	Micro-Strains
Cable#	23	002034	Volts	DC	-13.8	Micro-Strains
Cable#	24	001749	Volts	DC	-38.3	Micro-Strains
Cable#	25	002613	Volts	DC	+7.8	Micro-Strains

LVDT: -0.062386 VDC 0.000106 Inches

Hor. Rad.=.000609 VDC 40.1 W/M^2

Position #4 LT

Time:	9:46:4	Ø Date: 88	3/08/19	3		
Group#	3	Record#	8			
File na	ame: SC	DØSØ5				
Power :	supply:	4.9860	Volts	DC		
Cable#	1	006971	Volts	DC	-5.8	Micro-Strains
Cable#	2	+.001663	Volts	DC	-3.1	Micro-Strains
Cable#	3	+.000899	Volts	DC	+5.3	Micro-Strains
Cable#	4	001468	Volts	DC	+3.5	Micro-Strains
Cable#	5	001004	Volts	DC	+4.8	Micro-Strains
Cable#	6	004032	Volts	DC	-15.7	Micro-Strains
Cable#	7	000933	Volts	DC	-5.8	Micro-Strains
Cable#	8	001971	Volts	DC	+13.7	Micro-Strains
Cable#	9	001 302	Volts	DC	+.7	Micro-Strains
Cable#	10	+.002734	Volts	DC	-4.2	Micro-Strains
Cable#	11	+.003516	Volts	DC	-1.0	Micro-Strains
Cable#	12	000015	Volts	DC	+5.6	Micro-Strains
Cable#	13	001288	Volts	DC	+6.7	Micro-Strains
Cable#	14	004131	Volts	DC	+8.5	Micro-Strains
Cable#	15	004381	Volts	DC	-7.5	Micro-Strains
Cable#	16	001371	Volts	DC	+18.0	Micro-Strains
Cable#	17	003139	Volts	DC	-10.5	Micro-Strains
Cable#	18	003228	Volts	DC	+53.0	Micro-Strains
Cable#	19	003401	Volts	DC	-20.5	Micro-Strains
Cable#	20	003469	Volts	DC	-51.0	Micro-Strains
Cable#	21	002056	Volts	DC	+.2	Micro-Strains
Cable#	22	+.002912	Volts	DC	+10.5	Micro-Strains
Cable#	23	002029	Volts	DC	-11.6	Micro-Strains
Cable#	24	001752	Volts	DC	-39.4	Micro-Strains
Cable#	25	002612	Volts	DC	+8.3	Micro-Strains

LVDT: -0.062357 VDC 0.000104 Inches

Hor. Rad.=.000362 VDC 23.8 W/M^2

APPENDIX C

**B-TRAIN FIELD DATA** 

This appendix provides the raw data recorded in the field for the B-Train (ore trucks) tests. The file name corresponds to the test name used for documentation and organization of the data. The letters in the names imply the test situation.

Before testing began, the researchers prepared the following technique for documentation of each test series. All data was stored on a floppy disk under a file name. Thus a seven-letter file name was selected to describe the test conditions. The seven letters were formed as follows.



Based on this criteria, all static load tests for the B-Train were described by  $S??\phi B??$  where the question marks are filled in for the particular test conditions.

Each file is divided into three groups of data. The three groups of information are described below.

- Group #1 = This group contains the temperatures of the girder profile and instrument temperature at the beginning of the test.
- Group #2 = This group contains the initial unstrained voltages for all the strain gages (zero readings) taken immediately preceding the tests. Air temperature and wind speed are also recorded at this time.
- Group #3 = This group provides the strained voltages for all the strain gages the LVDT voltage and the horizontal solar radiation at the time of the test.

### MOORE CREEK BRIDGE PROJECT

Date: 89/07/31 File name: SLDØBØ6 Date: 88/08/19 Time: 19:56:33 Group# 1 Record# 1 TEMPERATURE PROFILE OF GIRDER: Thermistor# 1 8.9 Dec.C Thermistor# 2 9.4 Deg.C Thermistor# 3 9.4 Deg.C Thermistor# 4 9.3 Deg.C Thermistor# 5 9.2 Deg.C 9.1 Deg.C Thermistor# 6 9.3 Deg.C Thermistor# 7 Thermistor# 8 246.6 Dec.C Instrument | Temp: 15.33 Deg.C Instrument 2 Temp: 15.47 Deg.C ZERO STRAIN VOLTAGES: Record# 2 Time: 19:58:27 Group# 2 Power supply: 4.98670 Volts DC -.006939 Volts DC Cable# 1 +.001657 Volts DC Cable# 2 Cable# 3 +,000869 Volts DC -.001461 Volts DC Cable# 4 -.001003 Volts DC Cable# 5 -.003964 Volts DC Cable# 6 Cable# 7 -.000934 Volts DC Cable# 8 -.002028 Volts DC -,001307 Volts DC Cable# 9 +.002743 Volts DC Cable# 10 +.003520 Volts DC Cable# 11 -.000021 Volts DC Cable# 12 -.001288 Volts DC Cable# 13 -.004136 Volts DC Cable# 14 -.004379 Volts DC Cable# 15 -.001412 Volts DC Cable# 16 -.003129 Volts DC Cable# 17 -.003346 Volts DC Cable# 18 -.003360 Volts DC Cable# 19 -.003354 Volts DC Cable# 20 -.002061 Volts DC Cable# 21 Cable# 22 +.002874 Volts DC Cable# 23 -,002008 Volts DC -.001670 Volts DC Cable# 24 -.002611 Volts DC Cable# 25 LVDT: -0.061760 VDC 19.5 W/M^2 Hor, Rad. = 3.0E-4 VDC Air Temp= 11.2 Deg.C Wind Speed: 5.9 MPH

Position #14 LT

Time: 2	20:04:22	2 Date: 88	3/08/19	3		
Group#	3	Record#	3			
File na	ame: SL[	<b>30806</b>				
Power a	supply:	4.9908	Volts	DC		
Cable#	1	006963	Volts	DC	-7.4	Micro-Strains
Cable#	2	+.002043	Volts	DC	+156.3	Micro-Strains
Cable#	3	+.000731	Volts	DC	-56.3	Micro-Strains
Cable#	4	001980	Volts	DC	-210.2	Micro-Strains
Cable#	5	001280	Volts	DC	-112.3	Micro-Strains
Cable#	6	004007	Volts	DC	-16.1	Micro-Strains
Cable#	7	000726	Volts	DC	+84.9	Micro-Strains
Cable#	8	002231	Volts	DC	-81.7	Micro-Strains
Cable#	9	001589	Volts	DC	-113.1	Micro-Strains
Cable#	10	+.003119	Volts	DC	+150.6	Micro-Strains
Cable#	11	+.003712	Volts	DC	+76.2	Micro-Strains
Cable#	12	000490	Volts	DC	-188.9	Micro-Strains
Cable#	13	001319	Volts	DC	-12.0	Micro-Strains
Cable#	14	004197	Volts	DC	-23.1	Micro-Strains
Cable#	15	004442	Volts	DC	-23.8	Micro-Strains
Cable#	16	001423	Volts	DC	-4.0	Micro-Strains
Cable#	17	003227	Volts	DC	- 37.8	Micro-Strains
Cable#	18	003328	Volts	00	+8.2	Micro-Strains
Cable#	19	003445	Volts	DC	-32.6	Micro-Strains
Cable#	20	003526	Volts	DC	-67.1	Micro-Strains
Cable#	21	002073	Volts	DC	-4.1	Micro-Strains
Cable#	22	+.002880	Volts	DC	+1.4	Micro-Strains
Cable#	23	002064	Volts	DC	-21.5	Micro-Strains
Cable#	24	001775	Volts	DC	-41.1	Micro-Strains
Cable#	25	002549	Volts	DC	+26.1	Micro-Strains

### LVDT: -0.066079 VDC 0.000218 Inches

Hor. Rad.=.000197 VDC 13.0 W/M^2

Position #9 LT

Time: 2	0:06:15	5 Date: 88	3/08/19			
Group#	3	Record#	4			
File na	me: SLD	<b>WB06</b>				
Power s	upply:	4.9908	Volts	DC		
Cable#	1	007098	Volts	DC	-62.3	Micro-Strains
Cable#	Z	+,001884	Volts	DC	+91.7	Micro-Strains
Cable#	3	+.000929	Volts	DC	+24.1	Micro-Strains
Cable#	4	001746	Volts	DC	-115.2	Micro-Strains
Cable#	5	001147	Volts	DC	-58.2	Micro-Strains
Cable#	6	004242	Volts	DC	-111.6	Micro-Strains
Cable#	7	000818	Volts	DC	+47.5	Micro-Strains
Cable#	8	001925	Volts	DC	+42.5	Micro-Strains
Cable#	9	001401	Volts	DC	-37.4	Micro-Strains
Cable#	10	+.002846	Volts	DC	+40.6	Micro-Strains
Cable#	11	+.003580	Volts	DC	+23.0	Micro-Strains
Cable#	12	000168	Volts	DC	-59.2	Micro-Strains
Cable#	13	001402	Volts	DC	-45.3	Micro-Strains
Cable#	14	004370	Volts	DC	-92.6	Micro-Strains
Cable#	15	004342	Volts	DC	+16.3	Micro-Strains
Cable#	16	001279	Volts	DC	+53.9	Micro-Strains
Cable#	17	003006	Volts	DC	+49.8	Micro-Strains
Cable#	18	003062	Volts	DC	+113.7	Micro-Strains
Cable#	19	003554	Volts	DC	-75.8	Micro-Strains
Cable#	200	003732	Volts	DC	-148.8	Micro-Strains
Cable#	21	002059	Volts	DC	+1.5	Micro-Strains
Cable#	22	+.002937	Volts	DC	+24.0	Micro-Strains
Cable#	23	002133	Volts	DC	-48.9	Micro-Strains
Cable#	24	001925	Volts	DC	-100.5	Micro-Strains
Cable#	25	002564	Volts	DC	+20.0	Micro-Strains

### LVDT: -0.068221 VDC 0.000327 Inches

Hor. Rad.=.000173 VDC 11.4 W/M^2

Position #4 LT

Time: 20	:07:40	Date: 88	3/08/15	J		
Group#	3	Record#	5			
File nam	e: SLDQ	0B06				
Power su	pply:	4.9907	Volts	DC		
Cable#	1 -	.007222	Volts	DC	-112.7	Micro-Strains
Cable#	2 -	+.001717	Volts	DC	+23.8	Micro-Strains
Cable#	3 1	+.001141	Volts	DC	+110.2	Micro-Strains
Cable#	4 -	001530	Volts	DC	-27.5	Micro-Strains
Cable#	5 -	.001025	Volts	DC	-8.6	Micro-Strains
Cable#	6 -	004503	Volts	DC	-217.7	Micro-Strains
Cable#	7-	000914	Volts	DC	+8.4	Micro-Strains
Cable#	8 -	001563	Volts	DC	+189.5	Micro-Strains
Cable#	9 -	.001276	Volts	DC	+12.9	Micro-Strains
Cable# 1	Ø +	+.002692	Volts	DC	-21.4	Micro-Strains
Cable# 1	1 -	.003493	Volts	DC	-12.0	Micro-Strains
Cable# 1	2 +	+.000021	Volts	DC	+16.9	Micro-Strains
Cable# 1	3 -	.001298	Volts	DC	-3.6	Micro-Strains
Cable# 1	4 -	.004161	Volts	DC	-8.7	Micro-Strains
Cable# 1	5 -	.004391	Volts	DC	-3.4	Micro-Strains
Cable# 1	6 -	001161	Volts	DC	+101.2	Micro-Strains
Cable# 1	7-	.003143	Volts	DC	-4.6	Micro-Strains
Cable# 1	8 -	002839	Volts	DC	+202.2	Micro-Strains
Cable# 1	9 -	003628	Volts	DC	-105.2	Micro-Strains
Cable# 2	0-	003876	Volts	DC	-205.9	Micro-Strains
Cable# 2	1 -	002036	Volts	DC	+10.6	Micro-Strains
Cable# 2	2 +	+,003004	Volts	DC	+50.6	Micro-Strains
Cable# 2	3 -	.002150	Volts	DC	-55.7	Micro-Strains
Cable# 2	4 -	002005	Volts	DC	-132.3	Micro-Strains
Cable# 2	5-	002593	Volts	DC	+8.2	Micro-Strains

LVDT: -0.066497 VDC 0.000240 Inches

Hor. Rad.=.000167 VDC 11.0 W/M^2

Position #OFF BRIDGE

Time: 2	20:10:05	] Date: 88	3/08/15	}					
Group#	3	Record#	6						
File na	File name: SLDØBØ6								
Power :	supply:	4.9905	Volts	DC					
Cable#	1	006941	Volts	DC	+1.3	Micro-Strains			
Cable#	2	+.001656	Volts	DC	9	Micro-Strains			
Cable#	3	+.000867	Volts	DC	-1.1	Micro-Strains			
Cable#	4	001460	Volts	DC	+.9	Micro-Strains			
Cable#	5	001001	Volts	DC	+1.1	Micro-Strains			
Cable#	6	003966	Volts	DC	+.4	Micro-Strains			
Cable#	7	000938	Volts	DC	-1.3	Micro-Strains			
Cable#	8	002034	Volts	DC	-1.8	Micro-Strains			
Cable#	9	001307	Volts	DC	+.4	Micro-Strains			
Cable#	10	+.002745	Volts	DC	0	Micro-Strains			
Cable#	11	+.003523	Volts	DC	+.1	Micro-Strains			
Cable#	12	~.000020	Volts	OC	+.4	Micro-Strains			
Cable#	13	001287	Volts	DC	+.8	Micro-Strains			
Cable#	14	004138	Volts	DC	+.5	Micro-Strains			
Cable#	15	004385	Volts	DC	-1.1	Micro-Strains			
Cable#	16	001413	Volts	DC	+.0	Micro-Strains			
Cable#	17	003135	Volts	DC	-1.4	Micro-Strains			
Cable#	18	003347	Volts	DC	+.6	Micro-Strains			
Cable#	19	003364	Volts	DC	6	Micro-Strains			
Cable#	20	003358	Volts	DC	6	Micro-Strains			
Cable#	21	002064	Volts	DC	6	Micro-Strains			
Cable#	22	+.002874	Volts	DC	9	Micro-Strains			
Cable#	23	002010	Volts	DC	2	Micro-Strains			
Cable#	24	001674	Volts	DC	+1.1	Micro-Strains			
Cable#	25	002609	Volts	DC	+1.6	Micro-Strains			

# LVDT: -0.063100 VDC 0.000068 Inches

Hor. Rad.=.000143 VDC 9.4 W/M^2

### MOORE CREEK BRIDGE PROJECT

File name: SLD0B08 Date: 89/07/31 Date: 88/08/20 Time: 10:05:37 Group# 1 Record# 1 TEMPERATURE PROFILE OF GIRDER: 8.5 Deg.C Thermistor# 1 9.1 Deg.C Thermistor# 2 9.2 Deg.C Thermistor# 3 9.2 Deg.C Thermistor# 4 Thermistor# 5 9.1 Deg.C 8.9 Deg.C Thermistor# 6 Thermistor# 7 8.9 Deg.C Thermistor# 8 247.3 Deg.C Instrument 1 Temp: 22.54 Deg.C Instrument 2 Temp: 22.69 Deg.C ZERO STRAIN VOLTAGES: Record# 2 Time: 10:07:22 Group# 2 Power supply: 4.97170 Volts DC -.006939 Volts DC Cable# 1 +.001639 Volts DC Cable# 2 +.000897 Volts DC Cable# 3 -.001427 Volts DC Cable# 4 -.000978 Volts DC Cable# 5 -.003970 Volts DC Cable# 6 -.000943 Volts DC Cable# 7 -.001998 Volts DC Cable# 8 Cable# 9 -.001314 Volts DC +.002765 Volts DC Cable# 10 +.003535 Volts DC Cable# 11 -.000021 Volts DC Cable# 12 -.001297 Volts DC Cable# 13 -.004133 Volts DC Cable# 14 -.004358 Volts DC Cable# 15 -.001414 Volts DC Cable# 16 Cable# 17 -.003089 Volts DC -.003336 Volts DC Cable# 18 -.003352 Volts DC Cable# 19 Cable# 20 -.003323 Volts DC -.002068 Volts DC Cable# 21 +.002844 Volts DC Cable# 22 Cable# 23 -.001994 Volts DC -.001663 Volts DC Cable# 24 -.002576 Volts DC Cable# 25 LVDT: -0.062771 VDC Hor. Rad. = 1.0E-3 VDC 65.8 W/M^2 Air Temp= 10.0 Deg.C Wind Speed: 6.6 MPH

C-7

Position #14 LT

Time: 10	0:16:0E	i Date: 88	3/08/20	)		
Group#	3	Record#	3			
File nam	me: SLC	0808				
Power su	upply:	4.9722	Volts	DC		
Cable#	1	006957	Volts	DC	-7.1	Micro-Strains
Cable#	2	+.002025	Volts	DC	+157.3	Micro-Strains
Cable#	3	+.000756	Volts	DC	-57.5	Micro-Strains
Cable#	4	001945	Volts	DC	-210.9	Micro-Strains
Cable#	5	001262	Volts	DC	-115.8	Micro-Strains
Cable#	6	004010	Volts	DC	-16.1	Micro-Strains
Cable#	7	~.000729	Volts	DC	+87.3	Micro-Strains
Cable#	8	002197	Volts	DC	-81.0	Micro-Strains
Cable#	9	001597	Volts	DC	-114.3	Micro-Strains
Cable#	10	+.003136	Volts	DC	+150.0	Micro-Strains
Cable#	11	+.003726	Volts	DC	+77.1	Micro-Strains
Cable#	12	000489	Volts	DC	-189.1	Micro-Strains
Cable#	13	001327	Volts	DC	-12.0	Micro-Strains
Cable#	14	004190	Volts	00	-22.8	Micro-Strains
Cable#	15	004418	Volts	DC	-24.0	Micro-Strains
Cable#	16	001425	Volts	DC	-4.4	Micro-Strains
Cable#	17	003186	Volts	DC	-38.5	Micro-Strains
Cable#	18	003319	Volts	DC	+6.9	Micro-Strains
Cable#	19	003435	Volts	DC	-32.9	Micro-Strains
Cable# 2	2 <b>0</b>	003490	Volts	DC	-66.3	Micro-Strains
Cable# 2	21	002077	Volts	DC	-3.5	Micro-Strains
Cable# 2	22	+.002848	Volts	DC	+1.5	Micro-Strains
Cable# 2	23	002048	Volts	DC	-21.4	Micro-Strains
Cable# 2	24	001764	Volts	DC	-40.1	Micro-Strains
Cable# 2	25	002515	Volts	DC	+25.0	Micro-Strains

LVDT: -0.067084 VDC 0.000218 Inches

Hor. Rad.=.001355 VDC 89.3 W/M^2

C-8

Position #9 LT

Time: 1	0:29:51	Date: 88	3/08/20	0		
Group#	3	Record#	4			
File na	ame: SLC	00808				
Power :	supply:	4.9727	Volts	DC		
Cable#	1	007089	Volts	DC	-60.6	Micro-Strains
Cable#	2	+.001869	Volts	DC	+93.6	Micro-Strains
Cable#	3	+.000955	Volts	DC	+23.6	Micro-Strains
Cable#	4	001713	Volts	DC	-116.4	Micro-Strains
Cable#	5	001125	Volts	DC	-59.9	Micro-Strains
Cable#	6	004244	Volts	DC	-111.4	Micro-Strains
Cable#	7	000821	Volts	DC	+49.8	Micro-Strains
Cable#	8	001896	Volts	DC	+41.7	Micro-Strains
Cable#	9	001410	Volts	DC	-38.7	Micro-Strains
Cable#	10	+.002868	Volts	DC	+41.4	Micro-Strains
Cable#	11	+.003595	Volts	DC	+24.0	Micro-Strains
Cable#	12	000170	Volts	DC	-60.2	Micro-Strains
Cable#	13	001412	Volts	DC	-46.2	Micro-Strains
Cable#	14	004367	Volts	DC	-93.9	Micro-Strains
Cable#	15	004316	Volts	DC	+17.3	Micro-Strains
Cable#	16	001280	Volts	DC	+54.1	Micro-Strains
Cable#	17	002962	Volts	DC	+50.8	Micro-Strains
Cable#	18	~.003055	Volts	DC	+112.1	Micro-Strains
Cable#	19	003545	Volts	DC	-76.5	Micro-Strains
Cable#	20	003696	Volts	DC	-148.2	Micro-Strains
Cable#	21	002063	Volts	DC	+2.2	Micro-Strains
Cable#	22	+.002906	Volts	DC	+24.4	Micro-Strains
Cable#	23	002120	Volts	DC	-50.0	Micro-Strains
Cable#	24	001915	Volts	DC	-100.1	Micro-Strains
Cable#	25	002531	Volts	DC	+18.6	Micro-Strains

LVDT: -0.069459 VDC 0.000338 Inches

Hor. Rad.=.001741 VDC 114.7 W/M^2

Position #4 LT

Time: 1	0:40:57	'Date: 88	3/08/20	>		
Group#	3	Record#	5			
File na	me: SLC	XØBØ8				
Power s	upply:	4.9719	Volts	DC		
Cable#	1	007217	Volts	DC	-113.2	Micro-Strains
Cable#	2	+.001701	Volts	DC	+25.3	Micro-Strains
Cable#	3	+.001174	Volts	DC	+112.9	Micro-Strains
Cable#	4	001496	Volts	DC	-28.1	Micro-Strains
Cable#	5	001000	Volts	DC	-9.0	Micro-Strains
Cable#	6	004519	Volts	DC	-223.8	Micro-Strains
Cable#	7	000919	Volts	DC	+9.8	Micro-Strains
Cable#	8	001518	Volts	DC	+195.6	Micro-Strains
Cable#	9	001280	Volts	DC	+13.8	Micro-Strains
Cable#	10	+.002711	Volts	DC	-21.9	Micro-Strains
Cable#	11	+.003505	Volts	DC	-12.2	Micro-Strains
Cable#	12	+.000022	Volts	DC	+17.4	Micro-Strains
Cable#	13	001310	Volts	DC	-5.2	Micro-Strains
Cable#	14	004158	Volts	DC	-10.0	Micro-Strains
Cable#	15	004363	Volts	DC	-1.9	Micro-Strains
Cable#	16	001163	Volts	DC	+101.2	Micro-Strains
Cable#	17	003097	Volts	DC	-3.1	Micro-Strains
Cable#	18	002823	Volts	DC	+204.3	Micro-Strains
Cable#	19	003615	Volts	DC	-104.6	Micro-Strains
Cable#	20	003847	Volts	DC	-208.5	Micro-Strains
Cable#	21	002038	Volts	DC	+12.0	Micro-Strains
Cable#	22	+.002979	Volts	DC	+53.7	Micro-Strains
Cable#	23	002138	Volts	DC	-57.3	Micro-Strains
Cable#	24	001999	Volts	DC	-133.6	Micro-Strains
Cable#	25	002562	Volts	DC	+5.8	Micro-Strains

LVDT: -0.067700 VDC 0.000249 Inches

Hor. Rad.=.002040 VDC 134.4 W/M^2

#### MOORE CREEK BRIDGE PROJECT

Date: 89/07/31 File name: SCDØB10 Date: 88/08/20 Time: 11:19:52 Group# 1 Record# 1 TEMPERATURE PROFILE OF GIRDER: Thermistor# 1 7.9 Deg.C Thermistor# 2 8.7 Deg.C Thermistor# 3 8.9 Deg.C Thermistor# 4 8.9 Deg.C Thermistor# 5 8.7 Deg.C Thermistor# 6 8.5 Deg.C 8.6 Deg.C Thermistor# 7 Thermistor# 8 246.6 Deg.C Instrument 1 Temp: 17.85 Deg.C Instrument 2 Temp: 17.66 Deg.C ZERO STRAIN VOLTAGES: Group# 2 Record# 2 Time: 11:24:00 Power supply: 4.98040 Volts DC -.006952 Volts DC Cable# 1 +.001632 Volts DC Cable# 2 +.000896 Volts DC Cable# 3 -.001425 Volts DC Cable# 4 -.000977 Volts DC Cable# 5 -.003978 Volts DC Cable# 6 -.000955 Volts DC Cable# 7 Cable# 8 -.002006 Volts DC -.001319 Volts DC

Cable# 9 +.002763 Volts DC Cable# 10 +.003537 Volts DC Cable# 11 Cable# 12 -.000025 Volts DC -.001298 Volts DC Cable# 13 -.004137 Volts DC Cable# 14 Cable# 15 -.004374 Volts DC -.001421 Volts DC Cable# 16 -.003103 Volts DC Cable# 17 -.003347 Volts DC Cable# 18 Cable# 19 -.003356 Volts DC -.003328 Volts DC Cable# 20 -.002067 Volts DC Cable# 21 +.002850 Volts DC Cable# 22 -.002003 Volts DC Cable# 23 -.001672 Volts DC Cable# 24 -.002580 Volts DC Cable# 25 LVDT: -0.063785 VDC Hor. Rad.= 1.4E-3 VDC 95.4 W/M^2 Air Temp= 8.5 Deg.C Wind Speed: 4.1 MPH

.

Position #14 CTR

	1	1 0 1 . 0/	3 / A A / 3 /	-		<b>`</b>
lime:	34:5	I Date: 88	3/08/29	0		
Group#	ు 	Kecord#	3			
File na	ame: SCI	DORIO		-		
Power :	supply:	4.9793	Volts	DC		
Cable#	1	006978	Volts	DC	-11.2	Micro-Strains
Cable#	Z	+.001918	Volts	DC	+116.6	Micro-Strains
Cable#	3	+.000713	Volts	DC	-74.3	Micro-Strains
Cable#	4	001814	Volts	DC	-158.3	Micro-Strains
Cable#	5	001398	Volts	DC	-171.5	Micro-Strains
Cable#	6	004008	Volts	DC	-12.6	Micro-Strains
Cable#	7	000643	Volts	DC	+127.0	Micro-Strains
Cable#	8	~.002170	Volts	DC	-66.9	Micro-Strains
Cable#	9	001729	Volts	DC	-165.6	Micro-Strains
Cable#	10	+.003049	Volts	DC	+115.7	Micro-Strains
Cable#	11	+.003811	Volts	DC	+111.0	Micro-Strains
Cable#	12	000382	Volts	DC	-144.1	Micro-Strains
Cable#	13	001341	Volts	DC	-17.4	Micro-Strains
Cable#	14	004181	Volts	DC	-18.1	Micro-Strains
Cable#	15	004450	Volts	DC	-31.0	Micro-Strains
Cable#	16	001415	Volts	DC	+2.3	Micro-Strains
Cable#	17	003180	Volts	DC	-30.9	Micro-Strains
Cable#	18	-,003343	Volts	DC	+1.3	Micro-Strains
Cable#	19	003480	Volts	DC	-49.6	Micro-Strains
Cable#	20	003454	Volts	DC	-50.4	Micro-Strains
Cable#	21	002065	Volts	DC	+.6	Micro-Strains
Cable#	22	+.002848	Volts	DC	5	Micro-Strains
Cable#	23	002079	Volts	DC	- 30.4	Micro-Strains
Cahle#	24	001742	Volts	DC	-28.0	Micro-Strains
Cable#	25	002526	Volts	DC	+21.8	Micro-Strains
ᇦᆑᆑᆂᇻᆊ						

## LVDT: -0.066764 VDC 0.000151 Inches

Hor. Rad.=.001166 VDC 76.8 W/M^2

Position #9 CTR

Time:	11:47:05	5 Date: 88	3/08/20	<b>)</b>		
Group#	3	Record#	4			
File na	ame: SCE	00810				
Power :	supply:	4.9783	Volts	DC		
Cable#	1	007152	Volts	DC	-82.6	Micro-Strains
Cable#	2	+.001798	Volts	DC	+67.9	Micro-Strains
Cable#	3	+.000977	Volts	DC	+33.1	Micro-Strains
Cable#	4	001638	Volts	DC	-86.9	Micro-Strains
Cable#	5	001199	Volts	DC	-90.6	Micro-Strains
Cable#	6	004187	Volts	DC	-85.8	Micro-Strains
Cable#	7	000778	Volts	DC	+71.9	Micro-Strains
Cable#	8	001934	Volts	DC	+28.9	Micro-Strains
Cable#	9	001451	Volts	DC	-53.5	Micro-Strains
Cable#	10	+.002846	Volts	DC	+34.0	Micro-Strains
Cable#	11	+.003616	Volts	DC	+32.5	Micro-Strains
Cable#	12	000144	Volts	DC	-48.0	Micro-Strains
Cable#	13	001477	Volts	DC	-72.2	Micro-Strains
Cable#	14	004307	Volts	DC	-69.1	Micro-Strains
Cable#	15	004289	Volts	DC	+33.5	Micro-Strains
Cable#	16	001213	Volts	DC	+83.5	Micro-Strains
Cable#	17	003017	Volts	DC	+33.7	Micro-Strains
Cable#	18	003139	Volts	DC	+82.1	Micro-Strains
Cable#	19	003637	Valts	DC	-112.2	Micro-Strains
Cable#	20	003608	Volts	DC	-111.8	Micro-Strains
Cable#	21	002040	Volts	DC	+10.4	Micro-Strains
Cable#	22	+.002891	Volts	DC	+16.8	Micro-Strains
Cable#	23	002177	Volts	DC	-69.5	Micro-Strains
Cable#	24	001854	Volts	DC	-72.6	Micro-Strains
Cable#	25	002536	Volts	DC	+17.5	Micro-Strains

LVDT: -0.068623 VDC 0.000245 Inches

Hor. Rad.=.001314 VDC 86.6 W/M^2

Position #4 CTR

Time: 1	1:56:52	Date: 88	3/08/20	)		
Group#	3	Record#	5			
File na	me: SCD	00810				
Power s	upply:	4.9777	Volts	DC		
Cable#	1	007352	Volts	DC	-164.3	Micro-Strains
Cable#	2	+.001670	Volts	DC	+15.8	Micro-Strains
Cable#	3	+.001296	Volts	DC	+163.0	Micro-Strains
Cable#	4	001470	Volts	DC	-18.6	Micro-Strains
Cable#	5	001020	Volts	DC	-17.7	Micro-Strains
Cable#	6	004391	Volts	DC	-169.0	Micro-Strains
Cable#	7	000918	Volts	DC	+14.9	Micro-Strains
Cable#	8	001647	Volts	DC	+145.6	Micro-Strains
Cable#	9	001280	Volts	DC	+15.5	Micro-Strains
Cable#	10	+.002719	Volts	DC	-17.2	Micro-Strains
Cable#	11	+.003497	Volts	DC	-15.4	Micro-Strains
Cable#	12	+.000009	Volts	DC	+13.7	Micro-Strains
Cable#	13	001311	Volts	DC	-5.5	Micro-Strains
Cable#	14	004155	Volts	DC	-8.1	Micro-Strains
Cable#	15	004380	Volts	DC	-3.4	Micro-Strains
Cable#	16	001042	Volts	DC	+152.2	Micro-Strains
Cable#	17	003108	Volts	DC	-2.7	Micro-Strains
Cable#	18	002959	Volts	DC	+153.6	Micro-Strains
Cable#	19	003752	Volts	DC	-158.1	Micro-Strains
Cable#	20	003722	Volts	DC	-157.3	Micro-Strains
Cable#	21	002013	Volts	DC	+21.0	Micro-Strains
Cable#	2 Z	+.002948	Volts	DC	+39.6	Micro-Strains
Cable#	23	002208	Volts	DC	-81.9	Micro-Strains
Cable#	24	~.001920	Volts	DC	-98.9	Micro-Strains
Cable#	25	002560	Volts	DC	+7.6	Micro-Strains

LVDT: -0.067189 VDC 0.000172 Inches

Hor. Rad.=.001323 VDC 87.2 W/M^2

Position #OFF BRIDGE

Time	12:03:24	1 Date: 88	3/08/20	0				
Group#	3	Record#	6					
File name: SCDØB10								
Power s	supply:	4.9776	Volts	DC				
Cable#	1	006947	Volts	DC	+.4	Micro-Strains		
Cable#	2	+.001627	Volts	DC	-1.7	Micro-Strains		
Cable#	3	+.000891	Volts	DC	-1.8	Micro-Strains		
Cable#	4	001421	Volts	DC	+1.3	Micro-Strains		
Cable#	5	000974	Volts	DC	+1.0	Micro-Strains		
Cable#	6	003974	Volts	DC	+.7	Micro-Strains		
Cable#	7	000961	Volts	DC	-2.7	Micro-Strains		
Cable#	8	002010	Volts	DC	-2.1	Micro-Strains		
Cable#	9	001322	Volts	DC	-1.5	Micro-Strains		
Cable#	10	+.002762	Volts	DC	+.2	Micro-Strains		
Cable#	11	+.003535	Volts	DC	0	Micro-Strains		
Cable#	12	000027	Volts	DC	8	Micro-Strains		
Cable#	13	001296	Volts	DC	+.5	Micro-Strains		
Cable#	14	004136	Volts	DC	5	Micro-Strains		
Cable#	15	004376	Volts	DC	-1.8	Micro-Strains		
Cable#	16	001421	Volts	DC	3	Micro-Strains		
Cable#	17	~.003103	Volts	DC	7	Micro-Strains		
Cable#	18	003345	Volts	DC	+.0	Micro-Strains		
Cable#	19	003358	Volts	DC	-1.5	Micro-Strains		
Cable#	20	003330	Volts	DC	-1.5	Micro-Strains		
Cable#	Z 1	002064	Volts	DC	+.7	Micro-Strains		
Cable#	22	+.002849	Volts	DC	+.2	Micro-Strains		
Cable#	23	002002	Volts	DC	1	Micro-Strains		
Cable#	24	001674	Volts	DC	-1.Z	Micro-Strains		
Cable#	25	002572	Volts	ÐC	+2.7	Micro-Strains		

LVDT: -0.064538 VDC 0.000038 Inches

Hor. Rad.=.001373 VDC 90.4 W/M^2

### MOORE CREEK BRIDGE PROJECT

Date: 89/07/31 File name: SRDØB11 Date: 88/08/20 Record# 1 Time: 12:18:35 Group# 1 TEMPERATURE PROFILE OF GIRDER: Thermistor# 1 7.5 Deg.C Thermistor# 2 8.0 Deg.C Thermistor# 3 8.0 Deg.C Thermistor# 4 8.1 Deg.C Thermistor# 5 7.9 Deg.C Thermistor# 6 7.9 Deg.C Thermistor# 7 8.0 Deg.C Thermistor# 8 246.6 Deg.C Instrument | Temp: 15.75 Deg.C Instrument 2 Temp: 15.8 Deg.C ZERO STRAIN VOLTAGES: Record# 2 Time: 12:20:20 Group# 2 Power supply: 4.97840 Volts DC -.006947 Volts DC Cable# 1 Cable# 2 +.001627 Volts DC +,000892 Volts DC Cable# 3 -.001421 Volts DC Cable# 4 -.000974 Volts DC Cable# 5 -.003973 Volts DC Cable# 6 -.000961 Volts DC Cable# 7 Cable# 8 -.002010 Volts DC -.001324 Volts DC Cable# 9 +.002764 Volts DC Cable# 10 +.003538 Volts DC Cable# 11 -.000027 Volts DC Cable# 12 -.001295 Volts DC Cable# 13 -.004136 Volts DC Cable# 14 -.004377 Volts DC Cable# 15 -.001420 Volts DC Cable# 16 -.003103 Volts DC Cable# 17 -.003345 Volts DC Cable# 18 -.003358 Volts DC Cable# 19 -.003329 Volts DC Cable# 20 -.002066 Volts DC Cable# 21 +.002848 Volts DC Cable# 22 -.002001 Volts DC Cable# 23 -.001674 Volts DC Cable# 24 -.002571 Volts DC Cable# 25 LVDT: -0.064590 VDC Hor. Rad.= 1.8E-3 VDC 117.9 W/M^2 Air Temp= 7.9 Deg.C Wind Speed: 8.1 MPH

C-16
Position #14 RT

Time: 12:25:01 Date: 88/08/20							
Group#	3	Record#	3				
File na	ame: SR[	DØB11					
Power :	supply:	4.9783	Volts	DC			
Cable#	1	006981	Volts	DC	-13.9	Micro-Strains	
Cable#	2	+.001836	Volts	DC	+85.1	Micro-Strains	
Cable#	3	+.000682	Volts	DC	-85.4	Micro-Strains	
Cable#	4	001704	Volts	DC	-115.1	Micro-Strains	
Cable#	5	001503	Volts	DC	-215.4	Micro-Strains	
Cable#	6	004000	Volts	DC	-11.0	Micro-Strains	
Cable#	7	000569	Volts	DC	+159.7	Micro-Strains	
Cable#	8	002142	Volts	DC	-53.7	Micro-Strains	
Cable#	9	001830	Volts	DC	-204.2	Micro-Strains	
Cable#	10	+.002979	Volts	DC	+86.9	Micro-Strains	
Cable#	11	+.003879	Volts	DC	+137.8	Micro-Strains	
Cable#	12	000291	Volts	DC	-106.5	Micro-Strains	
Cable#	13	001351	Volts	DC	-22.5	Micro-Strains	
Cable#	14	004169	Volts	DC	-13.3	Micro-Strains	
Cable#	15	004463	Volts	DC	-34.6	Micro-Strains	
Cable#	16	001399	Volts	DC	+8.4	Micro-Strains	
Cable#	17	003165	Volts	DC	-24.7	Micro-Strains	
Cable#	18	003356	Volts	DC	-4.4	Micro-Strains	
Cable#	19	003515	Volts	DC	-62.4	Micro-Strains	
Cable#	20	003418	Volts	DC	-35.4	Micro-Strains	
Cable#	21	002059	Volts	DC	+2.8	Micro-Strains	
Cable#	22	+.002837	Volts	DC	-4.3	Micro-Strains	
Cable#	23	002099	Volts	DC	-39.0	Micro-Strains	
Cable#	24	001714	Volts	DC	-15.9	Micro-Strains	
Cable#	25	002529	Volts	DC	+17.1	Micro-Strains	

LVDT: -0.067273 VDC 0.000136 Inches

Hor. Rad. = .001888 VDC 124.4 W/M^2

Position #9 RT

Time:	12:27:57	7 Date: 88	3/08/20	0		
Group#	3	Record#	4			
File na	ame: SRE	DØB11				
Power :	supply:	4.9782	Volts	DC		
Cable#	1	007198	Volts	DC	-102.3	Micro-Strains
Cable#	2	+.001751	Volts	DC	+50.5	Micro-Strains
Cable#	3	+.001001	Volts	DC	+44.4	Micro-Strains
Cable#	4	001577	Volts	DC	-63.5	Micro-Strains
Cable#	5	001255	Volts	DC	-114.5	Micro-Strains
Cable#	6	004142	Volts	DC	-68.9	Micro-Strains
Cable#	7	000734	Volts	DC	+92.4	Micro-Strains
Cable#	8	001954	Volts	DC	+22.7	Micro-Strains
Cable#	9	001481	Volts	DC	-63.4	Micro-Strains
Cable#	10	+.002832	Volts	DC	+27.5	Micro-Strains
Cable#	11	+.003638	Volts	DC	+40.4	Micro-Strains
Cable#	12	000119	Volts	DC	- 37.1	Micro-Strains
Cable#	13	001527	Volts	DC	-93.3	Micro-Strains
Cable#	14	004258	Volts	DC	-49.2	Micro-Strains
Cable#	15	004259	Volts	DC	+47.4	Micro-Strains
Cable#	16	001156	Volts	DC	+106.2	Micro-Strains
Cable#	17	003051	Volts	DC	+20.6	Micro-Strains
Cable#	18	003200	Volts	DC	+57.6	Micro-Strains
Cable#	19	003708	Volts	DC	-139.1	Micro-Strains
Cable#	200	003535	Volts	DC	-81.9	Micro-Strains
Cable#	21	002026	Volts	DC	+15.9	Micro-Strains
Cable#	22	+.002870	Volts	DC	+8.8	Micro-Strains
Cable#	23	002218	Volts	DC	-86.2	Micro-Strains
Cable#	24	001799	Volts	DC	-49.7	Micro-Strains
Cable#	25	002540	Volts	DC	+12.6	Micro-Strains

## LVDT: -0.067936 VDC 0.000169 Inches

Hor. Rad.=.001709 VDC 112.6 W/M^2

Position #4 RT

Time: 12:30:12 Date: 88/08/20							
Group#	3	Record#	5				
File na	ame: SRI	DØB11					
Power :	supply:	4.9780	Volts	DC			
Cable#	1	007456	Volts	DC	-207.4	Micro-Strains	
Cable#	2	+.001654	Volts	DC	+11.0	Micro-Strains	
Cable#	3	+.001396	Volts	DC	+205.1	Micro-Strains	
Cable#	4	001449	Volts	DC	-11.4	Micro-Strains	
Cable#	5	001033	Volts	DC	-24.1	Micro-Strains	
Cable#	6	004288	Volts	DC	-128.4	Micro-Strains	
Cable#	7	000907	Volts	DC	+22.0	Micro-Strains	
Cable#	8	001738	Volts	DC	+110.6	Micro-Strains	
Cable#	9	001275	Volts	DC	+19.7	Micro-Strains	
Cable#	10	+.002730	Volts	DC	-13.6	Micro-Strains	
Cable#	11	+.003492	Volts	DC	-18.5	Micro-Strains	
Cable#	12	+.000003	Volts	DC	+12.1	Micro-Strains	
Cable#	13	001316	Volts	DC	-8.5	Micro-Strains	
Cable#	14	~.004155	Volts	DC	-7.8	Micro-Strains	
Cable#	15	004382	Volts	DC	-2.2	Micro-Strains	
Cable#	16	000944	Volts	DC	+191.5	Micro-Strains	
Cable#	17	003103	Volts	DC	1	Micro-Strains	
Cable#	18	003066	Volts	DC	+110.8	Micro-Strains	
Cable#	19	003855	Volts	DC	-197.6	Micro-Strains	
Cable#	20	003615	Volts	DC	-113.8	Micro-Strains	
Cable#	21	002000	Volts	DC	+26.2	Micro-Strains	
Cable#	22	+.002913	Volts	DC	+25.9	Micro-Strains	
Cable#	23	002260	Volts	DC	-103.0	Micro-Strains	
Cable#	24	001847	Volts	DC	-68.8	Micro-Strains	
Cable#	25	002559	Volts	DC	+4.8	Micro-Strains	

LVDT: -0.066692 VDC 0.000106 Inches

Hor. Rad.=.001505 VDC 99.1 W/M^2

Position #OFF BRIDGE

Time:	12:33:2	9 Date: 8	8/08/2	0			
Group	‡ 3	Record#	6				
File name: SRDØB11							
Power	supply:	4.9783	Volts	DC			
Cable‡	<b>†</b> 1	~.006951	Volts	DC	-1.7	Micro-Strains	
Cable‡	2	+.001628	Volts	DC	+.4	Micro-Strains	
Cable#	: 3	+.000892	Volts	DC	+.0	Micro-Strains	
Cable‡	; 4	001420	Volts	DC	+.4	Micro-Strains	
Cable#	: 5	000971	Volts	DC	+1.2	Micro-Strains	
Cable#	6	003976	Volts	DC	-1.3	Micro-Strains	
Cable#	: 7	000964	Volts	DC	-1.2	Micro-Strains	
Cable#	8	002009	Volts	DC	+.4	Micro-Strains	
Cable#	9	001324	Volts	DC	0	Micro-Strains	
Cable#	10	+.002764	Volts	DC	+.0	Micro-Strains	
Cable#	11	+.003538	Volts	DC	+.0	Micro-Strains	
Cable#	12	000027	Volts	DC	0	Micro-Strains	
Cable#	13	001299	Volts	DC	-1.6	Micro-Strains	
Cable#	14	004138	Volts	DC	8	Micro-Strains	
Cable#	15	004376	Volts	DC	+.4	Micro-Strains	
Cable#	16	001424	Volts	DC	-1.6	Micro-Strains	
Cable#	17	003102	Volts	DC	+.4	Micro-Strains	
Cable#	18	003346	Volts	DC	4	Micro-Strains	
Cable#	19	003360	Volts	DC	8	Micro-Strains	
Cable#	20	003330	Volts	DC	4	Micro-Strains	
Cable#	21	002067	Volts	DC	4	Micro-Strains	
Cable#	22	+.002847	Volts	DC	4	Micro-Strains	
Cable#	23	002001	Volts	DC	0	Micro-Strains	
Cable#	24	001673	Volts	DC	+.4	Micro-Strains	
Cable#	25	002569	Volts	DC	+.8	Micro-Strains	
LVDT:	-0.06479	9 VDC	0.000	011	Inches		

Hor. Rad.=.001584 VDC 104.3 W/M^2