

MATERIAL REQUIREMENTS	
ENCLOSURE MATERIAL	0.125" TYPE 5052-H32 ALUMINUM
TIME CLOCK	RTC AP41-L
FLASHER	EDI 810
HEATER	VULCAN OS1208-150A
THERMOSTAT	WHITE ROGERS 230-22
MAIN BREAKER	15A
AUXILIARY BREAKER	20A
TRANSIENT VOLTAGE SURGE PROTECTION	TESCO 15A
RADIO INTERFACE SUPPRESSOR	HESCO LF60
LOCK	BEST "BM" SERIES

NO.	DATE	REVISION	STATE	PROJECT DESIGNATION	YEAR	SHEET NO.	TOTAL SHEETS
			ALASKA	XXXXXXXX/XXXXXXXXXXXX	20XX	H##	HXX

NOTES:

1. LEAVE THREE FEET OF SLACK WIRE FROM CONTROLLER (TIME SWITCH) IN CABINET.
2. NEATLY WRAP AND/OR SECURE ALL WIRING IN CABINET.
3. FURNISH AN UNPAINTED NEMA 3R ENCLOSURE CONSTRUCTED OF MATERIAL SPECIFIED IN MATERIAL REQUIREMENTS TABLE.
4. MANUFACTURER SUPPLIED WIRING DIAGRAM AND CONTROLLER MANUAL SHALL BE PROVIDED BY CONTRACTOR AND LOCATED IN DOOR POUCH, ALSO TO BE SUPPLIED.
5. CABINET IS TO INCLUDE ALL EQUIPMENT SHOWN AND NEEDED FOR OPERATION INCLUDING ITEMS IN THE MATERIAL REQUIREMENTS TABLE OR APPROVED EQUALS.
6. WIRING DIAGRAM IS FOR GENERAL LAYOUT PURPOSE ONLY. ADDITIONAL WIRING TO TIME CLOCK AND/OR CABINET MAY BE REQUIRED AS CALLED FOR IN PLANS AND SPECS.

